



November 17, 2016

**THE REGIONAL MUNICIPALITY OF YORK
ADDENDUM # 9
T-16-11**

FOR: Construction of the New Paramedic Response Station# 19
LOCATION: 415 Harry Walker Parkway South, in the Town of Newmarket, Ontario
CLOSING: November 18, 2016 at 1:00 P.M. (Local time)

Bidders are requested to incorporate the changes/clarifications noted below to the above tender documents in your possession and be governed accordingly.

Responses to Bidders' Questions:

Question: Please could you confirm who is to supply the single-phase transformer vault? Will this be supplied by Newmarket Hydro under the \$40,000 cash allowance, or by the General Contractor?

Response: Transformer Vault will be supplied by the General Contractor. The transformer vault shall conform to Newmarket Hydro' standards.

Yours truly,

Jamie Oakley
Senior Purchasing Analyst
Supplies and Services