Michael Pacholok
Chief Procurement Officer

Purchasing and Materials Management Division
City Hall, 18th Floor, West Tower
100 Queen Street West
Toronto, Ontario M5H 2N2

Justin Lau
Manager, Corporate Services and Finance & Treasury Services, Purchasing Client Services, Purchasing and Materials Management Division

April 12, 2022

Via Ariba internet posting
(2 Pages + Attachments)

ADDENDUM No. 5
REQUEST FOR TENDER ARIBA Doc3398579373
CLOSING DATE (REVISED): 12:00 NOON (LOCAL TIME), April 19, 2021

For: Toronto Accessibility Upgrades – Group 29 at Toronto, Ontario

Please refer to the above Tender Call document in your possession and be advised of the following information:

1. REVISIONS

The attached items provide clarification for bidders.

2. QUESTIONS

Q1 – On building 843 Palmerston, Addenda 4, Page S 5401, the demolition section is different from the proposal section. Which one should we follow? In other words, the area of the S.O.G at the demolition is bigger than the proposal. As well as the backfill, not clear. Should it be granular or concrete?
Could you please send a clearer proposal section?

A1 – Due to the difficulty of providing 2:1 sloped excavation in the current building, we changed the drawing back to the original way of excavation. However, using sonotube foundation is recommended. As a result, the extent of excavation and the existing concrete slab are clear now. Refer to attached revised drawings for additional clarification.

Q2 – Provide specs for sign type A1.1 and A1.2
A1.1 L1 008 Division ID Toronto Public Library
A1.2 L1 009 Division ID South Riverdale Child Parent Centre Braille

A2 – The details are noted on Sheet D1902 in the bottom right quadrant. This sheet was issued as addendum #3.
The only difference between A1.1 and A1.2 will be 1 line vs 2 lines of text.
Also one additional note the message schedule incorrectly shows braille on this sign and there should not be.

Please continue to monitor this procurement as further extensions or possible cancellation may occur. Please see **www.toronto.ca/covid19** for more information on the City's response. Should you have any questions regarding this addendum send via the event message board or contact Max Parker by email at **Max.Parker@toronto.ca.**

Bidders must acknowledge receipt of all addenda on the space provided on the submission form as per the Process Terms and Conditions, Part 1.7 - Addenda, of the RFT document. All other aspects of the RFT remain the same.

Sincerely,

Clarman Yang

Clarman Yang
Supervisor, Corporate Purchasing
Purchasing and Materials Management Division