

April 12, 2022

Via Ariba internet posting
(1 Page)

ADDENDUM No. 6
REQUEST FOR TENDER ARIBA Doc3398579373
CLOSING DATE (REVISED): 12:00 NOON (LOCAL TIME), April 26, 2021

For: Toronto Accessibility Upgrades – Group 29 at Toronto, Ontario

Please refer to the above Tender Call document in your possession and be advised of the following information:

1. REVISIONS

The Closing Date for this call has been extended from April 19 to **April 26, 2022**. The question period for this call has ended.

2. QUESTIONS

Q1: Drawing D1401 calls for powder coated guards and handrails. This process cannot be done on site due to welding. We recommend painting the handrails.

A1 - Where welding on site is required for situations where installation of replacement handrails is to existing in-situ elements, painting is acceptable as the finish. All connections are to be grinded and smoothed prior to paint finish. Powder coating to be used in all other situation.

Please continue to monitor this procurement as further extensions or possible cancellation may occur. Please see www.toronto.ca/covid19 for more information on the City's response. Should you have any questions regarding this addendum send via the event message board or contact Max Parker by email at Max.Parker@toronto.ca.

Bidders must acknowledge receipt of all addenda on the space provided on the submission form as per the Process Terms and Conditions, Part 1.7 - Addenda, of the RFT document. All other aspects of the RFT remain the same.

Sincerely,



Clarman Yang
Supervisor, Corporate Purchasing
Purchasing and Materials Management Division