

2022-12-08 10:26:40 AM

1

E1101

POWER AND SYSTEMS DEMOLITION PLAN FIRST FLOOR

Scale: 1 : 100


NOTES:

1.

LIGHTING SWITCHES INDICATED ARE IMPACTED BY DOOR OR WALL DEMOLITION AND ARE TO BE REMOVED. SEE PROPOSED PLAN FOR NEW LOCATIONS. WALLS ARE BLOCK, NEW LIGHTS TO BE SURFACE MOUNT WITH WIREMOLD.


2.

RELOCATE EXISTING EMERGENCY LIGHT BATTERY PACK IMPACTED BY CREATION OF NEW WALL.



CLIENT

CITY OF TORONTO



55 John ST.
TORONTO, ON
M5V 3C6

COPYRIGHT

This drawing has been prepared solely for the intended use, thus any reproduction or distribution for any purpose other than authorized by IBI Group is forbidden. Written dimensions shall have precedence over scaled dimensions. Contractors shall verify and be responsible for all dimensions and conditions on the job, and IBI Group shall be informed of any variations from the dimensions and conditions shown on the drawing. Shop drawings shall be submitted to IBI Group for general conformance before proceeding with fabrication.

IBI Group Professional Services (Canada) Inc.
is a member of the IBI Group of companies


ISSUES

No.	DESCRIPTION	DATE
A	50% SUBMISSION	2021-09-23
B	90% SUBMISSION	2022-01-04
C	ISSUED FOR PERMIT	2022-01-04
D	ISSUED FOR TENDER	2022-05-25
E	ISSUED FOR TENDER	2022-09-12
F	RE-ISSUED FOR TENDER	2022-11-01
G	ADDENDUM 1	2022-12-08

CONSULTANTS

SEAL

PRIME CONSULTANT



IBI GROUP
175 Galaxy Blvd, Unit 100
Toronto, ON M9W 0C9, Canada
tel 416 679 1930 fax 416 675 4620
ibigroup.com

PROJECT TITLE

CITY OF TORONTO
ACCESSIBILITY UPGRADES

PROJECT ADDRESS

West Scarborough Community
Centre
313 Pharmacy Ave.

PROJECT NO:

122260

DRAWN BY:

V. MAC

CHECKED BY:

M. BOJIC

PROJECT MGR:

F. BOLOURIAN

APPROVED BY:

P. WILLIAMS

SHEET TITLE

ELECTRICAL
DEMOLITION PLAN 1ST
FLOOR

SHEET NUMBER

G28-184-E1101

ISSUE

G

BM 380/122260 - CoT TAU Upgrades R2020122260-TAU-28-184-313PHRMCY-E-R201.rvt
1 mm

ISSUES		
No.	DESCRIPTION	DATE
A	50% SUBMISSION	2021-09-23
B	90% SUBMISSION	2022-01-04
C	ISSUED FOR PERMIT	2022-01-04
D	ISSUED FOR TENDER	2022-05-25
E	ISSUED FOR TENDER	2022-09-12
F	RE-ISSUED FOR TENDER	2022-11-01
G	ADDENDUM 1	2022-12-08

CONSULTANTS

SEAL

PRIME CONSULTANT




PROJECT TITLE
**CITY OF TORONTO
ACCESSIBILITY UPGRADES**

PROJECT ADDRESS
**West Scarborough Community
Centre**
313 Pharmacy Ave.

PROJECT NO:
122260
DRAWN BY:
V. MAC
PROJECT MGR:
F. BOLOURIAN
CHECKED BY:
M. BOJIC
APPROVED BY:
P. WILLIAMS

SHEET TITLE
**POWER & SYSTEMS
PLAN 1ST FLOOR**

SHEET NUMBER
G28-184-E2101
ISSUE
G



1 POWER AND SYSTEMS PLAN FIRST FLOOR
E2101 Scale: 1 : 100

- NOTES:
1. PROVIDE POWER DOOR OPERATOR CONNECTIONS AS INDICATED, 15A 120V 1P CIRCUITS UNLESS OTHERWISE NOTED. CIRCUITS SHOWN ARE FOR GROUPING PURPOSES ONLY. FILL SPACE AS AVAILABLE. CIRCUIT NEW LOADS FROM NEW 15A BREAKER CIRCUITS FROM PANEL LPF. TAKE INVENTORY OF DEMOLISHED CIRCUITS IN CHANGEROOM/WASHROOM AREA AND COMPILER LIST OF SPARE CIRCUITS AND ASSIGN TO NEW LOADS ACCORDINGLY. EXTEND WIRING/CONDUIT TO SUIT.
 2. PROVIDE MONITOR SWITCH CONNECTIONS ON INDICATED DOORS. FOR NEW GYM DOORS CONNECT NEW MONITOR SWITCHES TO SECURITY ALARM SYSTEM IN BASEMENT STORAGE ROOM 13.
 3. PROVIDE NEW LIGHTS IN CHANGE ROOMS AS INDICATED, SURFACE MOUNT ON CONCRETE CEILING.
 4. PROVIDE NEW FIRE ALARM SPEAKERS TO REPLACE EXISTING IN CHANGE ROOMS.
 5. PROVIDE NEW LIGHT SWITCH TO CONTROL EXISTING LIGHTS CONTAINED BY NEW STORAGE ROOM. SAME CIRCUIT TO REMAIN. CONTROL TO BE SPLIT BETWEEN PRINT ROOM AND NEW STORAGE ROOM

Scale 1:100
0 2.5 5 10 m