



The City of Vaughan
Procurement Services
Department
2141 Major Mackenzie
Drive
Vaughan, ON L6A 1T1
Tel (905) 832-8555

ADDENDUM NOTICE

Addendum #: 7

Bid No: T24-253

Description: General Contracting Services for New Fire Station 7-12

Closing Date: Monday, June 10, 2024 3:00 PM

THE additions, deletions and/or revisions as hereinafter specified, shall form an integral part of the bid document and shall be read in conjunction with the requirements set forth in the bid document.

THE Addendum shall take precedence over all requirements to the aforementioned information in which it may prove to be at variance.

Question 1:

Addendum 5 Q&A 33.4 the response is yes to painting all exposed ceilings. What specifically on the ceilings is being painted? And please confirm CLT ceilings are left unpainted, but sealed as per the CLT specification.

Answer 1:

All paintable ceilings, i.e. gypsum board, exposed metal deck, are to be painted. CLT ceilings shall be left unpainted, but sealed as per Section 06 17 19.

THIS Addendum shall be acknowledged in the spaces provided online, stating that "I have reviewed the addendum".

THIS Addendum has been issued by the City of Vaughan and is in effect as of the addendum issue date.

Procurement Services Department

City of Vaughan