

PANEL : 1A (CONT.)										SHT. 2 OF 2			
DESCRIPTION	BKRK SIZE	WATTS PER PHASE			CIR NO	BUS	CIR NO	WATTS PER PHASE			BKRK SIZE	DESCRIPTION	
		A	B	C				A	B	C			
RECEPTACLES	15A	600			61		62	3000			40A	RANGE	
RECEPTACLES	15A		600		63		64		3000			15A	RANGEHOOD
RECEPTACLES	20A			600	65		66			600		20A	RECEPTACLES
RECEPTAC	15A	600			67		68	600				20A	RECEPTACLES
ELECTRIC STRIKES	15A				69		70	600				20A	RECEPTACLES
FACP (3/12+GRD-.21mmc)	15A			100	71		72			600		20A	RECEPTACLES
	2P	100			73		74	600				20A	RECEPTACLES
FIRE ALARM MONITORING PANEL (FMP)	15A		100		75		76	100				15A	SPARE
TRAP SEAL PRIMERS	15A *				77		78		100		100	15A	SPARE
ELECTRONIC FAUCETS	15A *	100			79		80	100				15A	GEN. ANNUNCIATOR PANEL
SPARE	15A				81		82		600			20A	RECEPTACLES
SPARE	15A				83		84					60A	GENERATOR PANEL
SPARE	15A				85		86	800				3P	
SPARE	15A				87		88		800				
SPARE	15A				89		90					20A	SPARE
SPARE	15A				91		92					20A	SPARE
SPARE	15A				93		94					20A	SPARE
SPARE	15A				95		96					20A	SPARE
SPARE	15A				97		98					20A	SPARE
SPARE	15A				99	100					20A	SPARE	
SPARE	15A *				101	102					20A	SPARE	
EXH. FAN HEF-1	15A	300			103	104					20A	SPARE	
EXH. FAN EF-2	15A		100		105	106					20A	SPARE	
EXH. FAN EF-4	15A			100	107	108					20A	SPARE	
EXH. FAN EF-6	15A	200			109	110	1000				50A	EXH. FAN EF-5	
EXH. FAN EF-11	15A		100		111	112		1000			2P		
					113	114							
					115	116							
					117	118							
					119	120							
* - DENOTES "GFY" TYPE OF BREAKER		8200	5800	6200	TOTALS		11800	13100	7200				
						20000		15000	13400				
52.3 kW		CONNECTED LOAD								120/208 VOLTS			
161.3 A		TOTAL AMPS								400 MAIN			
ELECT. RM.-131		LOCATION								120/2 CCTS/TUBS			

④ —DENOTES "WFO" TYPE OF BREAKER

PANEL		2A		PANEL SCHEDULE											
DESCRIPTION	BKRZ	WATTS PER PHASE			CIR NO	BUS ABC	CIR NO	WATTS PER PHASE			BKRZ SIZE	DESCRIPTION			
		A	B	C				A	B	C					
LIGHTING	20A	400					1	1000			15A 2P	HEATER			
NIGHT LIGHTING	20A		200				2		1000		15A 2P	HEATER			
BATTERY UNIT BU-3	20A			600	5		4			1000	15A 2P	MOTORIZED DAMPERS			
EXIT LIGHTS	15A	100					7	1000			15A	RECEPTACLES			
	15A		1000				9		100		15A	RECEPTACLES			
HOT WATER TANK HWMT-1	3P			1000	11		12		800	15A	EXH. FAN EF-3				
		1000			13		14	800			25A	PUMP P-1			
			1000		15		16		100		25A	PUMP P-2			
HOT WATER TANK HWMT-2	15A			1000	17		18		700		25A	PUMP P-3			
	3P				19		20	700			25A	PUMP P-4			
					21		22		700		20A	SPARE			
UPS	20A 2P				23		24		700		20A	SPARE			
REC-CIRC. PUMP	15A	200			25		26	700			20A	SPARE			
DMS SYSTEM	15A				27		28		700		20A	SPARE			
FIRE ALERT SYSTEM	15A				29		30		500		20A	SPARE			
DOOR ACCESS PANEL	15A				31		32	500			20A	SPARE			
SECURITY PANEL	15A				33		34		500		20A	SPARE			
RECEPTACLES	20A				35		36		500		20A	SPARE			
RECEPTACLES	20A				37		38				20A	SPARE			
SPARE	15A				39		40				20A	SPARE			
SPARE	15A				41		42				20A	SPARE			
SPARE	15A				43		44				20A	SPARE			
SPARE	15A				45		46				20A	SPARE			
SPARE	15A				47		48				20A	SPARE			
SPARE	15A				49		50				20A	SPARE			
SPARE	15A				51		52				20A	SPARE			
SPARE	15A				53		54				20A	SPARE			
SPARE	15A				55		56				20A	SPARE			
SPARE	15A				57		58				20A	SPARE			
SPARE	15A *				59		60								
		3700	3200	3600	TOTALS			4700	3100	4200					
					8400	6300	7800								
* - DENOTES "GFI" TYPE OF BREAKER															
22.5 KW		CONNECTED LOAD								120/208		VOLTS			
69.4 A		TOTAL AMPS								225		MAIN			
MECH. RM.-143 (MEZZANINE)		LOCATION								60/1		CCTS/TUBS			
Ⓢ - DENOTES "AFO" TYPE OF BREAKER															

[illegible]