


1. THIS IS A TYPICAL SCHEMATIC ONLY FOR CAPTION OFFICE-104 . SAME CONCEPT SHALL APPLY FOR LIGHTING CONTROL OF SIMILAR ROOMS/AREAS EXCEPT THAT LV DIMMER SWITCHES, ROOM CONTROLLERS & OCCUPANCY SENSORS ETC. SHALL BE PROVIDED AS REQUIRED AS PER LIGHTING LAYOUT OF THE RESPECTIVE ROOM/AREA.

⬠ TO BE WIRED TO THE DIMMABLE LIGHT FIXTURES.



2 LIGHTING CONTROL SCHEMATICS (TYP.)
E7.1 N.T.S.

3 LIGHTING CONTROL SCHEMATICS (TYP.)
E7.1 N.T.S.

E7.1