

NOTES:-

1. PROVIDE FIRE ALARM GRAPHICS TO BE INSTALLED ADJACENT TO THE LED ANNUNCIATOR IN THE MAIN ENTRANCE.
2. 'FZ'- DENOTES FIRE ALARM ZONE
3. 'SZ'- DENOTES SUPERVISORY ZONE
4. 'CZ'- DENOTES CONTROL ZONE
5. 'S.D'- DENOTES SMOKE DETECTOR
6. 'P.S'- DENOTES PULL STATION
7. 'H.D'- DENOTES HEAT DETECTOR
8. 'D.S'- DENOTES DUCT SMOKE DETECTOR
9. FOR NUMBER AND LOCATION OF DEVICES REFER TO FLOOR PLANS.
10. PROVIDE WIRING IN CONDUIT FOR COMPLETE OPERATIONAL SYSTEM
11. ALL PULL STATIONS SHALL BE C/W PLASTIC COVERS WITH LOCAL HORN.
12. PROVIDE ISOLATORS FOR EVERY ONE TO TWO HOUR RATED FIRE COMPARTMENT.
13. ALL LOOP WIRING FOR INITIATING CIRCUITS SHOULD RUN ON SEPARATE ROUTE INCLUDING RISER.
14. SOUND ALL AUDIBLE SIGNALS AND SHUT DOWN AIR SYSTEM IN CASE OF GENERAL ALARM.
15. PROVIDE CONNECTIONS C/W EMT CONDUIT AND WIRING TO ALL FIRE PROTECTION EQUIPMENT AND DEVICES (SPRINKLER SYSTEM) SHOWN ON THE FIRE ALARM ZONE SCHEDULE AS ALARM OR SUPERVISORY ZONE. REFER TO MECHANICAL DRAWINGS AND COORDINATE WITH MECHANICAL CONTRACTOR FOR LOCATIONS OF DEVICES PRIOR TO ROUGH IN. ALSO COORDINATE WITH SPRINKLER CONTRACTOR FOR ALARM ZONE AREAS BOUNDARIES AND LIMITATIONS AND COMPLY ACCORDINGLY.



PROJECT:
CITY OF VAUGHAN FIRE
STATION 7-12
9541 WESTON ROAD, VAUGHAN

THE CONTRACTOR SHALL VERIFY ALL DIMENSIONS PRIOR TO COMMENCEMENT OF THE WORK. ANY DISCREPANCIES ARE TO BE REPORTED TO THE CONSULTANT.

FIRE ALARM SYSTEM



E6.0