



KEYNOTE LEGEND	
Key Value	Keynote Text
E1	PROVIDE ONE DATA DROP TO WIRELESS ACCESS POINT (WAP) MODEL C8130. MOUNT WAP DIRECTLY ON CEILING (DRYWALL OR DROP CEILING, AS NOTED ON RFP).
E2	PROVIDE ONE DATA DROP TO WAP MODEL C8120. MOUNT WAP ON WALL APPROXIMATELY 9'10" TO 11' AFF.
P2	TWO TRANSFORMERS STACKED ONE ON TOP OF THE OTHER, COMPLETE WITH ENGINEERED STRUCTURAL CHANNEL SUPPORT. CONTRACTOR TO HIRE STRUCTURAL ENGINEER TO PROVIDE SEALED DETAIL DURING SUBMITTAL REVIEW PHASE.
P3	CONFIRM EXACT LOCATION OF DEVICE WITH THE OWNER PRIOR TO ROUGH-IN. PROVIDE LAMACOID NAMEPLATE INDICATING FUNCTION OF THE BUTTON.
P4	PROVIDE AUDIBLE ALARM FOR NOTIFICATION VIA PA SYSTEM TO THE IN-STATION STAFF. SEQUENCE OF OPERATION INITIATE AUDIBLE ALARM WHEN ENTRY IS MADE INTO THE BUILDING. DO NOT INITIATE AUDIBLE ALARM WHEN AN EXIT IS MADE.
P6	CONTRACTOR TO REVIEW FOUR FOLD DOOR SHOP DRAWINGS AND CONFIRM CONDUIT REQUIREMENTS FOR DOOR STATUS. WHETHER PROVIDED BY DOOR CONTACTS SENSOR ON THE DOOR, OR BY STATUS CONTACT IN THE CONTROL PANEL FOR EACH RESPECTIVE DOOR. CONTRACTOR TO INCLUDE FOR CONDUIT ROUGH-IN BASED ON EITHER SCENARIO.
P7	FOR TV IN DAY ROOM, PROVIDE LEGRAND EFSB4 4-GANG WALL BOX TO CONSOLIDATE POWER AND DATA BEHIND TV. PROVIDE DUPLEX RECEPTACLE AND AV PASS THRU BELOW TV SIMILAR TO DETAIL FOR TV AND DINING ROOM.
P8	ALTERNATIVE PRICE NO.1: CREDIT TO DELETE IN-FLOR RADIANT HEATING SYSTEM, DELETE BREAKERS, FEEDERS AND LOCAL DISCONNECTS FOR THE FOLLOWING EQUIPMENT: RFH-1, RFH-2, B-1, P-2 and P-3.
P9	ALTERNATIVE PRICE NO.2: DELETE 4-FOLD DOOR, AND IN LIEU, ADD OVERHEAD SECTIONAL DOOR, FOR POWER, DELETE 15A/3P CIRCUIT AND ADD 20A/2P CIRCUIT (BREAKER, FEEDER AND LOCAL DISCONNECT) TO SUIT 1HP, 208V/1PH OHD.
P10	APPARATUS BAY IS TO BE CONSIDERED A WET LOCATION, DEFINED AS CATEGORY 1 IN DESC SECTION 22.


- GENERAL SHEET NOTES**
- IN APPARATUS BAY, PROVIDE WEATHERPROOF WHILE IN USE COVER FOR ALL RECEPTACLES.



MISSISSAUGA

**CITY OF MISSISSAUGA
FIRE STATION 123**

3050 THE COLLEGEWAY
MISSISSAUGA, ONTARIO
CANADA



**architecture
interiors
urban design**

25 Main Street West
Hamilton, Ontario
L8P 1H1 Canada

T: 905-522-0220



**QUASAR
CONSULTING GROUP**

250 ROWNTREE DAIRY RD, WOODBRIDGE, ON

TEL: 905-507-0800
WEB: WWW.QUASARCG.COM

DRAWINGS ARE NOT TO BE SCALED.

CONTRACTOR MUST VERIFY ALL DIMENSIONS ON THE JOB AND REPORT ANY DISCREPANCY TO ARCHITECTS BEFORE PROCEEDING WITH WORK.


ALL DRAWINGS AND SPECIFICATIONS ARE THE PROPERTY OF THE ARCHITECT AND MUST BE RETURNED AT THE COMPLETION OF THE WORK.

SEALS

NO.	ISSUES/REVISIONS	DATE
9	ISSUED FOR ADDENDUM E-ADD-04	2024-07-02
8	ISSUED FOR TENDER	2024-05-01
7	ISSUED FOR TENDER	2024-05-01
6	ISSUED FOR TENDER REVIEW	2024-03-08
5	ISSUED FOR PERMIT	2024-01-24
4	ISSUED FOR 99% CD	2024-01-19
3	ALECTRA COORDINATION	2023-12-18
2	ISSUED FOR DESIGN DEVELOPMENT	2023-10-06
1	ELECTRA SERVICE REQUEST	2023-08-11

DRAWING TITLE:

**POWER AND SYSTEMS
PLAN**



ISSUE DATE: 2024-07-02

DRAWN BY: MS CHECKED BY: CB

PROJECT NO.: CM-22-281 SCALE: As Indicated

DRAWING NO.: REVISION: