




KEYNOTE LEGEND	
Key Value	Keynote Text
E1	PROVIDE ONE DATA DROP TO WIRELESS ACCESS POINT (WAP) MODEL C8130. MOUNT WAP DIRECTLY ON CEILING (DRY WALL OR DROP CEILING, AS NOTED ON RCP).
E2	PROVIDE ONE DATA DROP TO WAP MODEL C8120. MOUNT WAP ON WALL APPROXIMATELY 9' TO 11' R.F.F.
P2	TWO TRANSFORMERS STACKED ONE ON TOP OF THE OTHER, COMPLETE WITH ENGINEERED STRUCTURAL CHANNEL SUPPORT. CONTRACTOR TO HIRE STRUCTURAL ENGINEER TO PROVIDE SEALED DETAIL DURING SUBMITTAL REVIEW PHASE.
P3	CONFIRM EXACT LOCATION OF DEVICE WITH THE OWNER PRIOR TO ROUGH-IN. PROVIDE LAMACOID NAMEPLATE INDICATING FUNCTION OF THE BUTTON.
P4	PROVIDE AUDIBLE ALARM FOR NOTIFICATION VIA PA SYSTEM TO THE IN-STATION STAFF. SEQUENCE OF OPERATION INITIATE AUDIBLE ALARM WHEN ENTRY IS MADE INTO THE BUILDING. DO NOT INITIATE AUDIBLE ALARM WHEN AN EXIT IS MADE.
P6	CONTRACTOR TO REVIEW FOUR FOLD DOOR SHOP DRAWINGS AND CONFIRM CONDUIT REQUIREMENTS FOR DOOR STATUS. WHETHER PROVIDED BY DOOR CONTACTS SENSOR ON THE DOOR, OR BY STATUS CONTACT IN THE CONTROL PANEL FOR EACH RESPECTIVE DOOR. CONTRACTOR TO INCLUDE FOR CONDUIT ROUGH-IN BASED ON EITHER SCENARIO.
P7	FOR TV IN DAY ROOM, PROVIDE LEGRAND EFS84 4-GANG WALL BOX TO CONSOLIDATE POWER AND DATA BEHIND TV. PROVIDE DUPLEX RECEPTACLE AND AV-PASS THRU BELOW TV SIMILAR TO DETAIL FOR TV AND DINING ROOM.
P8	COMPONENT PRICE NO. 1: ADD IN-FLOOR RADIANT HEATING SYSTEM. PROVIDE BREAKERS, FEEDERS AND LOCAL DISCONNECTS FOR THE FOLLOWING: EQUIPMENT: RPH-1, RPH-2, B-1, P-2 and P-3.
P9	SUBSTITUTION PRICE NO. 1: DELETE 4-FOLD DOOR AND IN LIEU, ADD OVERHEAD SECTIONAL DOOR. FOR POWER, DELETE 15A/SP CIRCUIT AND ADD 20A/2P CIRCUIT (BREAKER, FEEDER AND LOCAL DISCONNECT) TO SUIT THP, 208V/1PH/0.0.
P11	OUTLET BOX FOR WEATHERPROOF EXTERIOR MUSHROOM STYLE BUTTON TO CLOSE THE 4-FOLD DOOR FROM THE EXTERIOR OF THE BUILDING. REDUNDANT TO AUTO CLOSE OR REMOTE CLOSE FEATURE OF DOOR. PROVIDE 21 mm CONDUIT AND CONTROL WIRE TO DOOR CONTROLLER. DOOR MANUFACTURER TO PROVIDE MUSHROOM STYLE OPERATOR.
GENERAL SHEET NOTES	
1.	IN APPARATUS BAY, PROVIDE WEATHERPROOF WHILE IN USE COVER FOR ALL RECEPTACLES.

NO.	ISSUES/REVISIONS	DATE
9	ISSUED FOR ADDENDUM E-ADD-05	2024-07-05
8	ISSUED FOR TENDER	2024-05-01
7	ISSUED FOR TENDER	2024-05-01
6	ISSUED FOR TENDER REVIEW	2024-03-08
5	ISSUED FOR PERMIT	2024-01-24
4	ISSUED FOR 99% CD	2024-01-19
3	ALECTRA COORDINATION	2023-12-18
2	ISSUED FOR DESIGN DEVELOPMENT	2023-10-06
1	ALECTRA SERVICE REQUEST	2023-08-11

NO.		ISSUES/REVISIONS		DATE	
DRAWING TITLE:					
POWER AND SYSTEMS PLAN					
ISSUE DATE:				2024-07-05	
DRAWN BY: MS		CHECKED BY: CB			
PROJECT NO.: CM-22-281		SCALE: As indicated			
DRAWING NO.:				REVISION:	