



THE REGIONAL MUNICIPALITY OF YORK

ADDENDUM # 2

BID # RTFC-1339-23-C23002

DATE: Wednesday, July 3, 2024

FOR: Renovation Projects Including Office Space, Corridor, and Washroom Renovations, known as Package D, at the York Region Administrative Centre, Located at 17250 Yonge Street in the Town of Newmarket

CLOSING DATE: Monday, July 15, 2024 1:00 PM

Bidders are requested to incorporate the changes/clarifications noted below to the above noted Bid Documents in your possession and be governed accordingly.

1. BIDDERS QUESTIONS (Q) AND REGION'S RESPONSES (A)

Question 1:

There are one access door on the third floor and four access doors on the 4th floor. But the spec doesn't have a security section, please confirm if it's required

Answer 1:

For the third floor, contractor is to relocate security components from existing door and frame. Existing frame to be reused. Contractor to supply new door per drawing 6/A600.

Relocation of security devices must be the following installers. Installer is to run all NEW cables/wires. Splicing of existing wires will not be allowed.

AC Electric	Chambers, Alex estimating@acelectricinc.ca (416) 939-0244
CEC Services Inc.	Kyle Feinstein estimating@beswickgroup.com (905) 713-3711
Electro-Works Ltd.	Dondi Keough dondi@tcsecure.ca (416) 529-7180
Ozz Electric	Mike Calitri mcalitri@ozzelectric.com (416) 891-8102

There are NO new security equipment on the 4th floor. There are existing security devices at those doors and can remain.

Bidders shall acknowledge receipt of all addenda to this RFT prior to submitting their Bid. Bids that do not contain evidence of receipt of all addenda will be deemed to be “incomplete” and will not be accepted in the Bidding Website.

This addendum shall remain attached to and form part of the Contract Documents.

Thank you,

Kim Froats

Kim Froats

Purchasing Analyst
Procurement Office

Attachments: NA