

## ADDENDUM



<b>To:</b>	ATA Architects Inc. 211 Lakeshore Road East Oakville, Ontario L6J 1H7	<b>No.:</b>	<b>ADD-E01</b>
<b>Fax/Email:</b>	mark@ataarchitectsinc.com	<b>Date:</b>	October 22, 2024
<b>Attention:</b>	Mark Driedger	<b>Project:</b>	Fire Hall 7-1 835 Clark Ave. W., Vaughan, ON
<b>From:</b>	Dhanu Das	<b>Project No.:</b>	<b>2021-0158</b>

This Addendum shall be attached to the drawings and specifications and shall form an integral part of the Contract Documents. The contents of this Addendum shall be brought to the attention of all concerned.

1. **RTU-1 specification change (refer Mechanical Addendum M02 dated 21.10.2024)**
  - 1.1. Drawing E-501-04 – Single Line Diagram – New (drawing not re-issued)
    - 1.1.1. RTU-1 selection updated as previous selection is no longer available.
    - 1.1.2. Update breaker and cable from 80A-3P (3#4AWG CU+G in 35mmC) to 150A-3P (3#2AWG CU+G in 35mmC) in panel DP-2A01
  - 1.2. Drawing E-702-01 – Mechanical Schedule (drawing not re-issued)
    - 1.2.1. RTU-1 updated specification
      - 1.2.1.1. MCA – 100.5A
      - 1.2.1.2. MOP – 150A

End of Addendum

