



**EXP Services Inc.**  
220 Commerce Valley Drive West, Suite 110  
Markham, Ontario  
L3T 0A8

Telephone: 905.695.3217  
Facsimile: 905.695.0167

## Electrical

### Addendum No. E-04

Reference: Added Scope and clarification

Issue Date: November 12, 2024

Project: UHN TWH – SEM & Corridor (EXP Project Number MRK-23004289-A0)

---

This addendum shall form an integral part of the Bid Documents for the above project and shall be read in conjunction therewith. This addendum shall, however, take precedence over all requirements of the previously issued Drawings and Specifications with which it may prove to be at variance, unless otherwise clarified by the Consultant.

This addendum must be signed by the Bidder in the appropriate space and must be attached to the back of the Bid Form for submission at the time of bidding. Bids not including this addendum signed as requested may be rejected as informal.

---

### **Revisions / Clarifications**

The following changes and clarifications shall be considered when submitting your bid.

#### **1.1. ELECTRICAL DRAWINGS**

##### **1.1.1. E-102 – LEVEL 1 FLOOR PLAN – DEMO- ELECTRICAL**

##### **1.1.2. E-103 – LEVEL 1 FLOOR PLAN – DEMO- POWER SYSTEM**

- .1 Existing BIX location was shown.

##### **1.1.3. E-201 – LEVEL 1 FLOOR PLAN – NEW WORK – LIGHTING LAYOUT**

- .1 Updated lighting control zones.
- .2 Updated lighting circuits.
- .3 Removed/relocated light switches.
- .4 Updated keynotes

- .5 Added/relocated occupancy sensors

**1.1.4. E-202 – LEVEL 1 FLOOR PLAN – NEW WORK – ELECTRICAL AND POWER SYSTEMS**

- .1 Provided new panels for RP-1-1EA and RP-1-1A
- .2 Existing BIX location was shown.
- .3 Added telephone line and power connection.
- .4 Updated power circuits.

**1.1.5. E-204 – BASEMENT FLOOR PLAN**

- .1 Added lighting fixtures and light switches.
- .2 Added new panel and transformer.
- .3 Added scope of modified existing conduits.

**1.1.6. E-205 – PENTHOUSE & ROOF FLOOR PLAN – ELECTRICAL LAYOUT**

- .1 Added/modified electrical panels.
- .2 Added power for motorized dampers.
- .3 Updated circuit and electrical devices.
- .4 Added power connection for duct smoke heating elements.

**1.1.7. E-401 – ELECTRIC DETAILS AND PANEL SCHEDULES**

- .1 Updated panel schedules as shown.

**1.1.8. E-501 – ELECTRICAL RISER DIAGRAM**

- .1 Updated power SLD and systems riser diagram.

----- **END OF ELECTRICAL ADDENDUM No. E-04** -----