



**EXP Services Inc.**  
220 Commerce Valley Drive West, Suite 110  
Markham, Ontario  
L3T 0A8

Telephone: 905.695.3217  
Facsimile: 905.695.0167

## Electrical

### Addendum No. E-05

Reference: Added Scope and clarification

Issue Date: November 19, 2024

Project: UHN TWH – SEM & Corridor (EXP Project Number MRK-23004289-A0)

---

This addendum shall form an integral part of the Bid Documents for the above project and shall be read in conjunction therewith. This addendum shall, however, take precedence over all requirements of the previously issued Drawings and Specifications with which it may prove to be at variance, unless otherwise clarified by the Consultant.

This addendum must be signed by the Bidder in the appropriate space and must be attached to the back of the Bid Form for submission at the time of bidding. Bids not including this addendum signed as requested may be rejected as informal.

---

### **Revisions / Clarifications**

The following changes and clarifications shall be considered when submitting your bid.

#### **1.1. ELECTRICAL DRAWINGS**

##### **1.1.1. E-001 – OVERALL PLAN, LEGEND, ABBREVIATION AND DRAWING LIST**

- .1 Drawings name updated.
- .2 Added/updated legends for receptable and clock system.

##### **1.1.2. E-002 – GENERAL NOTES AND LUMINARIES SCHEDULES**

- .1 Luminaire schedule updated and notes added.

##### **1.1.3. E-003 – SPERATE PRICE PLAN**

- .1 Updated pricing plan.

**1.1.4. E-101 – LEVEL 1 FLOOR PLAN – DEMO – LIGHTING LAYOUT**

- .1 Added keynote.

**1.1.5. E-102 – LEVEL 1 FLOOR PLAN – DEMO – POWER LAYOUT**

- .1 Added keynote.

**1.1.6. E-103 – LEVEL 1 FLOOR PLAN – DEMO – SYSTEM LAYOUT**

- .1 Added keynote.
- .2 Clarified removal and termination of the existing cable tray.

**1.1.7. E-201 – LEVEL 1 FLOOR PLAN – NEW WORK – LIGHTING LAYOUT**

- .1 Updated fixtures schedule.
- .2 Added/relocated lighting switches
- .3 Added note.

**1.1.8. E-202 – LEVEL 1 FLOOR PLAN – NEW WORK – ELECTRICAL AND POWER SYSTEMS**

- .1 Added an enlarged plan for Comm room.
- .2 Provide wooden board in Comm room.
- .3 Added/relocated power connection, receptacles, panic button and patient station.
- .4 Indicated the location of QR registration and intercom station.
- .5 Added note.
- .6 Extended cable tray and connected location with existing cable tray.
- .7 Added photo.

**1.1.9. E-203 – LEVEL 1 FLOOR PLAN – NEW WORK – EXAM ROOMS**

- .1 Relocated/removed devices as shown.
- .2 Added panic button.
- .3 Updated circuit schedule.
- .4 Updated lighting switch details.
- .5 Updated fixture type.

**1.1.10. E-204 – BASEMENT FLOOR PLAN**

- .1 Added photos.
- .2 Updated fixture type for crawl space.
- .3 Added lighting switches, exit signs and fire alarm speakers for crawl space.
- .4 Updated circuits for pumps connection.
- .5 Added note and keynote.
- .6 Provided enlarged plan for ground floor.

**1.1.11. E-205 – PENTHOUSE & ROOF FLOOR PLAN – ELECTRICAL LAYOUT**

- .1 Updated feeder location.
- .2 Added power for AHU pump.
- .3 Updated keynote.

**1.1.12. E-301 – BELOW GRADE FLOOR – ELECTRICAL LAYOUT**

- .1 Updated exit sign symbol.

**1.1.13. E-302 – GROUND FLOOR PLAN – LIGHTING LAYOUT**

- .1 Updated lighting layout. exit sign symbol.

**1.1.14. E-302 – GROUND FLOOR PLAN – POWER LAYOUT**

- .1 Relocated power and system devices.
- .2 Added security devices for existing stair exit.
- .3 Added keynote

**1.1.15. E-401 – ELECTRIC DETAILS AND PANEL SCHEDULES**

- .1 Updated panel schedules and headwall details.

**1.1.16. E-402 – MECHANICAL EQUIPMENY SCHEDULES**

- .1 Updated mechanical schedules.

**1.1.17. E-501 – ELECTRICAL RISER DIAGRAM**

- .1 Updated power SLD and systems riser diagram.

**1.1.18. C-E101 – GROUND FLOOR OVERALL PLAN – ELECTRICAL LAYOUT  
(DRAWING NUMBER UPDATED)**

- .1 Added photos and indicated the existing devices to be removed.
- .2 Updated note and keynote.

**1.1.19. C-E201 – LEVEL 3 FLOOR – ELECTRICAL LAYOUT (DRAWING NUMBER  
UPDATED)**

- .1 Updated section details.

**1.1.20. C-E301 – ELECTRICAL RISER DIAGRAM AND LUMINARIE SCHEDULE  
(DRAWING NUMBER UPDATED)**

- .1 Updated luminaire schedule.

----- END OF ELECTRICAL ADDENDUM No. E-05 -----