

**Senior Services and Long-Term Care
City Of Toronto**

**LAKESHORE LODGE
SERVERY, SHOWER, WASHROOM & TUB ROOM
RENOVATION 2024**

**PROJECT MANUAL
VOLUME 2 – 21508.F02
(2 OF 2)**

ISSUED FOR RETENDER
JUNE 2024

MSA PROJECT NO: 21508.F02

MONTGOMERY SISAM ARCHITECTS INC.
OJDROVIC ENGINEERING
CROSSEY ENGINEERING LTD.
CROSSEY ENGINEERING LTD.
KAIZEN FOODSERVICE PLANNING & DESIGN INC.

ARCHITECTURAL
STRUCTURAL
ELECTRICAL
MECHANICAL
FOODSERVICE

NO	2
----	---

DIVISION 00 - PROCUREMENT AND CONTRACTING REQUIREMENTS

Document	Title	Discipline	Pages
00 01 10	Table of Contents	A	2

DIVISION 01 - GENERAL REQUIREMENTS

Section	Title	Discipline	Pages
01 00 00	General Requirements	A	31
	- Appendix SA Form	A	1

DIVISION 02 - EXISTING CONDITIONS

Section	Title	Discipline	Pages
02 40 00	Demolition and Removals	A	8

DIVISION 03 - CONCRETE

Section	Title	Discipline	Pages
03 51 13	Cementitious Topping	A	3

DIVISION 05 - METALS

Section	Title	Discipline	Pages
05 50 00	Miscellaneous and Metal Fabrications	A	8

DIVISION 06 - WOOD, PLASTICS, AND COMPOSITES

Section	Title	Discipline	Pages
06 10 00	Rough Carpentry	A	4
06 20 00	Finish Carpentry	A	5

DIVISION 07 - THERMAL AND MOISTURE PROTECTION

Section	Title	Discipline	Pages
07 85 00	Firestopping and Smoke Seals	A	7
07 92 00	Sealants	A	7

DIVISION 08 - OPENINGS

Section	Title	Discipline	Pages
----------------	--------------	-------------------	--------------

08 11 13	Metal Doors and Frames	A	6
08 70 00	Door Hardware	A	5

DIVISION 09 - FINISHES

Section	Title	Discipline	Pages
09 21 16	Gypsum Board	A	11
09 65 16	Resilient Sheet Flooring	A	5
09 67 23	Epoxy Flooring	A	4
09 84 15	Hygienic Wall Cladding	A	3
09 91 00	Painting	A	8

DIVISION 10 - SPECIALTIES

Section	Title	Discipline	Pages
10 28 13	Washroom Accessories	A	3
10 80 00	Miscellaneous Specialties	A	3

DIVISION 11 - EQUIPMENT

Section	Title	Discipline	Pages
11 40 00	Food Service Equipment	A	54

DIVISION 22 - PLUMBING

Section	Title	Discipline	Pages
	See Mechanical Drawings.	M	

DIVISION 23 - HEATING, VENTILATING AND AIR CONDITIONING

Section	Title	Discipline	Pages
	See Mechanical Drawings.	M	

DIVISION 26 - ELECTRICAL

Section	Title	Discipline	Pages
	See Electrical Drawings.	E	

1 **SUMMARY OF WORK**

1.1 Work under this Contract covers the following major items.

1.2 The Scope of Work for this Project is to include, but not be limited to the following:

- .1 Level 4 Servery, Dining room and Dish Wash room renovations
- .2 Washrooms, Showers and Tub rooms on Level 2, 3 and 4.
- .3 Adding new condensing unit on roof

2 **ALTERNATIVES**

2.1 All alternatives must be submitted with the bid using Appendix SA. Complete and submit form appended to this Section.

3 **PHASING OF THE WORK**

3.1 The Work of this Contract shall be performed in phases. All Phasing will be subject to approval from the Building Services Manager and as identified in the Ministry Of Health Operational Plan for the Work.

4 **WORK RESTRICTIONS**

4.1 Contractor's Use Of Site

- .1 Use of site is limited to immediate areas of work. Areas designated for storage of material and equipment where specific to the project, are to be coordinated with the Owner and Building Services Manager.
- .2 Do not unreasonably encumber site with materials or equipment. Move stored products or equipment which interfere with operations of Owner and Building Services Manager, or other Contractors. Obtain and pay for use of off-site additional storage, or work areas as required by the Work.
- .3 Sign-in procedures: All Contractors/Subcontractors should sign-in daily meeting City of Toronto standards and CAN/CSA Z317.13 -12 - Infection Control During Construction, Renovation, and Maintenance of Health Care Facilities.

4.2 Coordination with Occupants

- .1 Coordinate performance and sequencing of the Work with the Owner. Notify the Owner 48 hours in advance of noise-generating activities or interruption of any building services which may disrupt normal operations. Do not interrupt building services without Owner's and Building Services Manager's permission.

4.3 Hours of Work

- .1 Hours of work for this contract are generally confined to 8:00am to 5:00pm Monday to Friday. Where required by sequencing of the Work, or where shutdown of building services is required, portions of the Work may be required to be performed outside of regular daily business hours, or on weekends. All Hours of Work permitted will be subject to approval from the Building Services Manager and will be as identified in the Ministry Of Health Operational Plan for the Work.

4.4 Allowances

- .1 Include all allowances listed below in the Bid Price. Expend Cash Allowances as directed by the Consultant. Each Cash Allowance will be adjusted to actual cost as defined hereunder and Contract Price will be amended accordingly by written order. Progress payments for work and material authorized under Cash Allowances will be made in accordance with the Contract. Cash allowances do not include H.S.T. Contractor to include all overhead and profit mark-ups associated with Material (Supply Only) or Assembly (Supply and Install) Cash Allowances.
 - .1 Include the following Allowances in the Bid Price:
 - .1 Amount for the Cash Allowance will be defined in the Bid Sheet.

5 **CONTRACT MODIFICATIONS**

- .1 Supplemental Instruction: as issued by the Consultant, consistent with the intent of the Contract Documents, and will not involve an adjustment in Contract Price or Contract Time.
- .2 Proposed Change: as issued by the Consultant, will notify the Contractor of an impending or proposed change to the Work, and will require submission of a quotation from the Contractor and all affected Subcontractors for each item noted. Submit quotation within the time period stipulated on the form, and indicate separate line items for labour and materials in each case. Work outlined in a Proposed Change must not proceed without the issuance of a Change Order signed by the Owner.
- .3 Change Order: will be issued by the Consultant upon review and approval of quotations for a Proposed Change, or a Change Directive, and authorizes the Contractor to proceed with the change(s) proposed. A Change Order will amend the Contract Price, and/or the Contract Time.
- .4 Fees For Changes to The Work
 - .1 The following fees will apply to the Contract Price for changes to the Work and shall include all statutory charges, applicable duties and taxes, charges required by labour agreements in force, charges related to site and/or office overhead, project management and administration, all shop and field supervision, clerical, drafting, bonding costs, permits, associated payroll costs, and other charges incidental to the work including but not limited to handling, equipment warranty, identification, coordination, scheduling, Bill 208 and WHMIS.
 - .2 The Fees For Changes In The Work shall apply only to extras to the Contract. Contractor or Subcontractor mark-up will not be applied to credits.
 - .3 For all Changes to the Work which may be ordered by the Owner, the following maximum net mark-ups for overhead and profit by the Contractor will be permitted for adjustments in Contract Price in accordance with the General Conditions:

Contractor's Mark-up on Work by Own Forces	Contractor's Mark-up on Subcontracted Work
5%	5%

- .4 For all Changes to the Work which may be ordered by the Owner, the following maximum net mark-ups for overhead and profit by Subcontractors will be permitted for adjustments in Contract Price in accordance with the General Conditions:

Contractor's Mark-up on Work by Own Forces	Contractor's Mark-up on Subcontracted Work
--	--

5%	5%*
----	-----

- .5 (*) Aggregate total of overhead and profit for ALL subtrades within the Subcontractor's Contract.

6 **APPLICATIONS FOR PAYMENT**

6.1 Applications for payment on account may be made monthly as the Work progresses, and shall be preceded by the submission of a Schedule of Values for review by the Consultant.

6.2 The second and all subsequent applications for payment shall include a statement based on the Schedule of Values, a statutory declaration (CCDC 9B), and a standard Workers Compensation Certificate of Clearance.

6.3 The General Contractor to provide cash flow projection for the Work at the project kick-off meeting and maintain the cash flow projection for the duration of the Work with additional submissions monthly with each progress draw.

6.4 Schedule Of Values

.1 Complete Schedule of Values must be submitted at the Project Pre-Construction Meeting. For Phased Work, the Schedule of Values shall identify value of the work by Phase and the value of all Phases must be submitted at the Project Pre-Construction Meeting.

.2 Submit Schedule of Values in spreadsheet form acceptable to the Consultant.

.3 List items of work as separate line items.

.4 The values of the Work shall be listed as to the aggregate percentage and dollar value completed, under the following major headings:

- .1 Initial contract amounts for each line item,
- .2 Progress to Date,
- .3 Percent Complete,
- .4 Current Invoice,
- .5 Previous Billings,
- .6 Contract Balance

.5 Final totals shall identify:

- .1 Total amount
- .2 Holdback deducted
- .3 Holdback released
- .4 Amount invoiced to date
- .5 Net amount
- .6 HST
- .7 Amount due this Certificate

7 **PROJECT MANAGEMENT & COORDINATION**

7.1 Project Coordination

- .1 The Contractor is responsible for the overall coordination of the Work. Coordinate the work of all subcontractors, and provide such assistance as is necessary, including but not limited to;
 - .1 Providing site dimensions and layout,
 - .2 Providing temporary facilities and controls,
 - .3 Scheduling subcontractors work to prevent conflicts,
 - .4 Scheduling and administering regular subtrade scheduling and coordination meetings throughout progress of the Work.
 - .5 Scheduling and administering regular subtrade safety meetings throughout progress of the Work.
- .2 The Contractor shall facilitate production of interference drawings where necessary for coordination of the Work. Provide such interference drawings to the Consultant for review.
- .3 Coordinate with Owner as required for any Owner supplied and installed items required by this Project. Provide miscellaneous blocking and mounting as required for intended items.

7.2 Project Supervision

- .1 The Contractor shall provide and maintain full-time supervision from their own staff on site. The supervisor shall be responsible for the overall day-to-day coordination on site between subtrades.
- .2 The supervisor shall coordinate the work of all subcontractors, and provide such assistance as is necessary.

7.3 Project Meetings

- .1 Schedule and administer regular project progress meetings throughout progress of work. Frequency of meetings as agreed by Owner Consultants and Contractor at start-up meeting. The minimum for progress meeting shall be bi-weekly.
- .2 Distribute written notice of each meeting to Owner & Consultants four days in advance of meeting date. Indicate full agenda of coming meeting.
- .3 The Contractor shall submit meeting notes within 24 hours of the meeting and from these records and other notes the official minutes can be prepared. Itemize significant proceedings and decisions. Identify 'action by' appropriate parties. Reproduce and distribute copies of minutes within three days after each meeting and transmit to meeting participants and affected parties not in attendance.
- .4 Standard Templates for Minutes of Meeting will be distributed for the Contractors use at the Pre-Construction Meeting.

- .5 Contractor to provide Project Contact List within 4 days following the Pre-Construction Meeting. Standard templates for the Contact List will be distributed for the Contractors use at the Pre-Construction Meeting.

7.4 Project Site Administration

- .1 Contractor to maintain at the Jobsite - 1 - 8.5" x 11" Binder containing the following:
 - .1 Contract Documents.
 - .2 Building Permit & all other required permits
 - .3 Building Permit Review Documents
 - .4 Addenda.
 - .5 Reviewed shop drawings.
 - .6 Change Orders and other Contract modifications.
 - .7 Field test and inspection reports.
 - .8 Approved schedules.
 - .9 MSDS Sheets and relevant Product Data.
 - .10 Contact List.
 - .11 Notice of Project.
 - .12 Rform correspondence.
 - .13 All additional items requested as per the Owners Pre-Construction List.

7.5 Construction Progress Schedule.

- .1 Prepare schedule in horizontal chart form, with weekly horizontal time scale identifying first/last work day of each week and separate line for each trade or operation of the Work. Schedule must utilize "critical path" method. Schedule to be MS Project format.
- .2 Project Schedules shall identify all long lead delivery items and shop drawing time requirements.
- .3 Identify projected major milestones in the course of the Work such as completion of foundation work, structure, closing in, major inspections by building officials, Substantial Performance, etc.
- .4 Submit one copy of preliminary Progress Schedule for review at the Project Pre-Construction Meeting. Amend and update schedule on a regular basis or as requested by the Consultant.
- .5 All project Schedules will be reviewed by the Consultant based on the time commitment identified in the RFQ documents.

7.6 Submittal Schedule

- .1 Provide schedule for submittal of all Shop Drawings, Product Data and Samples at the Project Pre-Construction Meeting.
- .2 Provide complete list of all manufactured products to be used in the course of the Work, including those amended by addenda.

7.7 Additional Documents

- .1 Consultant may issue additional documents in the form of drawings, specifications, schedules, or written instructions to assist proper execution of the Work. These documents shall take the form of either a Supplemental Instruction or Change Order.

7.8 Submittals

- .1 Submit to Consultant, all items specified for review, at least 10 days before reviewed submissions will be needed, and in orderly sequence so as to not cause delay in the Work. Do not proceed with work affected by the submittal until review is complete.
- .2 Review all submittals prior to submission to the Consultant. Submittals not stamped, signed, and dated will be returned without review.
- .3 Verify field measurements and affected adjacent work are coordinated. Contractor's responsibility for errors and omissions in submission, or deviations from requirements of Contract Documents, is not relieved by Consultant's review of submittals.
- .4 A 2 week standard timeframe is assumed for the preparation and submission of Sample, Shop Drawings, and Product Data. All Samples, Shop Drawings and Product Data which do not meet this criteria must be identified at the project Pre-Construction Meeting.

7.9 Submission Requirements

- .1 Submit digital copies of all submittals. Submittals by Email, or as copies of an email transmissions are not acceptable and will not be reviewed. Shop drawings and product data sheets not submitted in the scale type of the contract documents (ie. metric for metric drawings) will not be reviewed.
- .2 Accompany submissions with transmittal letter containing date, Project title and number, Contractor's name and address, drawing/page numbers of each shop drawing or data sheet, identification (ie. "structural steel shop dwgs."), and number of copies submitted.

7.10 Return of Submissions

- .1 If no errors are discovered or only minor corrections are made, one copy of the submission will be returned. If shop drawings or data sheets are rejected, noted copy will be returned and resubmission of corrected shop drawings or data sheets through the same procedure indicated above, shall be made.

7.11 Distribution of Submittals after Review

- .1 Distribute copies of shop drawings and product data which carry Consultant's stamp to all affected parties.

7.12 Shop Drawings

- .1 Indicate materials, methods of construction and attachment or anchorage, erection diagrams, connections, explanatory notes and other information necessary for completion of Work.
- .2 Adjustments made on shop drawings by the Consultant are not intended to change the Contract Price. If adjustments affect the value of Work, state such in writing to the Consultant prior to proceeding with the Work.
- .3 Reproductions of Consultants' drawings are not acceptable for the purpose of creating Shop Drawings.

7.13 Product Data Sheets

- .1 Manufacturer's standard schematics, catalogue sheets, diagrams, schedules, performance charts, illustrations and other descriptive data are acceptable in lieu of shop drawings, where specified.
- .2 Submit product data sheets or brochures requested in specification Sections, and as the Consultant may reasonably request where shop drawings will not be prepared due to standardized manufacture of product.
- .3 Submit copies of all WHMIS Data Sheets.

7.14 Samples

- .1 Submit duplicate samples for review, in sizes requested in respective specification sections. Label samples as to origin and intended use in the Work. Where colour, pattern or texture is criteria, submit full range of samples.
- .2 Deliver samples prepaid to Consultant's office.
- .3 Reviewed samples will become standards of work and material against which installed work will be checked on project.

8 CONTRACT ADMINISTRATION

- 8.1 The Contract Administration office functions performed by the Consultant will generally be done through the web based contract administration software "Rform" by Re Form Technologies Ltd. (www.rform.ca).
- 8.2 The Contractor will be required to participate with the balance of the project team by using Rform for the duration of the project. Rform is a free service to the Contractor and does not require the Contractor to pay any setup or usage fees.

- 8.3 The Contractor will be provided with instructions on the access and operation of Rform in the event they are not familiar with it's function or operation. The Contractor's staff involved in the project will be provided with access to Rform at no cost to the Contractor.
- 8.4 Suppliers and Subcontractors will not be provided with access to Rform. The distribution of information issued by the Consultant, and coordination of that information, remains the responsibility of the Contractor.
- 8.5 Rform will be used for issuing electronic project related documents, including Requests for Information, Supplemental Instructions, Proposed Change Orders, Change Orders, Change Directives, Progress Claims, Certificates of Payment, Submittal Reviews, and other forms as may be required. At the discretion of the Consultant, Rform may also be used for the distribution and filing of other project related documents, including but not limited to Field Review Reports, Test Reports, Meeting Minutes, and so on. Rform will also provides automatically generated logs of documents issued within Rform.
- 8.6 The Contractor will be required to print hard copies of all project related documents issued through Rform, and to maintain files of those documents on site at all times.
- 8.7 Notwithstanding that Rform does not require signatures for the issuance and approval of documents, adjustments to the Contract Price and Contract Time in a Change Order shall only be deemed to be agreed to by the Owner and Contractor when executed by hand, and that electronic acceptance does not satisfy the conditions of agreement under GC 6.2.2 of the CCDC2 2008 Stipulated Price Contract.

9 CONSTRUCTION PHOTOGRAPHS

- .1 General
- .1 Provide construction photographs in accordance with procedures and submission requirements specified in this section.
 - .2 Photographs shall be taken using a digital camera.
 - .3 Photo Print Size: minimum 100 x 150mm.
- .2 Progress Photographs
- .1 Provide construction photographs, documenting progress of the Work. Submit one digital set, with each monthly progress draw.
 - .2 Submit progress photographs with each monthly progress draw, documenting the following milestones;
 - .3 Completion of excavation and pouring of footings,
 - .4 Completion of foundations prior to backfilling,
 - .5 Completion of structural frame,
 - .6 Completion of rough-in of mechanical and electrical services before concealment.
 - .7 Completion of building veneers.
 - .8 Completion of each interior finish material.

- .9 Orientation of Photographs: provide photos from at least 2 general viewpoints, as well as specific views as required by milestones specified above, and as determined by Consultant prior to first Progress Draw.
 - .10 Identification: legible identification on 20 x 50mm white label on top left corner of all photographs indicating the following:
 - .1 Project name and number,
 - .2 Orientation,
 - .3 Date of exposure.
 - .3 Final Photographs
 - .1 In addition to progress photographs, provide 1 digital set of images, of final photographs of the completed project.
 - .2 Orientation of Photographs: provide final photos as follows:
 - .1 General viewpoints as defined above,
 - .2 Views of all exterior elevations,
 - .3 Views of site showing paved and landscaped surfaces,
 - .4 Interior views of all spaces,
 - .5 Specific views as determined by Consultant .
 - .3 Identification: legible identification on 20 x 50mm white label on top left corner of all photographs indicating the following:
 - .1 Project name and number,
 - .2 Orientation,
 - .3 Date of exposure.
- 10 **QUALITY CONTROL**
- 10.1 Independent Inspection and Testing
 - .1 Independent Inspection and Testing Consultants will be engaged by the Owner for the purpose of inspecting and/or testing individual portions of the Work. The initial cost of such services will be borne by the Owner, as allocated under Allowances.
 - 10.2 Access To Work
 - .1 Allow inspection & testing companies access to the Work, as well as off site manufacturing and fabrication plants.
 - 10.3 Reports
 - .1 Submit one digital copy of inspection and test reports to the Consultant.
 - .2 Provide copies to Subcontractor of work being inspected or tested, manufacturer or fabricator of material being inspected or tested. Submit one copy of inspection and test reports to the Building Official having jurisdiction, where required by that official.
 - .3 The cost of tests beyond those called for in the Contract Documents or beyond those required by the law of the Place of Work shall be appraised by the Consultant and may be authorized as recoverable.

-
- 10.4 Inspection and Testing - General
- .1 Furnish test results and mix designs as may be requested.
 - .2 The cost of tests and mix designs beyond those called for in the Contract Documents or beyond those required by the law of the Place of Work shall be appraised by the Consultant and may be authorized as recoverable.
- 10.5 Inspection and Testing - Procedures
- .1 Notify the appropriate agency and Consultant in advance of the requirement for tests, in order that attendance arrangements can be made.
 - .2 Submit samples and/or materials required for testing, as specifically requested in specifications. Submit with reasonable promptness and in an orderly sequence so as not to cause delay in the Work.
 - .3 Provide labour and facilities to obtain and handle samples and materials on site. Provide sufficient space to store, cure and inspect test samples.
- 10.6 Quality Of The Work
- .1 Quality of the Work shall be first class, executed by workers experienced and skilled in the respective duties for which they are employed. Immediately notify the Consultant if required work is such as to make it impractical to produce required results.
 - .2 Do not employ any unfit person or anyone unskilled in their required duties. The Consultant reserves the right to require the dismissal from the site, of workers deemed incompetent, careless, insubordinate or otherwise objectionable.
- 10.7 Defective Materials and Work
- .1 Where evidence exists that defective work has occurred, or that work has been carried out incorporating defective products, the Consultant may have independent tests, inspections, or surveys performed in order to determine if work is defective.
 - .2 Tests, inspections, or surveys carried out under these circumstances will be made at the Contractor's expense in the event of defective work, or at the Owner's expense where work is in conformance. This does not include re-testing of soil compaction during placement, where evidence exists of non-conformance with the Contract documents, but rather only if re-testing is called for after completion of compaction.
- 11 **TEMPORARY FACILITIES AND CONSTRUCTION CONTROLS**
- 11.1 Provide temporary utilities, facilities and controls in order to execute the work expeditiously. Remove from site all such work after use.

11.2 Vehicular Access & Parking

- .1 If authorized to use existing roads for access to project site, maintain such roads for duration of Contract and make good damage resulting from Contractor's use of roads. Maintenance shall include regular snow removal, and regular power washing to remove mud and dirt.
- .2 Where site access for construction vehicles necessitates use of public roads, remove mud and dirt from such roads where contaminated by construction vehicles.
- .3 Traffic Control: Provide and maintain flagpersons, traffic signals, barricades and flares, lights, or lanterns as required to perform the work and protect the public.
- .4 Provide and maintain adequate access to project site.
- .5 Build and maintain temporary access roads where indicated or required, and provide snow removal during period of work.
- .6 If authorized to use existing roads for access to project site, maintain such roads for duration of Contract and make good damage resulting from Contractor's use of roads. Maintenance shall include regular snow removal if not provided under separate contract, and regular power washing to remove mud and dirt.
- .7 Where site access for construction vehicles necessitates use of public roads, remove mud and dirt from such roads where contaminated by construction vehicles.
- .8 Traffic Control: Provide and maintain flag persons, traffic signals, barricades and flares, lights, or lanterns as required to perform the work and protect the public.

11.3 Construction Parking

- .1 Parking for construction equipment vehicles will be limited to the site or immediate areas of work.
- .2 Parking for Contractors' and Subcontractors' personal vehicles will not be permitted on site unless authorized by the Owner and Building Services Manager.

11.4 Temporary Utilities

- .1 Temporary Electricity and Lighting
 - .1 Connect to existing power supply in accordance with Canadian Electrical code.
 - .2 Install temporary facilities for power such as pole line and underground cables to approval of local power supply authority.
 - .3 Electrical power and lighting systems installed under this contract can be used for construction requirements provided that guarantees are not affected thereby. Make good damage. Replace lamps which have been used more than a period of 3 months.

-
- .4 Provide temporary lighting in all areas of construction, to the minimum requirements of the Occupational Health and Safety Act, and minimum requirements specified herein.
 - .2 Temporary Water Supply
 - .1 Water supply is available in existing building and will be provided for construction usage at no cost.
 - .2 Permanent water supply system installed under this contract can be used for construction requirements provided that guarantees are not affected thereby. Make good damage.
 - .3 Temporary Heating and Ventilating
 - .1 Provide and maintain all temporary heat and ventilation necessary during construction, including cost of installation, fuel, operation, attendance and maintenance. Use of direct-fired heaters discharging waste products into work areas will not be permitted unless prior approval is given by Consultant.
 - .2 Prevent hazardous accumulation of dust, fumes, mists, vapours or gases in areas occupied during construction.
 - .3 Provide local exhaust ventilation to prevent harmful accumulation of hazardous substances into atmosphere of occupied areas.
 - .4 Dispose of exhaust materials in manner that will not result in harmful exposure to persons.
 - .5 Ventilate storage spaces containing hazardous or volatile materials.
 - .6 Maintain strict supervision or operation of temporary heating and ventilating equipment.
 - .7 Conform to the requirements of CAN/CSA Z317.2-01 – Special Requirements for Heating Ventilating and Air Conditioning (HVAC) Systems in Health Care Facilities.
 - .4 The permanent HVAC systems of the building, or portions thereof, may not be used for construction purposes.
- 11.5 Construction Facilities
- .1 Temporary Telephone and Facsimile
 - .1 Provide and pay for temporary telephone. Cellular telephones are acceptable.
 - .2 Equipment, Tools and Materials Storage
 - .1 On site storage of materials and equipment is not permitted unless authorized by the Building Services Manager. Provide adequate weathertight enclosures with raised floors, for storage of materials, tools, and equipment which are subject to damage by weather.
 - .2 Temporary enclosures required by subtrades as workshops shall be provided by those trades.
 - .3 Confine the Work and the operations of employees to limits indicated by the Contract Documents. Where on-site storage is authorized, do not unreasonably encumber the premises with Products.

- .4 Do not load or permit to be loaded any part of the Work with a weight or force that will endanger the Work.
- .3 Site Storage and Overloading
 - .1 Confine the Work and the operations of employees to limits indicated by the Contract Documents. Do not unreasonably encumber the premises with products.
 - .2 Do not load or permit to be loaded any part of the Work with a weight or force that will endanger the Work.
- .4 Sanitary Facilities
 - .1 The Owner's existing facilities may not be used. Provide sanitary facilities for work force in accordance with governing regulations and ordinances. Post notices and take such precautions as required by local health authorities. Keep area and premises in sanitary condition. Where portable toilet facilities are provided, empty and sanitize such facilities on a weekly basis, or more frequently if required.
 - .2 Owner's existing facilities may not be used, unless designated by the Building Services Manager. Use only those facilities when so designated. Maintain designated facilities in a clean and sanitary condition while in use by construction workers.
 - .3 Permanent new facilities may not be used.
- 11.6 Construction Safety
 - .1 Observe all construction safety measures as required by the General Conditions of the Contract, the Occupational Health and Safety Act and Regulations for Construction Projects, and by all authorities having jurisdiction, provided that in case of conflict or discrepancy, the more stringent requirements shall apply.
 - .2 Provide applicable spare safety equipment such as helmets, safety glasses, and harnesses, and enforce their use by Consultants, the Owner, their representatives and any authorized visitors to the site.
 - .3 Provide and maintain fences, gates and locks, covered walkways, guard rails, barriers, night lights, and appropriate warning signage as required for the protection of the public, and of public and private property; as required by the General Conditions of the Contract, the Occupational Health and Safety Act and Regulations for Construction Projects, and by all authorities having jurisdiction. Erect and maintain sturdy railings around shafts, and the like, to protect workmen and the public from injury.
 - .4 Contractors are to provide relevant certifications for all workers and sub-contractors at the pre-construction meeting. Copies shall be kept onsite in the Project Binder.
- 11.7 Workplace Hazardous Materials Information System
 - .1 Comply with all requirements of Workplace Hazardous Materials Information System (WHMIS) regarding use, handling, storage, and disposal of hazardous materials; and regarding labelling and provision of material safety data sheets.

-
- .2 Include copies of all WHMIS data sheets in Operations and Maintenance Manuals.
- 11.8 Construction Aids
- .1 Falsework: Design and construct falsework in accordance with CSA S269.1.
- 11.9 Temporary Barriers & Enclosures
- .1 Dust Screens
 - .1 Provide dust tight screens or partitions to localize dust generating activities, and for the protection of workers, finished areas of Work and the public.
 - .2 Dust screens shall consist of, as a minimum, 0.15 mm thick polyethylene sheets secured to appropriate framing and sealed at all joints and at perimeter to prevent migration of dust.
 - .3 Maintain and relocate protection until such work is complete.
 - .2 Temporary Partitions
 - .1 Provide temporary partitions to separate the work areas from occupied resident areas.
 - .2 Temporary partitions shall consist of 92mm steel studs with 16mm Type X gypsum board both sides. Partitions shall be constructed as fire separations having a 1 hour fire resistance rating. Provide 89mm thick sound attenuation batt insulation.
 - .3 Provide lockable fire-rated hollow metal doors and frames for access to work areas by workers, and to prevent access by resident or unauthorized personnel.
 - .4 Provide temporary windows.
 - .3 Contractor to provide security until dust screens and temporary partitions are erected.
 - .4 Dust Screen and Temporary partitions must be erected to the satisfaction of the Building Services Manager and the Consultant. A Dust Control/Temporary Partition Layout Proposal, must be submitted for review by the Building Services Manager and Consultant prior to the start of the Work.
 - .5 Security
 - .1 Where security of an existing building has been reduced by the Work, provide temporary means to maintain security. Provide and pay for security service to patrol the site if building cannot be otherwise secured.
 - .2 Adhere to the Owner's policies for security and access to long term care centre.
 - .6 Building Access
 - .1 Access existing building only at points designated by the Owner.

- .2 When designated by the Owner, elevators assigned for Contractor's use may be used for moving workers and materials within building. Protect walls of elevators to approval of Consultant before use. Accept liability for damage, safety of equipment and overloading of existing equipment.
- .7 Site Signs and Notices
 - .1 Maintain approved signs and notices in good condition for duration of project, and dispose of off site on completion of project or earlier if directed by Consultant.
 - .2 No other signs or advertisements of any description except notices regarding safety and instruction, shall be put up around the building, or site, without the approval of the Consultant.
 - .3 Provide and install all temporary signage as required to direct interior and exterior traffic flows.
- 11.10 Permits
 - .1 Owner to provide building permit. Contractor shall maintain all permits and provide close-out at project completion.
 - .2 Contractor shall obtain and apply for all other permits (including scaffolding, hoist, trailer, temporary buildings etc.) licenses, deposits, and certificates of inspection as part of the Contract Price as per Conditions of the Contract. Ensure that permits, licences, deposits and certificates included under specific Sections are provided as specified.
- 12 **FIRE SAFETY**
- 12.1 Fire Fighting Equipment
 - .1 Provide and maintain in working order, ULC labelled, 9kg 4A 60BC type fire extinguishers, and locate in prominent positions to approval of authorities having jurisdiction.
- 12.2 Fire Department Access
 - .1 Construction activities must not obstruct access routes designated for fire department equipment. If necessary that existing access be obstructed or deleted, alternative access, acceptable to the fire department, must be provided prior to commencement of construction, in accordance with Ontario Building Code location and design criteria for required access routes.
- 12.3 Control of Combustible Materials
 - .1 The stockpiling of construction materials adjacent to the existing building must be carefully controlled in accordance with the Ontario Fire Code. Materials stored, and their proximity to equipment used in construction, may create a fire hazard. Control of combustibles on a construction site is regulated under the Occupational Health and Safety Act.

12.4 Hot Work And Red Tag Permit Training

- .1 All Contractors including Sub-Contractors who are involved in this Project shall submit written certificates prior to commencement of work confirming that all staff performing work has successfully completed “Managing Impairments Using FM Global’s Red Tag Permit System” and “Managing Hot Work Using FM Global’s Hot Work Permit System”.
- .2 In order to successfully complete the training, a grade of 80% is required. The contractor and sub-contractor’s staff must be re-certified every three years.
- .3 The free online training session can be accessed through <http://training.fmglobal.com>. Each session takes less than one hour to complete and can be accessed 24 hour a day, seven days a week from any computer connected to the Internet.
- .4 Contractor shall coordinate with the City’s Project Manager to obtain the login credentials. Authorization will be obtained by the Project Manager by sending an e-mail to onlinetraining@fmglobal.com with the name, company name and e-mail address of the person(s) requiring authorization. Please note that 24 hours is required to allow for confirmation of contractor authorization. Contractor is responsible for coordinating registration of the courses with the City’s Project Manager.

13 **PRODUCT REQUIREMENTS**

13.1 Product Options

- .1 Provide products specified under individual specification sections. Where Specification lists two or more products, or two or more manufacturers of the same product, the Contractor may select one of the listed products or manufacturers. Confirm selection of products and manufacturers when requested by the Consultant.
- .2 When only one product or manufacturer is listed in the specifications, it is intended that only that product or manufacturer is acceptable.

13.2 Product Substitution Procedures During Construction

- .1 The Contractor shall identify all proposed product substitutions using Appendix SA - Suggested Alternatives. All Suggested Alternatives must be included with the bid submission at the time of Tender. Suggested Alternatives submitted after Tender will not be accepted.
- .2 Products may only be substituted during the Construction period for one or more of the following reasons:
 - .1 Insolvency of the product manufacturer.
 - .2 Inability of the manufacturer to provide the product(s) in the timeframe required to maintain the construction schedule.

- .3 Product specified has been discontinued.
- .4 Substitution proposed offers better performance than that specified, at no additional cost.
- .5 Substitution offers equivalent performance to that specified, at a reduced cost to the Owner (reduction in Contract Price).

.3 Items 1.2, and 1.3 will require a letter from the manufacturer, confirming their inability to provide the products specified, or inability to meet the schedule.

.4 Items 1.4, and 1.5 will be at the discretion of the Owner.

13.3 Availability

.1 Immediately upon signing Contract, review Product delivery requirements, and identify lead times for supply of all Products. If lead times in supply of Products may affect the Construction Schedule, notify the Consultant in order that appropriate action may be authorized in ample time to prevent delay in performance of the Work.

.2 In the event of failure to notify the Consultant at commencement of Work, and should it appear that Work may be delayed for such reason, the Consultant reserves the right to substitute more readily available products of similar character, at no increase in Contract Price.

13.4 Reference Standards

.1 Within the specifications, reference standards are identified. Conform to these standards, in whole or part, as specifically requested.

.2 If there is question as to whether any product or system is in conformance with applicable standards, the Consultant reserves the right to have such products or systems tested to prove or disprove conformance. The cost for such testing will be born by the Contractor.

13.5 Product Transportation & Delivery

.1 Transportation and delivery costs of Products required in the performance of the Work, are included in the Contract Price.

.2 Products must be appropriately crated, skidded, boxed, shrink-wrapped, or otherwise packaged to protect such products from damage during shipment. Products which arrive at the site in a damaged condition must be rejected and returned to the supplier/manufacturer for immediate replacement.

13.6 Product Storage, Handling and Protection

.1 Handle and store Products in a manner to prevent damage, adulteration, deterioration and soiling and in accordance with manufacturer's instructions.

-
- .2 Store packaged or bundled Products in original and undamaged condition with manufacturer's seal and labels intact. Do not remove from packaging or bundling until required in the Work.
 - .3 Store products subject to damage from weather in weatherproof enclosures.
 - .4 Store sheet materials and lumber on flat, solid supports and keep clear of ground. Slope to shed moisture.
 - .5 Remove and replace damaged Products at own expense and to the satisfaction of the Consultant.
- 13.7 Manufacturer's Instructions
- .1 Unless otherwise indicated in the specifications, install or erect Products in accordance with manufacturer's printed instructions. Do not rely on labels or enclosures provided with Products. Obtain written instructions directly from manufacturers.
 - .2 Notify Consultant in writing, of conflicts between the specifications and manufacturer's instructions, so that Consultant may establish correct course of action.
 - .3 Improper installation or erection of Products, due to failure in complying with these requirements, authorizes the Consultant to require removal, replacement where necessary, and re-installation at no increase in Contract Price.
- 13.8 Fastenings
- .1 Provide metal fastenings and accessories in same texture, colour and finish as adjacent materials, unless indicated otherwise.
 - .2 Space anchors within limits of load limit or shear capacity and ensure that they provide positive permanent anchorage. Wood or any other organic material plugs are not acceptable.
 - .3 Keep exposed fastenings to a minimum, space evenly and install neatly.
 - .4 Fastenings which cause spalling or cracking of material to which anchorage is made are not acceptable.
- 13.9 Quality Of Materials
- .1 Products, materials, equipment and articles (referred to as Products throughout the specifications) incorporated in the Work shall be new, not damaged or defective, and of the best quality (compatible with specifications) for the purpose intended. If requested, furnish evidence as to type, source and quality of Products provided.

- .2 Defective products, whenever identified prior to the completion of Work, will be rejected, regardless of previous inspections. Inspection does not relieve responsibility, but is a precaution against oversight or error. Remove and replace defective Products at own expense and be responsible for delays and expenses caused by rejection.
- .3 Should any dispute arise as to the quality or fitness of Products, the Consultant may request additional testing based upon the requirements of the Contract Documents, to confirm acceptability of products or materials.
- .4 Unless otherwise indicated in the specifications, maintain uniformity of manufacture for any particular or like item throughout the building.
- .5 Permanent labels, trademarks and nameplates on Products are not acceptable in prominent locations, except where required for operating instructions, or when located in mechanical or electrical rooms.

13.10 Defective Materials and Work

- .1 Where evidence exists that defective work has occurred, or that work has been carried out incorporating defective products, the Consultant may have independent tests, inspections, or surveys performed in order to determine if work is defective.
- .2 Tests, inspections, or surveys carried out under these circumstances will be made at the Contractor's expense in the event of defective work, or at the Owner's expense where work is in conformance. Where tests incorporate a number of samples, payment will be assessed, by the Consultant, based on the ratio of conforming to non-conforming results. This does not include re-testing of soil compaction during placement, where evidence exists of non-conformance with the Contract documents, but rather only if re-testing is called for after completion of compaction.

13.11 Warranties & Guarantees

- .1 Warrant all products and labour forming part of the Work for two (2) years except where individual sections identify greater warranty requirements.
- .2 Warrant products and assemblies for the specified periods of time where in excess of the Contract Warranty, as specified within their respective sections.
- .3 Guarantee aspects of the Work for the specified periods of time where in excess of the Contract Warranty, as specified within their respective sections.
- .4 Warranties and Guarantees shall commence at Date of Substantial Performance of the Contract as certified by the Consultant.
- .5 Warranties and Guarantees shall be original copies, printed on company letterhead, or on a standard company warranty certificate, bearing the name of the company.
- .6 Warranties and Guarantees shall indicate:
 - .1 Name of the Principal (the Manufacturer/Subcontractor),

- .2 Name of the Obligee (the Owner),
- .3 Name and address of Project,
- .4 Commencement date (Date of Substantial Performance),
- .5 Duration of warranty or guarantee,
- .6 Clear statement of what is included, and what if any exclusions there are, and
- .7 Signature of Principal's representative having signing authority.

14 EXECUTION REQUIREMENTS

14.1 Examination

.1 Acceptance of Conditions

- .1 The General Contractor shall examine all existing or pre-determined conditions, prior to commencing work in that area, and report to the Consultant all conditions unacceptable for work to proceed. Commencement of work shall imply acceptance of conditions as is.
- .2 Subcontractors shall examine all existing or pre-determined conditions affecting their portion of the Work, prior to commencing such work, and report to the Contractor all conditions unacceptable for work to proceed. Commencement of work shall imply acceptance of conditions as is.

14.2 Preparation

.1 Field Engineering

- .1 Locate, confirm and protect control points prior to starting the Work. Preserve permanent reference points during construction.
- .2 Establish reference lines and elevations. Locate and lay out by instrumentation.

.2 Survey Requirements

- .1 A certified land survey prepared by a Registered Ontario Land Surveyor (OLSA member), acceptable to Owner, will be required under the following circumstances:
 - .1 Where the Work is an entirely new building,
 - .2 Where the Work is an addition to be constructed up to site setback line(s), as legislated by municipality, or
 - .3 Where the Work is a long term care centre or addition thereto.
- .2 Establish two new permanent bench marks on site, referenced to existing bench mark(s) by survey control points. Record locations, with horizontal and vertical data for inclusion in Operations and Maintenance Manual.

.3 Records

- .1 Maintain a complete, accurate log of control points and survey work as work progresses.
- .2 On completion of foundations and major site improvements, prepare certified survey showing dimensions, locations, angles and elevations of foundation work.

-
- 14.3 Cutting and Patching
- .1 Submit a written request in advance, for approval of cutting or alteration which affects:
 - .1 Structural integrity of any element of Project.
 - .2 Integrity of weather-exposed or moisture-resistant elements.
 - .3 Efficiency, maintenance, or safety of any operational element.
 - .4 Visual qualities of sight-exposed elements.
 - .5 Work of Owner or separate contractor.
 - .2 Inspect existing conditions, including elements subject to damage or movement during cutting and patching.
 - .3 After uncovering, inspect conditions affecting performance of work. Beginning of cutting or patching means acceptance of existing conditions.
 - .4 Perform cutting, fitting and patching, including excavation and fill, to complete the Work. Perform work to avoid damage to other work.
 - .5 Employ original installer to perform cutting and patching for weather-exposed and moisture-resistant elements, and sight-exposed surfaces.
 - .6 Cut rigid materials using power saw or core drill. Pneumatic or impact tools not allowed.
 - .7 Fit work airtight to pipes, sleeves, ducts, conduit, and other penetrations through surfaces. At penetration of fire-rated wall, ceiling, or floor construction, completely seal voids with fire stopping material, full thickness of construction element. Refer to 'Firestops and Smoke Seals Section' where provided. Maintain Fire Separation to code as required at no additional cost to the Owner.
 - .8 Refinish surfaces to match adjacent finishes; for continuous surfaces refinish to nearest intersection; for an assembly, refinish entire unit to the satisfaction of the Consultant at no additional cost to the Owner.
 - .9 Provide all openings greater than 200mm in non-structural elements of work for penetrations of mechanical and electrical work. Divisions 21, 22, 23 and 26 shall provide all sleeves and locations for sleeves. The cost of all cutting and patching required by Divisions 21, 22, 23 and 26 shall be paid for by those trades.
 - .10 Ensure that all cutting and patching work, including that paid for under Divisions 21, 22, 23 and 26, is properly performed by the respective trades skilled in that line of work. Restore work with new products in accordance with Contract Documents.
- 14.4 Location Of Equipment and Fixtures

-
- .1 Location of mechanical and electrical equipment, fixtures and devices indicated or specified, are to be considered as approximate. Final location of such items will be determined on site, based on integration with structural and architectural elements, and as required by coordination with other trades. In the event of a conflict, final determination of location of these items rests with the Consultant at no additional cost to the Owner.
 - .2 Prepare and submit for review by the Consultant, interference field drawings, to indicate relative position of various services and equipment, at the following locations as a minimum:
 - .1 Under all rooftop mechanical units.
 - .2 At locations of all major ductwork, piping, and conduit crossovers.
 - .3 Where ductwork passes under major structural elements.
 - .3 Locate equipment, fixtures and distribution systems to provide minimum interference and maximum usable space and in accordance with manufacturer's recommendations for safety, access and maintenance.
 - .4 Request a review of items by Consultant once rough-in is underway, prior to final installation, and obtain approval for actual locations.
- 14.5 Concealment
- .1 Conceal pipes, ducts and wiring in floor, wall and ceiling construction of finished areas, except where indicated otherwise.
- 14.6 Lighting Fixtures at Suspended Ceilings
- .1 Ensure that secure support is provided for lighting fixtures by suspended ceilings, or by separate hangers, or by both.
 - .2 Coordinate the ceiling system and lighting fixture installations to provide adequate support.
 - .3 Submit affidavits with acceptable design information confirming that the installation of the suspended ceiling system and/or separate fixture hangers will provide adequate support for the lighting fixtures without exceeding specified deflection tolerances for the ceiling system.
 - .4 Conform to current requirements of the Electrical Safety Authority (ESA).
- 14.7 Existing Services
- .1 Where work involves the interruption of, or connection to existing services, carry out such work as directed by governing authorities, with minimum of disturbance to pedestrian and vehicular traffic.
 - .2 All interruption of shut down of Building Systems must be fully coordinated with the Consultant and Building Services Manager.

- .3 Before commencing work, establish location and extent of service lines in area of work and notify Consultant of findings.
- .4 Submit schedule to, and obtain approval from Consultant for any shutdown or closure of active service or facility. Adhere to approved schedule and provide notice to affected parties.
- .5 Provide adequate bridging over trenches which cross sidewalks or roads to permit normal traffic.
- .6 Where unknown services are encountered, immediately advise Consultant and confirm findings in writing.
- .7 Remove abandoned service lines to distance of 1200mm from foundations. Cap or otherwise seal lines at cut-off points as directed by Consultant.
- .8 Record locations of maintained, re-routed and abandoned service lines.

14.8 Alterations, or Additions to Existing Building

- .1 Execute work with least possible interference or disturbance to occupants, public and normal use of premises. Arrange with Owner to facilitate execution of work.
- .2 Interruptions to building services shall require a minimum of 72 hours written notice to the Owner. Obtain Owner's approval before interrupting any building service.

14.9 Protection Of Work In Progress

- .1 Adequately protect Work completed or in progress. Work damaged or defaced due to failure in providing such protection is to be removed and replaced, or repaired, as directed by the Consultant, at no increase in Contract Price.
- .2 Prevent overloading of any part of the building. Do not cut, drill or sleeve any load bearing structural member, unless specifically indicated, without written approval of Consultant.
- .3 Protect finished surfaces with overlays of protective materials such as Kraft paper, cardboard, or plywood, as required for individual applications to provide adequate protection.

15 **CLEANING & WASTE MANAGEMENT**

- 15.1 Conduct cleaning and disposal operations to comply with local ordinances and environmental protection legislation.
- 15.2 Store volatile wastes in covered metal containers, and remove from premises at end of each working day.
- 15.3 Provide adequate ventilation during use of volatile or noxious substances. Use of building ventilation systems is not permitted for this purpose.

-
- 15.4 No Mixing of Materials in open areas used by Building Occupants.
- 15.5 Area for Mixing of Materials to be determined by the Consultant and Building Services manager
- 15.6 Failure to maintain site cleanliness to the satisfaction of the Building Services Manager and the Consultants will result in cleaning performed by the owner and charged to the Contractor. (for both general cleaning and final cleaning).
- 15.7 All cleaning materials used(for both general cleaning and final cleaning) to be reviewed and approved for use by the Consultant and Building Services Manager.
- 15.8 Cleaning During Construction
- .1 Maintain the Work in tidy condition, free from accumulation of waste products and debris, other than that caused by the Owner or other Contractors.
 - .2 Remove waste material and debris from the work areas and deposit in waste container at the end of each working day.
 - .3 Vacuum clean interior areas prior to start of finishing work. Maintain areas free of dust and other contaminants during finishing operations.
 - .4 Individual Subcontractors are responsible for the daily clean-up and removal of debris related to, or generated by, their own work. The overall responsibility for project cleanliness rests with the Contractor.
- 15.9 Waste Management
- .1 Audit, separate and dispose of construction waste generated by new construction or by demolition of existing structures in whole or in part, in accordance with Ontario Regulations 102/94 and 103/94 made under the Environmental Protection Act.
 - .2 Fires, and burning of rubbish or waste on site is prohibited.
 - .3 Burying of rubbish or waste materials, except as specified herein, is prohibited.
 - .4 Disposal of waste or volatile materials such as mineral spirits, oil, gasoline or paint thinner into ground, waterways, or sewer systems is prohibited.
 - .5 Empty waste containers on a regular basis to prevent contamination of site and adjacent properties by wind-blown dust or debris.
- 15.10 Final Cleaning Operations
- .1 Immediately following Date of Substantial Performance, and prior to Owner occupancy of the building or portion of the building affected by the Work, conduct full and complete final cleaning operations.

- .2 Final cleaning operations shall be performed by an experienced professional cleaning company, possessing equipment and personnel sufficient to perform full building cleaning operations.
- .3 Remove all surplus products, tools, construction machinery and equipment not required for the performance of remaining work, and thereafter remove any remaining materials, equipment, waste and debris.
- .4 Make arrangements with and obtain permits from authorities having jurisdiction for disposal of waste and debris.
- .5 Use only cleaning materials recommended by manufacturer of surface to be cleaned, and as recommended by cleaning material manufacturer.
- .6 Cleaning operations shall include the removal of all stains, spots, scuff marks, dirt, dust, remaining labels, adhesives or other surface imperfections.
- .7 Remove all paint spots or overspray from all affected surfaces.
- .8 Vacuum, clean and dust behind grilles, louvres and screens.
- .9 Broom clean and spray wash all exterior paved surfaces.
- .10 Remove dirt and other disfiguration from exterior surfaces.
- .11 Clean all areaways, drywells, and drainage systems.
- .12 Clean all equipment and fixtures to a sanitary condition, clean or replace filters of mechanical equipment.

16 **PROJECT CLOSE-OUT PROCEDURES**

16.1 Inspection and Declaration

- .1 Arrange for, conduct and document final inspections, close-out and commissioning at the completion of the Work in accordance with procedures described in the General Conditions of CCDC2-2008, and OAA/OGCA Document 100.

16.2 Substantial Performance

- .1 Contractor's Inspection
 - .1 Refer to OAA/OGCA Document 100 - STAGE 2.
 - .2 When the Contractor has carried out the steps in Stage 2 of OAA/OGCA Document 100, and has determined that the requirements of the Contract have been substantially performed as defined by local Lien legislation, the Contractor shall make application for Substantial Performance of the Work.

-
- .3 In addition to the requirements of OAA/OGCA Document 100, the following items shall accompany the Contractor's application for Substantial Performance. These items must be submitted and reviewed and complete in all respects, and all verification certificates and reports having been submitted and approved by the Consultants prior to issuing Substantial Completion:
 - .1 Completed Maintenance Manuals for all disciplines,
 - .2 As-Built Drawings for all disciplines,
 - .3 Occupancy Permit (where required by Municipality),
 - .4 Air Balance Report (legible technicians worksheets are acceptable),
 - .5 Gas fired appliances inspection,
 - .6 Plumbing Inspection,
 - .7 Domestic Water Quality Test Report,
 - .8 Sprinkler dry test verification letter stamped and signed by sprinkler design Engineer,
 - .9 Mechanical start-up reports (Boilers, HVAC Units, Chillers, Water Softeners, etc.),
 - .10 Fire Alarm verification (include legible technicians worksheets),
 - .11 Emergency Lighting verification,
 - .12 ESA Certificate,
 - .13 Systems operations have been demonstrated to Owner's personnel.
 - .4 The Contractor and all Subcontractors shall conduct an inspection of the work, identify deficiencies and defects, and make corrections as required to conform with the Contract Documents. Notify Consultant in writing of satisfactory completion of Contractor's Inspection and that corrections have been made. Request a Consultant's Inspection.
 - .2 Consultant's Inspection
 - .1 The Consultants shall perform an inspection of the Work to assess the validity of the Contractors application, and shall identify in separate lists, unfinished work and deficiencies. Contractor shall correct work accordingly.
 - .3 Substantial Performance of the Work
 - .1 Refer to OAA/OGCA Document 100 - STAGE 4.
 - .2 Should the Consultant concur with the Contractor's application for Substantial Performance, the Consultant shall notify the Contractor of approval of the application for Substantial Performance and issue a Certificate of Substantial Performance.
 - .3 The Contractor shall publish a copy of the Certificate of Substantial Performance in a construction trade newspaper, and shall provide the Consultant with proof of the date of publication.
 - .4 Lien Period And Release Of Basic Holdback
 - .1 Refer to OAA/OGCA Document 100 – STAGE 5.
 - .2 Commencement of Lien and Warranty Periods
 - .1 The day following the date of publication of Certificate of Substantial Performance shall be the date of commencement of the Warranty Period, and of the 45 day Lien Period prior to release of basic holdback, unless required otherwise by lien statute of the Place of the Work.

- .2 When the Contractor has carried out the required steps in Stages 3 and 4 of OAA/OGCA Document 100, the Contractor shall make application for Release of Basic Holdback.
- .3 The Consultant shall prepare the Certificate for Payment for release of basic holdback, and promptly upon receipt of the necessary documentation, issue the Certificate for Payment to the Owner.
- .5 Final Inspection and Payment
 - .1 Refer to OAA/OGCA Document 100 - STAGE 6.
 - .2 Submit a signed statement stating following have been performed:
 - .1 Work has been reviewed for compliance with Contract Documents,
 - .2 All deficiencies have been corrected and unfinished work have been completed,
 - .3 Work is complete and ready for Final Inspection.
 - .3 When items noted above are completed, a final inspection of the Work will be performed by the Owner, the Consultants, and the Contractor.
 - .4 If the Work is deemed to be incomplete, complete outstanding items and request a reinspection.
 - .5 If the Work is deemed to be complete, the Consultant will issue a Final Certificate for Payment.
- .6 Deficiency Review
 - .1 Following the issuance of the Certificate of Substantial Performance and prior to the Contractor's application for Final Payment and release of any monies retained as "Finishing Holdback", the Contractor shall continue to complete unfinished work and correct deficiencies. At the request of the Contractor, the Consultants shall conduct up to two general deficiency reviews during this period.
 - .2 The first review will be undertaken only if the Contractor has inspected the Work, and states in writing that the unfinished work noted in their application for Substantial Performance has been completed, and at least 50% of all deficiencies have been corrected.
 - .3 The second review will be undertaken only if the Contractor has inspected the Work, and states in writing that at least 90% of the deficiencies have been corrected.
 - .4 If the Consultants determine during either review that the above noted criteria for progress have not been met, they may terminate the deficiency review.
- .7 Reinspection
 - .1 Should reinspection by Consultant be required due to failure of work to comply with Contract Documents, the Owner will deduct amount of Consultant's compensation for reinspection services from monies owed to the Contractor.

17 **CLOSE-OUT SUBMITTALS**

17.1 Quality

- .1 Spare parts, maintenance materials and special tools provided shall be new, not damaged or defective, and of the same quality and manufacture as products provided in the Work.
- .2 If requested, furnish evidence as to type, source and quality of Products provided.
- .3 Defective products will be rejected, regardless of previous inspections. Replace products at own expense.

17.2 Delivery, Storage, and Handling

- .1 Deliver all materials required as maintenance materials, spare parts or special tools, to the site, include shipping costs, and store as directed.
- .2 Store spare parts, maintenance materials and special tools in a manner to prevent damage, or deterioration.
- .3 Store in original and undamaged containers with manufacturer's seals or labels intact.
- .4 Store materials subject to damage from severe climatic changes in a climate-controlled, weatherproof enclosure.
- .5 Store paints and freezable materials in a moderately heated and ventilated room.

17.3 Maintenance Materials, Spare Parts & Tools

- .1 Provide spare parts in quantities specified in individual specification sections. Provide identical items to those installed in the Work.
- .2 Provide maintenance materials in quantities specified in individual specification sections. Provide identical items of same manufacturer, dye lot or production run as items in the Work.
- .3 Provide special tools in quantities specified in individual specification sections, and tag items identifying their function and equipment or products to which they are associated.
- .4 Receive and catalogue all items. Check inventory and include approved listings in Operations and Maintenance Manual.
- .5 Obtain receipts for delivered products and submit prior to Substantial Performance.

17.4 Operations and Maintenance Manual

- .1 Prepare Operations and Maintenance Manual during the course of construction and have completed prior to Date of Substantial Performance.

- .2 Maintain digital copy of the Operation and Maintenance Manual volume(s) for periodic review and comment, as requested by the Consultant during the course of construction.
- .3 Submit digital copies of the final completed volume(s) and one digital copy as either a PDF or Microsoft Word document with the application for Substantial Performance in accordance with OAA/OGCA Document 100.
- .4 Provide table of contents and index tab sheets for each volume. Itemize and tabulate contents.
- .5 Group drawings as to content, and index for quick reference.
- .6 Each copy of the Operation and Maintenance Manual shall contain, as a minimum, the following information:
 - .1 Project contact list including after hours/emergency contact numbers
 - .2 All contract documents including tender calls, addendums, contract and change orders
 - .3 Contact information, including after-hours/emergency contact numbers, for maintenance and repairs
 - .4 Warranty and guarantee certificates
 - .5 Equipment start-up and troubleshooting instructions
 - .6 Equipment schematics & diagrams
 - .7 Catalogue of all maintenance materials and quantities
 - .8 Maintenance data
 - .9 Approved and stamped all shop drawings
 - .10 Before and after photographs organized such that the before and after photographs of any one are positioned adjacent to each other for easy reference.

17.5 As-Built Drawings

- .1 Record information on a clean set of black line opaque drawings, provided by Owner.
- .2 Maintain as-built drawings on site and update as construction progresses. Allow periodic review by Consultant as requested.
- .3 Record information concurrently with construction progress. Do not conceal work until required information is recorded.
- .4 Contract drawings and shop drawings: legibly mark each item to record actual construction, including:
 - .1 Measured depths of elements of foundation in relation to finish first floor datum.
 - .2 Measured horizontal and vertical locations of underground utilities and appurtenances, referenced to permanent surface improvements.
 - .3 Measured locations of internal utilities and appurtenances, referenced to visible and accessible features of construction.

- .4 Field changes of dimension and detail.
- .5 Changes made by change orders.
- .6 Details not on original Contract Drawings.
- .7 References to related shop drawings and modifications.

17.6 Record Drawings

- .1 Upon attaining Substantial Performance completion of the Work, obtain base CAD drawings, from the Consultant. The electronic files will be in AutoCad Version 2004. Update the AutoCad drawings to include as-built conditions.
- .2 Submit electronic files to the Consultant for review. Any subsequent changes found by the Consultant shall remain the responsibility of the Contractor at no charge to the Owner.'

END OF SECTION

APPENDIX SA – SUGGESTED ALTERNATIVES

Bidder: _____

The following Suggested Alternatives are **NOT INCLUDED** in the Bid price.

Individual Suggested Alternatives may be discarded or incorporated into the Final Contract Price at the discretion of the Owner.

Provide the appropriate data for comparison showing conformance to specified standards, dimensions, fabrication, colour, quality assurance, warranty, execution etc. as necessary for the Consultant to confirm the Suggested Alternative meets or exceeds the specifications. At the time of this submittal, provide the Consultant with the relevant Architectural details which prove conformance with the design intent and co-ordination with and installation by affected trades.

Suggested Alternative Prices **DO NOT INCLUDE** H.S.T.

Suggested Alternatives identified on this form are for Divisions 1 to Division 26 inclusive.

We submit a proposal to substitute for:

specified in Section _____ of the Specifications, the following alternative:

The Suggested Alternative is submitted for the following reason:

We ensure that a comparison has been made of all specified characteristics, that the Suggested Alternative does not alter the intent of the Drawings and Specifications and we hereunder tabulate significant variations which lessen the performance characteristics and quality of materials, increase the weights and / or dimensions, and substitute different materials for those specified.

The effect on the stipulated price is (choose one):

ADDITION (\$ _____) DEDUCTION (\$ _____)

(Submit a separate sheet for each item)

1 General

1.1 **SECTION INCLUDES**

- .1 Labour, Products, equipment and services necessary for demolition and removals Work in accordance with the Contract Documents.
- .2 Work included: Requirements for demolishing, salvaging and removing wholly or in part the various items designated on the drawings or required to be removed or partially removed for the receipt of the Work of this Contract, including not necessarily limited to:
 - .1 Alteration and renovations to existing building.
 - .2 Demolish existing flooring and base to existing substrate as indicated on drawings. Repair any cracks and/or skim coats for new level floor finish. Removal of existing floor along weld seem where possible.
 - .3 Clean existing wall finish, ready to receive new wall protection or new paint.
 - .4 Removal of all existing mirror, sink, grab bar and water-closet as shown on Drawings.
 - .5 Temporarily remove existing nurse call pull, light switch, and other wall mounted devices; store and protect for reinstallation.
 - .6 Removal of existing wall mounted millwork.
 - .7 Removal of existing shower head, faucet and controller.
 - .8 Removal of existing door and frame. Partially demolish existing stud wall, provide wall opening for new door.
 - .9 Remove existing millwork and kitchen equipment in servery and dish washing room. Refer to Kaizen's Drawings for details.
 - .10 Cutting and removing of walls, floors, ceilings, doors and frames , in the existing buildings as indicated on Drawings.
 - .11 Patching, making good openings and chases in walls, floors, ceilings, including the supply and installation of lintels, channels and finishes.
 - .12 Removal of rubbish, debris, demolished fixtures, fitments and items not scheduled to remain the Owner's property, resulting from the demolition and preparatory work.
 - .13 Remove abandoned services such as conduits, pipes, wiring, ducts, fixtures, equipment, etc. where required for the work or indicated on the drawings.
 - .14 Removal of asphalt pavements, concrete curbs and walks, and other site amenities as indicated on drawings.
 - .15 Removal of all mechanical items including plumbing fixtures, services etc. where required for the work or indicated on drawings and or where not required to be relocated.
 - .16 Removal of existing electrical items including fixtures, etc. where required for the work or indicated on the drawings and not required to be relocated.
 - .17 Dust control during the operations of the work of this Section.
 - .18 Removal shall mean removal from site and safe disposal in a legal manner.

1.2 **REFERENCES**

- .1 CSA S350-M, Code of Practice for Safety in Demolition of Structures.

1.3 **SUBMITTALS**

- .1 Where required by Authorities having jurisdiction, submit a Fire Plan to local fire department for review and approval.
- .2 Submit shop drawings, diagrams and details in accordance with Section 01 00 00.
- .3 30 calendar days prior to start of demolition and removals work, submit for review, drawings, diagrams or details showing sequence of disassembly work and shoring of supporting structures in accordance with authorities having jurisdiction.
- .4 Submit for approval, a plan showing impacts, interruptions and delays to Owners operations.
- .5 Have submissions signed and sealed by Professional Engineer licensed in Province of Ontario.
- .6 Submit to Consultant, details of where rubble, debris and other materials are to be disposed or reused. Include each disposal/reuse site location, operator's name and business address, type of license under which site operates, and criteria used by site to assess suitability of rubble, debris and other materials for disposal.
- .7 Give notice to Utility Authorities controlling services and appurtenances which will be affected by demolition work.

1.4 **QUALITY ASSURANCE**

- .1 Prepare waste audits, waste reduction workplans, source separation programs and recycling programs as required by jurisdictional authorities and update programs and implement such programs as required.
- .2 Perform the work of this section in accordance with the 'Environmental Protection Act' including Ontario Regulation 102 and the 'Environmental Assessment Act' including Ontario Regulation 103.
- .3 Conform to Fire Code, Regulation under the Fire Marshals Act.
- .4 The demolition contractor must engage a registered professional engineer who holds a certificate of authorization and an appropriate level of liability insurance to prepare demolition procedures.
- .5 As part of the contract requirements, the engineer for the demolition contractor should be required to sign the general review commitment required by city building departments.

1.5 **SITE CONDITIONS**

- .1 Interruptions to Owners operations will not be permitted.

- .2 Perform operations, machine and equipment movements, deliveries and removals at time or times that will permit uninterrupted operations in and around structures, including parking, deliveries, and Site access and egress.
- .3 Take over structures to be demolished based on condition on date that Tenders close.

2 Products

2.1 **MATERIALS**

- .1 All materials requiring removal shall become the Contractor's property and shall be removed and disposed of from the site, as the work progresses, unless indicated otherwise.
- .2 Salvaged material:
 - .1 Salvage and stockpile Products, materials, and equipment as specified herein, indicated on Site or indicated on drawings.
 - .2 Coordinate items to be salvaged with Consultant. Existing furniture/equipment in all work areas to be stored as per Owner's discretion.
 - .3 Salvaged materials shall not be chipped, cracked, split, stained or damaged.
 - .4 Store items off of moist surfaces.

3 Execution

3.1 **GENERAL**

- .1 Clean up rubble and debris, resulting from work promptly and dispose at end of day or place in waste disposal bins. Empty bins on regular basis.
- .2 Stockpiling of rubble, debris, and surplus Products on Site will not be permitted.
- .3 Remove, handle and transport Products indicated to be salvaged and stored for future use. Transport Products to storage area(s) designated by Consultant. Perform work to prevent any damage to Products during removal and in storage. Products damaged during removal, will be inspected by Consultant. Consultant will determine extent of damage and accept or refuse Products.
- .4 List and description of items to be removed and stored or reused:
 - .1 Washroom Accessories (Refer to Drawings for all removed , stored and reused washroom accessories).
 - .2 Existing furniture/equipment in all work areas to be stored as per Owner's discretion.
 - .3 Additional items as indicated on the drawings or by the Consultant or Owner.

- .5 Tag and log all items to be salvaged to the satisfaction of the Consultant. Ensure identification tags do not damage items to be salvaged and are non-permanent, removable and durable.
- .6 Take precautions to guard against movement, settlement or collapse of adjacent services, sidewalks and driveways. Be liable for such movement, settlement or collapse caused by failure to take necessary precautions. Repair promptly such damage when ordered.

3.2 EXAMINATION

- .1 Verify condition and dimensions of previously installed Work upon which this Section depends. Report defects to Consultant. Commencement of work of this Section means acceptance of existing conditions.

3.3 PRESERVATION OF REFERENCES

- .1 Record location and designation of survey markers and monuments located within demolition area, prior to removal. Store and restore markers and monuments upon completion of Work or relocate as directed by Consultant.

3.4 PROTECTION

- .1 Prevent movement or damage of adjacent structures, services, walks, paving, landscaping and parts of existing structure to remain. Supply and install bracing, and shoring as required. Make good damage caused by demolition to acceptance of Consultant.
- .2 Protect adjacent structures and property against damage which might occur from falling debris or other causes. Repair or replace damage caused from work of this Section to acceptance of Consultant.
- .3 Do not interfere with use of adjacent structures and Work areas. Maintain free, safe passage to and from adjacent structures and Work areas.
- .4 Take precautions to support affected structures. If safety of structure being demolished, adjacent structures or services are endangered, cease demolition operations and take necessary action to support endangered item. Immediately inform Consultant. Do not resume demolition until reasons for endangering have been determined and corrected and action taken to prevent further endangering.
- .5 If movement or settlement occurs, install additional bracing and shoring as necessary and make good damage to acceptance of Consultant.
- .6 Hang tarpaulins where debris and other materials are lowered. Build in around openings with wood and plywood at locations used for removal of debris and materials.

- .7 Prevent debris from blocking surface drainage system, mechanical, and electrical systems which are required to remain in operation.
- .8 Pay particular attention to prevention of fire and elimination of fire hazards which would endanger Work or adjacent structures and premises.
- .9 Supply and install adequate protection for materials to be re-used, set on ground and prevent moisture pick-up. Cover stockpiles of materials with tarpaulins.
- .10 Close off access to areas where demolition is proceeding by barricades and post warning signs.
- .11 Supply, install and maintain legal and necessary barricades, guards, railings, lights, warning signs, security personnel and other safety measures, and fully protect persons and property.
- .12 Dust/weather partitions:
 - .1 Prior to demolition work proceeding in existing structures, temporarily enclose Work areas, access and supply and install dustproof and weatherproof partitions. Design partitions to prevent dust and dirt infiltration into adjoining areas, prevent ingress of water, and to resist loads due to wind.
 - .2 Prevent dust, dirt and water from demolition operations entering operational areas.
 - .3 Adjust and relocate partitions as required for various operations of work.
 - .4 Upon completion of work, remove and dispose of partitions from Site.
- .13 Dust protection:
 - .1 Clean water to be applied to hard and soft surfaces and on open excavation faces on Site daily to eliminate dust.
 - .2 Roadways and sidewalks to be cleaned daily or as required.
 - .3 A designated truck loading area on granular material or existing asphalt to be used to mitigate tracking of demolition debris off Site.
 - .4 Loaded vehicles leaving Site to be cleaned of loose soil and debris with power washing or alternative method.
 - .5 Trucks loaded with indigenous soil or demolition debris to be covered by tarps or attached screens.
- .14 Blasting is not permitted.

3.5 **PREPARATION**

- .1 Disconnect and/or re-route electrical data, communication and telephone service lines entering structures to be demolished. Post warning signs on electrical lines and equipment which is required to remain energized.

- .2 Disconnect and cap designated mechanical services:
 - .1 Natural gas supply lines: As indicated on drawings and as required for alteration work, to be removed by qualified workers in accordance with gas company instructions.
 - .2 Sewer and water lines: Remove and dispose of as indicated on Contract Drawings and as required for alteration work.
- .3 Disassemble and remove mechanical equipment, ductwork and piping complete with supports and associated components.
- .4 Do not disrupt active or energized utilities designated to remain undisturbed.
- .5 Perform rodent and vermin control to comply with health regulations.

3.6 **DEMOLITION**

- .1 Perform demolition with extreme care. Confine effects of demolition to those parts which are to be demolished.
- .2 Perform work and prevent inconvenience to persons outside those parts which are to be demolished.
- .3 Carry out demolition in accordance with the requirements of CSA S350-M.
- .4 Demolish parts of structure to permit remedial work as indicated.
- .5 Demolition shall proceed safely in systematic manner from roof to grade and as necessary to accommodate remedial work indicated. Work on each floor level shall be complete before commencing work on supporting structure and safety of its supports are impaired. Parts of building which would otherwise collapse prematurely shall be securely shored. Walls and piers shall not be undermined.
- .6 Do not overload floor or wall with accumulations of material or debris or by other loads.
- .7 Perform work to minimize dusting. Keep work area wetted down with fog sprays to prevent dust and dirt rising. Supply and install temporary water lines and connections that may be required. Upon completion, remove installed temporary water lines. Use covered chutes, water down.
- .8 Do not sell or burn materials on Site.
- .9 Remove existing equipment, services, and obstacles where required for refinishing or making good of existing surfaces, and replace as Work progresses.
- .10 At end of day's work, leave Work in safe condition with no part in danger of toppling or falling. Protect interiors of parts not to be demolished from exterior elements.

- .11 Drainage and sewer system protection:
 - .1 Ensure that no dust, debris or slurry enters drainage and sewer system on Site.
 - .2 Remove and dispose of debris and slurry promptly from Site.
 - .3 Comply with City of Milton Sewer Use By-Law.

- .12 Concrete:
 - .1 Demolish concrete by methods which avoid impact loads on items which are not to be demolished.
 - .2 Where only part or parts of a concrete floor, wall, or other items are to be demolished, use saw cuts to isolate areas which are to be demolished except where existing reinforcing steel is to be left in place. Prior to such isolating, install suitable support to prevent premature movement of area(s) being isolated and undesirable transfer of loads as cutting progresses. If necessary remove area(s) to be demolished by successively isolating small sections.
 - .3 Where reinforcing steel is to be left in place, use saw cuts from surface of concrete around perimeter(s) of area(s) to be demolished, chip concrete without damaging reinforcing steel. Retouch damaged epoxy coating of existing reinforcing steel.

- .13 Masonry:
 - .1 Demolish block or brick walls in small sections of not more than 2 m². Do not permit masonry to fall in mass from one level to another.
 - .2 Where only part(s) of a wall is to be demolished, install adequate support for adjacent part(s).
 - .3 After removal of masonry walls, grind smooth floors ready for new floor finish.

- .14 Steel: Where only part or parts of structure is to be demolished, dismantle and maintain structure stable. Do not place excessive loads on components. Install adequate temporary guys and supports to ensure stability and to prevent excessive loading. Support each component being disconnected from structure, and lower, do not drop, component after it is disconnected.

- .15 Cut openings through existing walls, partitions, and floors. Establish exact location of steel reinforcing in existing concrete slabs or walls before cutting. Be responsible for damage to existing steel reinforcing and be liable for structural failure. Make good surfaces disturbed with materials to match existing.
 - .1 Where only part or parts of wall panel and assembly is to be demolished, dismantle, to prevent damage to adjacent wall panels.
 - .2 Form openings in panels such that edges are left straight, clean and not ragged.
 - .3. Remove existing wall panels where indicated to be replaced only as new windows under Section 08 44 00 are ready for installation.

16. Where doors are scheduled to be removed, include:
 1. Removal in re-usable condition of doors and door hardware, and store at the Place of the work.
 2. Removal of door frames.
17. Where doors are scheduled to be removed, include removal of door frames and door hardware.
18. Remove interior partitions, fittings, fixtures and accessories as indicated on drawings. Partitions and walls shall be removed full height to structure above.
19. Remove interior finishes, such as ceiling and floor finishes, where new finishes are indicated on Contract Drawings.
 1. Removal of existing ceilings shall include complete removal including bulkheads and suspension system.
 2. Removal of adhesive applied finishes shall include complete removal to substrate including adhesive. Take adequate care to prevent damage to substrate.
 3. Remove existing floor finishes, include mortar bed, underlayment or other cleavage membranes, underpad, base, floor moulding and transition strips.
20. Demolish all other items indicated or required.

3.7 **RECYCLING**

- .1 Whenever possible, all materials shall be recycled. Pay all costs for this work.
- .2 Deliver to nearest appropriate recycling depot all materials accepted for recycling by Authorities having jurisdiction over the Place of Work, including but not limited to cardboard, paper, plastic, aluminum, steel, and glass.
- .3 Deliver to nearest appropriate depot all scrap and excess gypsum wallboard for recycling of this material.

3.8 **DISPOSAL OF MATERIALS**

- .1 Remove from Site, rubble, debris, and other materials that can not be recycled resulting from demolition and removals work in accordance with Authorities having Jurisdiction, except where specified or indicated on Contract Drawings to be reused.
- .2 Conform to requirements of municipality's Works Department regarding disposal of waste materials.
- .3 Materials prohibited from municipality waste management facilities shall be removed from Site and dispose of at recycling companies specializing in recyclable materials.

3.9 **RESTORATION**

- .1 Where demolition removed a structure or installation, restore area in accordance with Authorities having Jurisdiction.

END OF SECTION

- 1 General
- 1.1 **SECTION INCLUDES**
 - .1 Labour, Products, equipment and services necessary for topping work in accordance with the Contract Documents.
- 1.2 **REFERENCES**
 - .1 ASTM C109M, Standard Test Method for Compressive Strength of Hydraulic Cement Mortars (Using 2-in. or 50-mm Cube Specimens).
- 1.3 **SUBMITTALS**
 - .1 Product data:
 - .1 Submit duplicate copies of manufacturer's Product data in accordance with Section 01 00 00 indicating:
 - .1 Performance criteria, compliance with appropriate reference standard(s), characteristics, and limitations.
 - .2 Product transportation, storage, handling and installation requirements.
 - .2 Shop drawings:
 - .1 Submit shop drawings in accordance with Section 01 00 00 indicating:
 - .1 Sections, details, materials, dimensions, thicknesses of each layer, maximum and minimum thicknesses, 3, 7, and 28 day load characteristics, and surface finishes
 - .3 Certificates: Submit certification from manufacturer, stating that materials proposed for use are compatible with specified floor finishes.
- 1.4 **QUALITY ASSURANCE**
 - .1 Installers qualifications: Perform work of this Section by a company that has a minimum of five years proven experience in installations of a similar size and nature and that is approved by manufacturer. Submit to Consultant, applicator's current certificate of approval by the material manufacturer as proof of compliance.
 - .2 Mock-up:
 - .1 Construct one room mock-up of topping in location acceptable to Consultant.
 - .2 Arrange for Consultant's review and acceptance, allow 48 hours after acceptance before proceeding with work.
 - .3 Mock-up may remain as part of Work if accepted by Consultant. Remove and dispose of mock-ups which do not form part of Work.
 - .4 Upon acceptance, mock-up shall serve as a minimum standard of quality for the balance of the work of this Section.

1.5 **SITE CONDITIONS**

- .1 Do not install work of this Section outside of following environmental ranges without Consultant's and Product manufacturer's written acceptance:
 - .1 Concrete temperature: 10°C minimum.
 - .2 Ambient air temperature: 16°C to 30°C
 - .3 Precipitation: None.
 - .4 Relative Humidity: None
- .2 Supply and install temporary protection and facilities to maintain Product manufacturer's, and above specified environmental requirements for 48 hours before, during, and 48 hours after installation.

2 Products

2.1 **MATERIALS**

- .1 Concrete based self-levelling compound:
 - .1 Compressive strength to ASTM C109, 28 day 4100 psi.
 - .2 Flexural strength to ASTM C109: 28 day 1000 psi.
 - .3 Primer: Type as recommended by topping manufacturer to suit intended condition.
 - .4 Acceptable material: 'Ardex K-15' by Ardex Engineered Cements or approved alternative.
- .2 Water: potable.

2.2 **MIXES**

- .1 Mix toppings in accordance with manufacturer's written instructions.

3 Execution

3.1 **EXAMINATION**

- .1 Verify condition and dimensions of previously installed Work upon which this Section depends. Report defects to Consultant. Commencement of work of this Section means acceptance of existing conditions.

3.2 **PREPARATION**

- .1 Verify substrate surfaces are solid, free from surface water, frozen matter, dust, oil, grease, scaling or laitance, projections and any other foreign matter detrimental to performance. Obtain manufacturer's approval of substrate in writing, submit copy to Consultant.
- .2 Prohibit traffic on prepared areas until work of this Section is completed.

- .3 Supply and install temporary protection to adjacent surfaces, floor drains, and steel angles to prevent damage resulting from work of this Section.
- .4 Prior to application of topping, remove all debris by vacuuming.

3.3 INSTALLATION

- .1 Install topping in accordance with reviewed shop drawings and manufacturer's written instructions.
- .2 Self-levelling topping:
 - .1 Install self-levelling material in accordance with manufacturer's written instructions.
 - .2 Let cure in accordance with manufacturer's written instructions.

3.4 PROTECTION

- .1 Provide temporary protection for surfaces subjected to concentrated loads before they have cured sufficiently to carry them without damage.
- .2 Prevent traffic over completed areas, and protect work of this Section from precipitation, freezing, and debris after final installation.

END OF SECTION

1 General

1.1 **SECTION INCLUDES**

.1 Design, labour, Products, equipment and services necessary for the miscellaneous and metal fabrication work in accordance with the Contract Documents.

1.2 **REFERENCES**

- .1 ASTM A123, Specification for Zinc (Hot Dip Galvanized) Coatings on Iron & Steel Products.
- .2 ASTM A153, Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware.
- .3 ASTM A307, Specification for Carbon Steel Bolts and Studs, 60,000 psi Tensile Strength.
- .4 ASTM A653/A653M, Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvanealed) by the Hot-Dip Process.
- .5 CISC/CPMA 1.73.a, A Quick-Drying One-Coat Paint for Use on Structural Steel.
- .6 CAN/CSA-G40.20/G40.21-M, General Requirements for Rolled or Welded Structural Quality Steel/ Structural Quality Steels.
- .7 CAN/CSA S16.1-M, Limit States Design of Steel Structures.
- .8 CSA S136.1-M, Commentary on CAN/CSA S136-M, Cold Formed Steel Structural Members.
- .9 CSA W47.1, Certification of Companies for Fusion Welding of Steel Structures.
- .10 CSA W48, Filler Metal and Allied Materials for Metal Arc Welding.
- .11 CSA W59-M, Welded Steel Construction (Metal Arc Welding).
- .12 CAN/CSA W117.2-M, Safety in Welding, Cutting and Allied Processes.
- .13 CAN/CGSB 1.40-M, Primer, Structural Steel, Oil Alkyd Type.
- .14 CGSB 85-GP-16M, Painting Galvanized Steel.
- .15 NAAMM, The National Association of Architectural Metal Manufacturers.
- .16 Steel Structures Painting Council (SSPC), Steel Structures Painting Manual, Vol. 2.

1.3 **DESIGN REQUIREMENTS**

- .1 Design details and connections, where not shown on Drawings, in accordance with CAN/CSA-S16.1 and CSA S136.1.

1.4 **SUBMITTALS**

- .1 Shop drawings:
 - .1 Submit shop drawings for fabrication and erection of miscellaneous and metal items in accordance with Section 01 00 00 indicating:
 - .1 Materials, core thicknesses, class of finish (AMP 555), connections, joints, method of anchorage, number of anchors, supports, reinforcement, details, and accessories.
 - .2 Ensure shop drawings are of one uniform size and based on field measurements.

1.5 **QUALITY ASSURANCE**

- .1 Retain a Professional Engineer, licensed in the Province of Ontario, with experience in work of comparable complexity and scope, to perform the following services as part of the work of this Section:
 - .1 Design steel stairs, handrails and railings, glazed guard, wire rope balustrade system, and metal fabrication items that are required to resist live, dead, lateral, wind, or seismic loads.
 - .2 Review, stamp, date and sign shop drawings.
- .2 Workmanship: Fabricate work of this Section to meet the required class of workmanship indicated below in accordance with NAAMM's AMP 555, Section 8.
 - .1 Class 1: for use on direct exposed to view fabricated items:
 - .1 Exposed surfaces are finished smooth without pits, mill marks, nicks, burrs, sharp edges, and scratches filled or ground off. Defects should not show when painted, polished, or finished.
 - .2 Welds should be concealed where possible. Exposed welds are ground to small radius with uniform sized cove unless otherwise noted.
 - .3 Distortions should not be visible to the eye.
 - .4 Exposed joints are fitted to a hairline finish.
- .3 Execute welding by firms certified in accordance with CSA W47.1 Division 1 or 2.1. Ensure welding operators are licensed per CSA W47.1 for types of welding required by Work.
- .4 Perform stainless steel work in accordance with NAAMM, Code of Standard Practice for the Metal Industry, Workmanship, Class 1.

2 Products

2.1 **MATERIALS**

.1 General:

- .1 All materials under work of this Section, including but not limited to, primers and paints are to have low VOC content limits.
- .2 Unless detailed or specified herein, standard products will be acceptable if construction details and installation meet intent of Drawings and Specifications.
- .3 Include all materials, products, accessories, and supplementary parts necessary to complete assembly and installation of work of this Section.
- .4 Incorporate only metals that are free from defects which impair strength or durability, or which are visible. Install only new metals of best quality, and free from rust or waves and buckles, and that are clean, straight, and with sharp defined profiles.
- .2 Structural shapes, plates, and similar items: CAN/CSA-G40.20/G40.21-M, Grade 350W. Hollow structural sections: CAN/CSA-G40.20/G40.21-M, Grade 350W, Class H.
- .3 Galvanized sheet steel: ASTM A653/A653M Grade A, Z275 Commercial Quality zinc coating, size and shape as shown.
- .4 Stainless steel sheet and plate: ASTM A480/A480M, Type 304, finish to AISI No. 4. Size as shown.
- .5 Stainless steel tubing: ASTM A269, Type 304, to AISI No. 4 finish. Size as shown.
- .6 Stainless steel shapes: ASTM A276, Type 304, finish to AISI No. 4 or X-L Blend S as indicated. Sizes and shapes as shown.
- .7 Welding materials: CSA W48 and CSA W59-M.
- .8 Fasteners: Conforming to ASTM A307, Grade A, in areas not exposed to view, use unfinished bolts with hexagon heads and nuts. In areas exposed to view, use bolts, nuts, washers, rivets, lock washers, anchor bolts, machine screws and machine bolts Z275 zinc coated in accordance with ASTM A653/A653M. Supply bolts of lengths required to suit thickness of material being joined, but not projecting more than 6 mm beyond nut, without the use of washers.
- .9 Primer paint: CAN/CGSB-1.40-M or CPMA 1.73a.
- .10 Galvanized primer paint: Inorganic zinc rich primer. For use on galvanized fabrications where touch up is to remain unpainted in finished work; Carbozinc 11WB by Carboline Company, Catha-Coat 305 by Devoe Coatings or Zinc Clad XI by Sherwin Williams.

- .11 Drilled inserts: "HSL-3" by Hilti Inc. or "Dynabolt Sleeve Anchors" by ITW Construction Products, heavy-duty anchors, sizes as shown.
- .12 Adhesive anchor system: 'HIT HY 200 Injectable Mortar with Hilti HAS Stainless Steel Anchor Rod System' by Hilti Ltd. or approved alternative by ITW Construction Products, complete with all components required for a complete installation.

2.2 FABRICATION

- .1 Verify dimensions of existing Work before commencing fabrications and report any discrepancies to the Consultant.
- .2 Fit and assemble work in shop where possible. Execute work in accordance with details and reviewed shop drawings.
- .3 Use self-tapping shake-proof screws on items requiring assembly by screws or as indicated. Use screws for interior metal work. Use welded connections for exterior metal work unless otherwise found acceptable by the Consultant.
- .4 Ensure exposed welds are continuous for length of each joint. File or grind exposed welds smooth and flush. Seal exterior steel fabrications against corrosion in accordance with CAN/CSA S16.1-M.
- .5 Execute shop welding to requirements specified .
- .6 Carefully make and fit details. Take special care with exposed finished work to produce a neat and correct appearance to the Consultant's acceptance.
- .7 Assemble members without twists or open joints.
- .8 Correctly size holes for connecting work of other trades where such can be determined prior to fabrication. Where possible, show holes on shop drawings. Place holes not to cause appreciable reduction in strength of member.
- .9 Draw mechanical joints to hairline tightness and seal countersunk screw and access holes for locking screws with metal filler where these occur on exposed surfaces.

2.3 FABRICATED ITEMS

- .1 Refer to Drawings for details of metal fabrication work and related items not specifically listed in this Section.
- .2 Where work is required to be built into work of other Sections supply such members to respective Sections.
- .3 Provide miscellaneous and metal fabrications indicated on the drawings, listed below, and not indicated to be supplied under other Sections. Provide miscellaneous and metal fabrications including but not limited to the following:

- .4 Channel door frames: Structural channel sections, selected for trueness of web and flange, with joints welded and ground smooth. Supply bar stop and bent bar anchors for anchorage to masonry or concrete as required. Fit frames with temporary spreaders to prevent frame from springing out of shape.
- .5 Vanity counter supports:
 - .1 Providesupports for vanity counters. Construct supports of steel angles and steel plate as detailed. Where indicated, conceal supports within cavity of drywall partition.
 - .2 Provide all drill holes required for concealed anchorage of counters and for anchoring to building structure.
- .6 Miscellaneous steel brackets, supports and angles
 - .1 Supply and install or supply for installation by trades responsible, all loose steel brackets, supports and angles where indicated, except where such brackets, supports and angles are specified under work of other Sections. Drill for countersunk screws, expansion anchors and anchor bolts.
 - .2 Unless otherwise specified, prime paint for interior installation; galvanized finish for exterior installation.

2.4 STAINLESS STEEL WORK

- .1 Take all necessary precautions to safeguard against latent surface discolouration due to disturbance of the natural protective oxide coating of the material or to contamination from other sources.
- .2 Workmanship shall be the best standard practice for this type of work. Execute stainless steel work in accordance with the applicable instructions set forth in Atlas Stainless Steels' "Technical Data" handbook on stainless steel.
- .3 Do all stainless steel fabrication in clean shops, located away from areas where carbon steel is burnt, ground, or cut with abrasive wheels to ensure that carbon steel dust will not be embedded into the stainless steel, and as follows:
 - .1 In fabrication of stainless steel do not use tools and dies which have been used on carbon steels.
 - .2 Ensure tools and dies use for forming and cutting stainless steel are free of nicks and other damage.
 - .3 Do not use carbon grits and grinding wheels which will imbed foreign particles into stainless steel surfaces. Use only stainless steel wool when wool polishing is required.
 - .4 Stainless steel items, on which rust stains appear, shall be replaced with new fabricated material.

2.5 ANCHORS AND FASTENING

- .1 Use weld studs of size not larger than 10 mm for attaching miscellaneous materials and equipment to building steel. If weight of item requires larger fasteners use clips or brackets and secure by welding or through bolting.

- .2 Use self drilling expansion type concrete anchors for attaching to masonry and concrete
- .3 Do not secure items to steel deck.
- .4 Use steel beam clamps of two bolt design to transmit load to beam web. Do not use C and I clamps.

2.6 **WELDING**

- .1 Perform welding by electric arc process.
- .2 Execute welding to avoid damage or distortion to Work. Execute welding in accordance with following standards:
 - .1 CSA W48 - for Electrodes. If rods are used, only coated rods are allowed.
 - .2 CSA W59-M and CSA W59S1-M for design of connections and workmanship.
 - .3 CAN/CSA W117.2-M - for safety.
- .3 Thoroughly clean welded joints and expose steel for a sufficient distance to perform welding operations. Finish welds smooth. Supply continuous and ground welds which will be exposed to view and finish paint.
- .4 Test welds for conformance and remove work not meeting specified standards and replace to Consultant's acceptance.

2.7 **SHOP PAINTING**

- .1 Clean steel to SSPC SP6 and remove loose mill scale, weld flux and splatter.
- .2 Shop prime steel with one coat of primer paint to dry film thickness of 0.07 mm. Paint on dry surfaces, free from rust, scale, grease. Do not paint when temperature is lower than 7 deg C. Paint items under cover and leave under cover until primer is dry. Follow paint manufacturer's recommendations regarding application methods, equipment, temperature, and humidity conditions.
- .3 Shop prime galvanized steel in accordance with CGSB 85-GP-16M.
- .4 Clean but do not paint surfaces being welded in field.
- .5 Do not paint surfaces embedded in concrete, but clean as if they were to be primed.
- .6 Do not prime steel to be fireproofed or to receive intumescent paint coating.
- .7 Do not prime machine finished surfaces, but apply an effective anti-rust compound.
- .8 Take precautions to avoid damage to adjacent surfaces.

3 Execution

3.1 **EXAMINATION**

- .1 Examine previously installed Work, upon which this Section depends, verify dimensions and condition of existing Work, and coordinate repairs, alterations, and rectification if necessary. Commencement of work of this Section is deemed to signify acceptance of existing, prior conditions.
- .2 Obtain Consultant's written approval prior to field cutting or altering of structural members.

3.2 **ERECTION**

- .1 Install metal fabrications in accordance with reviewed shop drawings and manufacturer's written instructions.
- .2 Fit joints and intersecting members accurately. Make work in true planes with adequate fastenings. Build and erect work plumb, true, square, straight, level and accurate to sizes detailed, free from distortion or defects detrimental to appearance or performance.
- .3 Perform drilling of concrete and steel as required to fasten work of this Section.

3.3 **TOUCH UPS**

- .1 Paint bolt heads, washers, nuts, field welds and previously unpainted items. Touch up shop primer damaged during transit and installation, with primer to match shop primer.

END OF SECTION

1 General

1.1 **SECTION INCLUDES**

.1 Labour, Products, equipment and services necessary for rough carpentry work in accordance with the Contract Documents.

1.2 **REFERENCES**

.1 ASTM A325, Specification for Bolts Quenched/Tempered Steel Nominal Thread Diameter M16 - M36 For Structural Steel Joints.

.2 ASTM A653, Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.

.3 ASTM D2898, Standard Practice for Accelerated Weathering of Fire Retardant Treated Wood for Fire Testing.

.4 ASTM E84, Standard Test Method for Surface Burning Characteristics of Building Materials.

.5 ASTM F1667, Driven Fasteners: Nails, Spikes and Staples.

.6 CAN/CSA O80 Series M, Wood Preservation.

.7 CAN/CSA O141, Softwood Lumber.

.8 CAN/ULC-S102, Standard Method of Test for Surface Burning Characteristics of Building Materials and Assemblies.

.9 NLGA, Standard Grading Rules for Canadian Lumber, National Lumber Grades Authority

1.3 **QUALITY ASSURANCE**

.1 Lumber identification: Grade stamp of an agency certified by the Canadian Lumber Standards Accreditation Board.

.2 Lumber quality: Carefully select individual pieces so that knots and obvious defects will not interfere with placing bolts, proper nailing or making proper connections.

.3 Moisture Content of wood at time of construction shall be 19% maximum.

.4 Each piece of pressure treated lumber and fire retardant treated lumber shall be shop marked with the pressure treatment brand and ULC monogram respectively, in accordance with CAN/CSA O80-M.

5. Dimensions of lumber shall conform to dressed sizes specified in CAN/CSA-0141 unless actual dimensions are otherwise indicated or specified.

6. Dimensional references to lumber on Drawings and in Specifications are to nominal sizes unless actual dimensions are indicated. Such actual dimensions shall be dry size.
- .7 Lumber defects: Discard wood with defects which will render a piece unable to serve its intended function. Lumber will be rejected by Consultant for excessive warp, twist, bow, crook, mildew, fungus, or mould, as well as for improper cutting and fitting, whether or not it has been installed.

1.4 ENVIRONMENTAL REQUIREMENTS

1. When it is required that wood maintain dimensional stability and tolerances to ensure accurate installation of later work, store and install it only in dry areas, and where no further installation of moist materials is contemplated.

1.5 PRODUCT DELIVERY, STORAGE AND HANDLING

- .1 Store materials in a dry area. Cover materials with tarpaulins or polyethylene sheets to prevent moisture absorption and impairment of structural and aesthetic properties. Vent to allow air movement. Tie covering to keep in place.

2 Products

2.1 MATERIALS

- .1 General: All materials under work of this Section, including but not limited to, adhesives are to have low VOC content limits.
- .2 Lumber: Softwood, G4S, moisture content 19% or less at time of installation, in accordance with the following:
 - .1 Lumber shall be of same species and grade, equally seasoned and shall be processed and stamped at same mill.
 - .2 CSA O141 and NLGA Standard Grading Rules for Canadian Lumber.
 - .3 Board quality: Construction or better.
 - .4 Dimension quality:
 - .1 Structural joists, planks, and framing: No. 1 Select Structural.
 - .2 Light framing: Construction.
- .3 Fire retardant treatment of lumber and plywood (interior and protected locations): 'Dricon FRT' fire retardant treatment by Biewer Lumber or approved alternative, conforming to ASTM E84, to provide a flame spread rating of 25 or less.
- .4 Rough hardware: Conforming to ASTM F1667; Nails, bolts, screws, anchors, expansion shields, and other fastenings required to frame and fix rough carpentry as follows:
 - .1 Nails, spikes and staples: Spiral type.
 - .2 Bolts: ASTM A325; 12.7 mm diameter minimum with nuts and washers unless noted otherwise.

- .3 Screws: Countersunk head, full thread type.
- .4 Proprietary fasteners: Toggle bolts, expansion shields, lag bolts, screws, inorganic fibre plugs, recommended for purpose by manufacturer.
- .5 Galvanize rough hardware used in fire treated wood and hardware exposed to the atmosphere.

3 Execution

3.1 **EXAMINATION**

- .1 Verify condition and dimensions of previously installed Work upon which this Section depends. Report defects to Consultant. Commencement of work of this Section means acceptance of existing conditions.

3.2 **GENERAL**

- .1 Lay out work carefully and to accommodate work of others. Cut and fit accurately: erect in position indicated by Drawings.
- .2 Install rough carpentry to allow for expansion and contraction of the materials.
- .3 Cut work into lengths as long as practicable and with square ends. Align, level, square, plumb, and secure work permanently in place. Brace work temporarily as required. Join work only over solid backing.
- .4 Bore holes true to line and to same size as bolts. Drive bolts into place for snug fit, and use plates or washers for bolthead and nut bearings. Turn up bolts and lag screws tightly when installed, and again just before concealed by other work or at completion of Work.
- .5 Provide anchors, bolts, and inserts required for attachment of the work of this Section, to those performing the work of other Sections and who are responsible for their installation.
- .6 Do not attach work by wood plugs or blocking in concrete or masonry. Use lead shields, expansion shields, or similar methods only as approved by Consultant.

3.3 **MISCELLANEOUS WOODWORK**

- .1 Fit and install wood furring, strapping, grounds and blocking. Adequately size, correctly place and conceal members for finishes, fitments and for work under other Sections. Do not assume that Drawings show required work exactly or completely. Anchor wood members securely in place.
- .2 Install rough bucks, nailing strips and linings to rough openings as required for backing for frames and other work.

- .3 Except where steel supports are specifically shown, provide wood blocking and supports in metal stud partitions for fastening of item such as casework and other wall mounted accessories. Have respective trades approve the location of such wood blocking.
- .4 Bolt wood blocking or nailing strips to steel framing.
- .5 Align and plumb faces of furring and blocking to tolerance of 1:600.
- .6 Use fire retardant lumber for blocking/framing in ceiling\ spaces, partitions and bulkheads.

3.4 **FASTENERS**

- .1 Frame, anchor, fasten, tie and brace members for required strength and rigidity.
- .2 Use hot dipped galvanized fasteners for exterior work and work below grade.
- .3 Countersink bolts and bolt heads as required for clearance of other work.
- .4 Size fasteners to penetrate base member by half of fastener length minimum. Minimize splitting of wood members by staggering nails in direction of grain.
- .5 For plywood use spiral, annular or resin coated nails and staples.

3.5 **SURFACE-APPLIED WOOD PRESERVATIVE**

- .1 Treat raw surfaces, drilled holes and cut ends of pressure treated wood with 2 coats of wood preservative immediately after cutting.
- .2 Apply preservative by dipping, by brush or by pouring into plugged holes to completely saturate surface.

END OF SECTION

-
- 1 General
- 1.1 **SECTION INCLUDES**
- .1 Labour, Products equipment and services necessary for the finish carpentry work in accordance with the Contract Documents.
- 1.2 **REFERENCES**
- .1 ANSI A208.1, Particleboard.
- .2 ANSI/HPVA HP-1, Hardwood and Decorative Plywood.
- .3 ANSI/NEMA LD 3, High-Pressure Decorative Laminates.
- .4 APA - The Engineered Wood Association.
- .5 ASTM F1667, Driven Fasteners: Nails, Spikes and Staples.
- .6 Architectural Woodwork Manufacturers Association of Canada (AWMAC).
- .7 North American Architectural Woodwork Standards (NAAWS).
- .8 CAN/CSA O141, Softwood Lumber.
- .9 CSA O151-M, Canadian Softwood Plywood.
- .10 National Hardwood Lumber Association (NHLA) Rules for the Measurement and Inspection of Hardwood and Cypress.
- .11 National Lumber Grades Authority (NLGA) Standard Grading Rules for Canadian Lumber.
- 1.3 **SUBMITTALS**
- .1 Shop drawings: Submit shop drawings of finish carpentry work in accordance with Section 01 00 00 indicating:
- .1 Materials, thicknesses, sizes, finishes, wood species, grades, profiles, connection attachments, shop jointing, field jointing, reinforcing, anchorage, fastener types and sizes, location of exposed fastenings, mechanical and electrical service routes, service outlets, cutout locations, and sizes.
- .2 Include erection drawings, plans, elevations, sections, and details as applicable.
- .2 Samples: Submit samples of the following in accordance with the requirements of Section 01 00 00:
- .1 Two representative pieces of each type of wood to receive a stained or natural finish.
- .2 Two representative pieces of each type of wood finished as specified.

- .3 Two of each colour, pattern, gloss, and texture of plastic laminate, in manufacturer's standard tag size.
- .4 Two samples of laminated plastic joints, edging, cutouts and postformed profiles.
- .5 Two of each quartz surface, in 100 x 75 x 19 mm samples.
- .6 One of each item of finish carpentry hardware.

- .3 Extended warranty: Submit extended warranty signed and registered by the manufacturer providing the warranty in the name of the Owner for the timeframe and coverage specified in this Section.

1.4 **QUALITY ASSURANCE**

- .1 Execute work of this Section by member of AWMAC, with 5 years experience in finish carpentry work of comparable complexity and scope. Submit proof of experience upon Consultant's request.
- .2 Fabricate finish carpentry work in accordance with NAAWS, Premium Quality materials and installation unless otherwise indicated. Perform work in accordance with the definition of Good Workmanship as defined in the NAAWS.
- .3 Remove and replace finish carpentry work which does not conform to the NAAWS or as amended by these Specifications.
- .4 Mock-up:
 - .1 Shop fabricate one mock-up of a base cabinet, wall cabinet, and counter top for each type of surfacing specified, complete with hardware and shop applied finishes, installed in location acceptable to Consultant.
 - .2 Arrange for Consultant's review and acceptance, allow 48 hours after acceptance before proceeding with work.
 - .3 When accepted, mock-up will demonstrate minimum standard for this work. Mock-up may remain as part of Work if accepted by Consultant. Remove and dispose of mock-ups which do not form part of Work.

1.5 **DELIVERY, STORAGE, AND HANDLING**

- .1 Deliver, store, and handle finish carpentry in accordance with the NAAWS. Control the temperature and humidity in accordance with the NAAWS recommendations, before, during, and after finish carpentry delivery, and also during storage and installation.

1.6 **EXTENDED WARRANTY**

- .1 Submit an extended warranty for finish carpentry work of this Section in accordance with General Conditions, except that warranty period is extended to 2 years from date of Contract Documents.
 - .1 Warrant against defects in material and workmanship including but not limited to opening of joints, cracking, shrinkage, warpage, and delamination of finish carpentry.

.2 Coverage: Complete replacement including affected adjacent Work.

2 Products

2.1 **MATERIALS**

.1 General:

.1 Materials used for work of this Section are to include, but not be limited to the following criteria:

- .1 Regionally sourced materials.
- .2 FSC Certified wood.
- .3 Low VOC content limits.

.2 Adhesives - Urea-formaldehyde-free glues.

.3 All dimensional lumber and plywood to be FSC certified.

.4 All composite wood and/or agrifibre products (including core materials) and adhesives used to fabricate laminated assemblies used in building must not contain added urea-formaldehyde.

.5 Material to be sourced regionally from within 800 km of jobsite wherever possible.

.2 Concealed framing lumber and plywood (marine grade):

.1 Eastern Spruce, Balsam Fir, or Jack Pine, to CAN/CSA O141, NLGA, and NAAWS Custom Grade, S4S, average moisture content 7% +/- 2% at installation.

.2 Softwood plywood: CSA O151-M; 13 mm or 19 mm unless indicated otherwise, (G2S).

.3 Hardwood lumber: Conform to NHLA and NAAWS Premium Grade, S4S, average moisture content 7% +/- 2% at installation.

.4 Plastic laminate (PLAM-#): Provide plastic laminates conforming to ANSI/NEMA LD 3 as follows:

.1 Flatwork face sheet: 1.2 mm thick, heavy wear resistance.

.2 Vertical interior face sheets: 0.8 mm thick.

.3 Postformed face sheet: 0.8 mm thick.

.4 Backing sheet: thickness to match face sheet, high pressure laminate, manufactured by same manufacturer as face sheet.

.5 Edge: Hot air edge banding by Rehau or approved alternative.

.6 Plastic laminate: As manufactured by Arborite, Formica, Forbo, Nevamar, Pionite and Wilsonart or approved alternative.

.7 Colours: Refer to Finish / Material / Product Schedule.

5. Melamine Surfaced Particleboard: ANSI A208.1, Grade M2 particleboard with a melamine impregnated decorative paper thermofused onto the surface. Edging to be done in minimum 0.5 mm thin PVC to match melamine colour. 'Panval Thermofused Melamine Panels' by Uniboard Canada Inc. or approved alternative. Colours as follows:

.1 Interior millwork surfaces: White.

- .2 Exterior millwork surfaces: Colour and pattern as selected by Consultant.
- .6 Medium Density Fibreboard (MDF), core or panel: ANSI A208.2; omnidirectional, light coloured with uniform density throughout 'Superior MDF' by G-P Flakboard Ltd. or 'Panfibre Excel MDF' by Uniboard Canada Inc., meeting the following minimum criteria:
 - .1 Density: 740 kg/m³.
 - .2 Internal bond: 0.8 N/mm².
 - .3 Modulus of rupture: 30 N/mm².
 - .4 Modulus of elasticity: 3400 N/mm².
 - .5 Face screw holding: 1450 N.
 - .6 Core screw holding: 1300 N.
 - .7 Moisture content: 4-7%
- .7 Particle board core: ANSI A208.1, Grade M2 of thickness indicated. Particleboard to be bound with waterproof adhesive and meeting the following minimum criteria:
 - .1 Density: minimum 705 kg/m³.
 - .2 Internal bond: 0.45 N/mm².
 - .3 Modulus of rupture: 14.5 N/mm².
 - .4 Modulus of elasticity: 2250 N/mm².
 - .5 Face screw holding: 1000 N.
 - .6 Edge screw holding: 900 N.
- .8 Porcelain Slab (PCT-1): 12 mm thick, Laminam pure ceramic slabs, manufactured by Stonetile or approved alternative. Size indicated on Drawings.
- .9 Solid surfacing (CS-1):
 - .1 12 mm thick sheet stock, provide with bullnose edge and all cutouts as required. 'Corian' solid surfacing by DuPont or approved alternative in colour selected by Consultant.
 - .2 Installation and seam adhesives to be as recommended by solid surfacing manufacturer, colour matched to solid surfacing.
- .10 Laminating adhesive: CSA O112 Series, water resistant type, low VOC content, selected by laminate manufacturer for intended end use.
- .11 Draw bolts and splines: Type as recommended by fabricator.
- .12 Nails and staples: Conforming to ASTM F1667; Size and type to suit application, galvanized for interior humid areas and for treated lumber; plain finish elsewhere.
- .13 Bolts, nuts, washers, blind fasteners, lags and screws: Size and type to suit application. Stapling is not acceptable.
- .14 Adhesive and bituminous mastic: Selected by the millwork fabricator with low VOC content.
- .15 Miscellaneous metals: In accordance with Section 05 50 00.

- .16 Finishing: In accordance with Section 09 91 00.

2.2 **HARDWARE**

- .1 The following hardware is the minimum quality standard for the work of this Section. Alternatives may be considered provided they are approved by Consultant prior to ordering of products.
- .2 Drawer slides: Full extension, 8400 Series by Knape & Vogt.
- .3 Pilasters: Clear anodized aluminum recessed shelf standards with 12 mm divisions, Model 233 by Knape & Vogt.
- .4 Clips: Bright zinc plated, adjustable height shelf supports, Model 256 by Knape & Vogt.
- .5 Cabinet hinges: Heavy duty, concealed, 100 degree, clip, self closing, Model MODUL by Blum.
- .6 Drawer and cabinet pulls: 10 mm dia. x 106 mm wide, stainless steel with matt finish, 115.61.601 by Hafele.
- .7 Magnetic catches: Model 918 by Knape & Vogt.
- .8 Locks: Cam locks/deadbolt locks complete with lock core by Hafele, type to suit application and installation.

2.3 **PLASTIC LAMINATE WORK**

- .1 Perform plastic laminate work in accordance with NAAWS and ANSI/NEMA LD 3.
- .2 Ensure adjacent parts of continuous laminate work match in colour and pattern.
- .3 Laminate plastic laminates to veneer core plywood, unless otherwise specified or indicated, in accordance with manufacturer's instructions. Laminate postformed laminates to particle board core in accordance with manufacturer's instructions.
- .4 Fabricate core surfaces and profiles with continuous support and bond over entire surface to receive plastic laminate.
- .5 Apply plastic laminate backing sheets to balance shrinkage stresses induced by plastic laminate face sheets.
- .6 Joints:
 - .1 Install joints in accordance with reviewed shop drawings.
 - .2 Jointing shall be placed at logical locations in intended millwork item and shall meet the overall aesthetic intent of the Consultant.
 - .3 Minimize joints in plastic laminate work.
 - .4 Do not install joints in plastic laminate work in less than 2400 mm o.c.

- .5 Locate joints minimum 610 mm from cut-outs.
- .6 Offset core and plastic laminate facing joints.
- .7 Form shaped profiles and bends as indicated, using postformed grade laminate to laminate manufacturer's instructions.
- .8 Edging to be done using straight self-edging laminate strip to match adjacent colour, finish, gloss, and pattern to cover exposed edge of core material. Chamfer exposed edges uniformly at approximately 20 degrees. Do not mitre laminate edges.
- .9 Apply laminated plastic liner sheet to interior of cabinetry and where indicated.
- .10 Fabricate units by solid surfacing manufacturer's certified or approved fabricator/installer. Fabricate built-up profiles as indicated.

2.4 **FABRICATION**

- .1 Be responsible for methods of construction and for ensuring that materials are rigidly and securely attached and will not be loosened by the work of other sections.
- .2 Coordinate locations of concealed supports and blocking with other parts of work. Provide cutouts for outlet boxes and other fixtures.
- .3 Fabricate work in a manner which will permit expansion and contraction of the materials without visible open joints. Conceal joints and connections in wherever possible.
- .4 Set nails and countersink screws, apply wood filler to indentations, sand smooth and leave ready to receive finish.
- .5 Mitre exposed corners, no end grain shall be visible in completed installation.
- .6 Finish millwork in accordance with Section 09 91 00. Finished millwork shall be free from bruises, blemishes, mineral marks, knots, shakes and other defects and shall be selected for uniformity of colour, grain and texture.
- .7 Shelving to cabinetwork to be adjustable unless otherwise noted.
- .8 Recess shelf standards, unless noted otherwise. Stagger recessed shelf standards on opposite sides of divider.
- .9 Do not exceed maximum 760 mm unsupported span for 19 mm thick shelving. House fixed shelving into gables and divisions.
- .10 Shop assemble finish carpentry to accommodate delivery and handling and to ensure passage through building openings.
- .11 Shop install cabinet hardware for doors, shelves and drawers. Recess shelf standards unless noted otherwise.

-
- .12 Fabricate finish carpentry to profiles shown.
- 3 Execution
- 3.1 **EXAMINATION**
- .1 Verify condition and dimensions of previously installed Work upon which this Section depends. Report defects to Consultant. Commencement of work of this Section means acceptance of existing conditions.
- 3.2 **INSTALLATION**
- .1 Install finish carpentry work in accordance with NAAWS and tolerances for architectural woodwork and reviewed shop drawings.
 - .2 Set and secure finish carpentry in place, rigid, plumb, square, and level.
 - .3 Scribe and cut as required, fit to abutting walls, and surfaces, fit properly into recesses and to accommodate columns, fixtures, outlets, or other projecting, intersecting or penetrating objects leaving a 0.8 mm gap maximum.
 - .4 Coordinate cutouts for plumbing fixtures, inserts, appliances, outlet boxes, and other fixtures, in finish carpentry. Round internal corners of cut-outs and seal exposed cores.
 - .5 Form joints to conceal shrinkage.
 - .6 Install draw bolts and splines in laminated plastic counter top joints at maximum spacing 450 mm o.c., and 75 mm from edge. Make joints flush, hairline butt joints.
 - .7 Install finishing hardware accurately and securely in accordance with manufacturer's directions, adjust and clean.
 - .8 Install prefinished millwork at locations shown on drawings. Position accurately, level, plumb straight.
 - .9 Apply bituminous coating over wood framing members in contact with masonry or cementitious construction.
 - .10 Porcelain slab:
 - .1 Install porcelain slab in accordance with manufacturer's instructions.
 - .2 Align work plumb and level.
 - .3 Seal perimeter of fabrication to adjacent construction in accordance with Section 07 92 00.
 - .11 Solid surfacing:
 - .1 Install solid surfacing in accordance with manufacturer's instructions.
 - .2 Align work plumb and level.

- .3 Seal perimeter of fabrication to adjacent construction in accordance with Section 07 92 00.

- .12 Wood blocking:
 - .1 Fit and install wood furring, strapping, grounds and blocking. Adequately size, correctly place and conceal members for finishes, fitments and for work under other Sections. Do not assume that Drawings show required work exactly or completely. Anchor wood members securely in place.
 - .2 Install rough bucks, nailing strips and linings to rough openings as required for backing for frames and other work.
 - .3 Except where steel supports are specifically shown, provide wood blocking and supports in metal stud partitions for fastening of item such as casework and other wall mounted accessories. Have respective trades approve the location of such wood blocking.

- .13 Fastening:
 - .1 Coordinate wall securement, anchorage, and blocking for finish carpentry items.
 - .2 Position items of finished carpentry work accurately, level, plumb, true and fasten or anchor securely.
 - .3 Design and select fasteners to suit size and nature of components being joined. Use proprietary devices as recommended by manufacturer.
 - .4 Provide heavy duty fixture attachments for wall mounted cabinets.
 - .5 Set finishing nails to receive filler. Where screws are used to secure members, countersink screw in round cleanly cut hole and plug with wood plug to match material being secured.

- .14 Remove and replace damaged, marked, or stained finish carpentry.

END OF SECTION

1 General

1.1 **SECTION INCLUDES**

- .1 Labour, Products, equipment and services necessary for firestopping and smoke seals work in accordance with the Contract Documents.

1.2 **REFERENCES**

- .1 ASTM C303, Standard Test Method for Dimensions and Density of Preformed Block and Board-Type Thermal Insulation.
- .2 ASTM C920, Standard Specification for Elastomeric Joint Sealants.
- .3 ASTM C1104, Standard Test Method for Determining the Water Vapor Sorption of Unfaced Mineral Fiber Insulation.
- .4 ASTM E814, Test Method for Fire Tests of Through-Penetration Fire Stops.
- .5 ASTM E2174, Standard Practice for On-Site Inspection of Installed Fire Stops.
- .6 CAN/ULC S102, Surface Burning Characteristics of Building Materials and Assemblies.
- .7 CAN/ULC S114, Standard Method of Test for Determination of Non-Combustibility in Building Materials.
- .8 CAN/ULC S115, Standard Method of Fire Tests of Firestop Systems.
- .9 CAN/ULC S129, Standard Method Of Test For Smoulder Resistance Of Insulation (Basket Method).
- .10 CAN/ULC S702, Thermal Insulation, Mineral Fibre for Buildings.

1.3 **DEFINITIONS**

- .1 Fire Separation: A construction assembly, plane or device, either vertical or horizontal, which is required to prevent the passage of fire and smoke for a prescribed period of time. Proof of compliance to required time rating shall be by ULC, Warnock Hersey (or similar approved) certification or shall be as listed in the Ontario Building Code Supplementary Standard SB-2.
- .2 Smoke Separation: A construction assembly, plane or device, either vertical or horizontal, which is not required to prevent the passage of fire for a prescribed period of time but is required to prevent the passage of smoke. A "Smoke Separation" is also known as a "Fire Separation with No Rating" or a "Zero Hour Rated Separation".

- .3 Non-Rated Separation: A construction assembly, plane or device, either vertical or horizontal, which is not required to prevent the passage of fire for a prescribed period of time and is not required to prevent the passage of smoke.

1.4 **SYSTEM DESCRIPTION**

- .1 Firestopping and smoke seals: ULC or Intertek Testing Services listed Products and systems in accordance with CAN/ULC S115 suitable to actual application and installation conditions.
- .2 Firestop applications that exist for which no ULC or cUL tested system is available through a manufacturer, a manufacturer's engineering judgment derived from similar ULC or cUL system designs or other tests will be submitted to local authorities having jurisdiction for their review and approval prior to installation. Engineer judgment drawings must follow requirements set forth by the International Firestop Council.
- .3 Firestop and smoke seal system shall achieve a fire resistance rating and smoke seal rating equal to that of assemblies into which they are installed.
- .4 Provide smoke sealants over firestopping materials or combination smoke seal/firestop seal material to form air tight barriers to retard the passage of gas and smoke.
- .5 Firestopping and smoke seals located at movement joints shall be designed with movement capability.
- .6 Firestopping and smoke seals within mechanical and electrical assemblies shall be provided as part of the work of Divisions 21, 22, 23, 26, 27, and 28 respectively.

1.5 **SUBMITTALS**

- .1 Product data:
 - .1 Submit copies of manufacturer's Product data in accordance with Section 01 00 00 indicating:
 - .1 Performance criteria, compliance with appropriate cUL or ULC reference standard, characteristics, limitations.
 - .2 Product transportation, storage, handling and installation requirements.
 - .3 Submit firestop and smoke seal manufacturer's Product data for materials and prefabricated devices, including manufacturer's printed installation instructions.
 - .2 Shop drawings:
 - .1 Submit shop drawings in accordance with Section 01 00 00 indicating:
 - .1 Fire rated and smoke sealed systems for each typical application.
 - .2 Construction details, accurately reflecting actual job conditions.
 - .3 ULC or Intertek Testing assembly listing.

-
- .4 Each floor and wall assembly requiring firestop system with each corresponding ULC firestop system.
 - .3 Certification:
 - .1 Submit certified documentation from manufacturer for each worker performing work of this Section.
 - .2 Submit installer's and Product manufacturer's certification verifying compliance with the Contract Documents and conformance with ASTM E814 and CAN/ULC S115.
 - 1.6 **QUALITY ASSURANCE**
 - .1 Installers qualifications: Perform work of this Section by a company that has a minimum of five years proven experience in the installation of firestopping and smoke seal work of a similar size and nature and that is approved by manufacturer. Submit to Consultant, applicator's current certificate of approval by the material manufacturer as proof of compliance.
 - .2 Manufacturer's direct representative and/or fire protection specialist shall be on-site during initial installation of firestop systems to train appropriate contractor personnel in proper selection and installation procedures conforming to manufacturer's written recommendations published in their literature and drawing details.
 - .3 Pre-construction meetings: Arrange with manufacturer's representative, Contractor, Consultant and Field Engineer to determine responsibility for handling such issues as FT rated partitions, firestop custom details, compatibility, mixed penetrations, and to review installation procedures 48 hours in advance of installation.
 - 1.7 **DELIVERY STORAGE AND HANDLING**
 - .1 Deliver materials to Place of Work in manufacturer's unopened containers, containing classification label with labels intact and legible at time of use.
 - .2 Do not use damaged or adulterated materials exceeding their expiry date.
 - 1.8 **SITE CONDITIONS**
 - .1 Conform to manufacturer's requirements and maintain a minimum temperature of 5⁰ C for a minimum period of 24 h before application, during, and until application is fully cured.
 - .2 Maintain sealant at a minimum 18° C for best workability.
 - 2 Products
 - 2.1 **ACCEPTABLE MANUFACTURERS**
 - .1 Acceptable manufacturers of rated systems include:

- .1 3M
- .2 Hilti Canada Corporation.
- .3 Specified Technologies Inc. (STI Firestop)
- .4 Tremco Ltd.

2.2 GENERAL SYSTEM REQUIREMENTS

- .1 All materials under work of this Section, including but not limited to, primers and sealants are to have low VOC content limits.
- .2 Do not use Products containing asbestos.
- .3 Firestopping components shall not contain volatile solvents or require special application to protect plastic pipe from firestopping compound.
- .4 Provide smoke seal sealant in following colours:
 - .1 Grey or white in finished areas.
 - .2 Red in unfinished areas.
- .5 Smoke sealant for overhead and vertical joints for floor to be self-levelling and non-sagging sealant.
- .6 Smoke sealant at vertical through penetrations in areas with floor drains shall be waterproof type.

2.3 MATERIALS

- .1 Following materials have been provided for convenience. Contractor shall provide complete system with all components and accessories as required for fire resistant and smoke seal installation.
- .2 Firestop sealant: single component, low modulus, silicone rubber, moisture curing sealant to ASTM C920, ULC labelled to CAN/ULC S115.
- .3 Pre-Installed firestop devices for use with non-combustible and combustible pipes, conduit and/or cable bundles penetrating concrete floors and walls.
 - .1 Cast-in place firestop device complete with aerator adaptor when used in conjunction with aerator system. Model CP 680-P by Hilti or approved alternative.
 - .2 Cast-in place firestop device for use with noncombustible penetrants. Model CP 680-M by Hilti or approved alternative.
 - .3 Speed sleeve for use with cable penetrations. Model CP 653 by Hilti or approved alternative.
 - .4 Firestop block. Model CFS-BL by Hilti or approved alternative.
- .4 Re-penetrable, round cable management devices for use with new or existing cable bundles penetrating walls:
 - .1 Speed sleeve with integrated smoke seal fabric membrane. Model CP 653 by Hilti or approved alternative.

- .2 Firestop Sleeve. Model CFS-SL SK by Hilti or approved alternative.
- .3 Retrofit sleeve for use with existing cable bundles. Model CFS-SL RK by Hilti or approved alternative.
- .4 Gangplate for use with multiple cable management devices. Model CFS-SL GP by Hilti or approved alternative.
- .5 Gangplate Cap for use at blank openings in gangplate for future penetrations. Model CFS-SL GP CAP by Hilti or approved alternative.
- .5 Firestop insulation: to CAN/ULC S702, Type 2; mineral fibre manufactured from rock or slag, suitable for manual application.
 - .1 Density: Minimum 64 kg/m³ when tested to ASTM C303.
 - .2 Combustibility: Noncombustible to CAN/ULC S114.
 - .3 Melt temperature: >1175 degrees C.
 - .4 Surface burning characteristics: to CAN/ULC S102, maximum flame spread of 0, smoke developed of 0.
 - .5 Moisture Absorption: 0.04 percent when tested to ASTM C1104.
 - .6 Smoulder Resistance: 0.01 percent when tested to CAN/ULC S129.
- .6 Damming, back-up, supports, and anchorage: In accordance with manufacturer's fire rated systems and to acceptance of authorities having jurisdiction.
- .7 Primer: As recommended by firestopping sealant manufacturer.

3 Execution

3.1 EXAMINATION

- .1 Verify condition and dimensions of previously installed Work upon which this Section depends. Report defects to Consultant. Commencement of work of this Section means acceptance of existing conditions.
- .2 Verify that substrates and surfaces to receive firestopping and smoke seals are clean, dry, and frost free.

3.2 PREPARATION

- .1 Prepare, modify, and adjust void sizes, proportions, and conditions to conform to fire rated and smoke sealed assembly requirements such as assembly opening size and dimensional restrictions.
- .2 Clean surfaces to remove material detrimental to bond including dust, paint, rust, oil, grease, moisture, frost and other foreign matter to manufacturers recommendations.
- .3 Mask adjacent surfaces to avoid spillage and over-coating of adjacent surfaces. Remove stains from adjacent surfaces.

3.3 INSTALLATION

- .1 Install firestopping and smoke seal systems in accordance with reviewed Shop Drawings, manufacturer's instructions and fire rated assembly to establish continuity and integrity of fire separations.
- .2 Install firestop insulation in compacted thicknesses required by ULC design. Compress insulation approximately 50 percent.
- .3 Install primers as recommended by firestop and smoke seal Product manufacturers.
- .4 Install temporary forming, damming, back-up as required, remove after materials have achieved initial cure and will resist displacement.
- .5 Install firestop and smoke seal filler in horizontal joints providing 25% compression fit.
- .6 Use resilient, elastomeric firestopping and smoke seal systems in following locations:
 - .1 Openings and sleeves for future use.
 - .2 Penetration systems subject to vibration or thermal movement.
 - .3 Penetration systems in acoustical containment enclosures.
- .7 Trowel and tool exposed firestop and smoke seal. Product surfaces to uniform, smooth finish.
- .8 Seal joints to ensure an air and water resistant seal capable of withstanding compressions and extensions due to thermal wind or seismic joint movement.
- .9 Taped joints will not be acceptable.
- .10 Repair damaged firestopped and smoke sealed surfaces to acceptance of Consultant.
- .11 Identify each firestop and smoke seal penetration assembly with permanent label listing following:
 - .1 Assembly and rating in hours.
 - .2 Date of installation.
 - .3 Installing company's name and telephone number.
- .12 Do not cover materials until full cure has taken place.

3.4 INSPECTION AND TESTING

- .1 Inspection of through-penetration firestopping shall be performed in accordance with ASTM E2174 to ensure that firestopping and smoke seals have been installed in accordance with Contract documents and to tested and listed firestop system.

3.5 **CLEAN-UP**

- .1 Clean all surfaces adjacent to sealed holes and joints to be free of excess firestop materials and soiling as work progresses.
- .2 Remove excess materials and debris immediately after application.

3.6 **SCHEDULE OF FIRESTOP AND SMOKE SEAL LOCATIONS**

- .1 Following firestop and smoke seal location schedule is included for convenience and may not be complete. Examine Contract Drawings and other specification sections and determine entire extent of work of this Section. Generally provide systems with required fire and smoke ratings at following locations:
 - .1 Gaps at intersections of fire-resistance rated walls and partitions.
 - .2 Control and sway joints in fire-resistance rated walls and partitions.
 - .3 Gaps at top of fire-resistance rated partitions and walls.
 - .4 Penetrations through fire-resistance rated walls and partitions including but not limited to mechanical and electrical services and openings and sleeves for future use.
 - .5 Penetrations through fire-resistance rated floor slabs, ceilings, and roofs.
 - .6 Gaps at edge of floor slabs at exterior walls.
 - .7 Perimeter of retaining angles on rigid ducts greater than 0.012 m², firestopping material between retaining angle and fire separation and between retaining angle and duct, on each side of fire separation.
 - .8 Where indicated on drawings.
 - .9 At non-rated assemblies that require a smoke seal.
 - .10 Where required by Ontario Building Code.

END OF SECTION

- 1 General
- 1.1 **SECTION INCLUDES**
 - .1 Labour, Products, equipment and services necessary for sealant work in accordance with the Contract Documents.
 - .2 Work of this Section does not include sealants in firestopping and smoke sealed assemblies.
 - .3 Work of this Section does not include sealant work identified in individual specification sections.
- 1.2 **REFERENCES**
 - .1 ASTM C834, Specification for Latex Sealants.
 - .2 ASTM C920, Specification for Elastomeric Joint Sealants.
 - .3 ASTM C1330, Specification for Cylindrical Sealant Backing for Use with Cold Liquid Applied Sealants.
- 1.3 **SUBMITTALS**
 - .1 Product data: Submit copies of Product data in accordance with Section 01 00 00 describing type, composition and recommendations or directions for surface preparation, material preparation and material installation.
 - .2 Samples:
 - .1 Submit following samples in accordance with Section 01 00 00 :
 - .1 Two samples of sealant/caulking, for colour selection.
 - .2 Two samples of back-up material and primer for physical characteristics.
 - .3 Extended warranty: Submit extended warranty signed and registered by the manufacturer providing the warranty in the name of the Owner for the timeframe and coverage specified in this Section.
- 1.4 **QUALITY ASSURANCE**
 - .1 Qualifications: Work of this Section shall be executed by trained applicators approved by sealant manufacturer and having a minimum of 5 years proven experience.
 - .2 Retain a Professional Engineer, licensed in Province of Ontario, with experience in scaffolding and rigging work of comparable complexity and scope, to perform following services as part of work of this Section:
 - .1 Design of scaffolding and rigging.
 - .2 Review, stamp, and sign shop drawings.

.3 Conduct on-site inspections, prepare and submit written inspection reports verifying that this part of Work is in accordance with Contract Documents and reviewed shop drawings.

.3 Mock-up:

.1 Construct one 1200 mm long mock-up of each sealant type in location acceptable to Consultant.

.2 Demonstrate joint preparation, sealant application and tooling.

.3 Arrange for Consultant's review and acceptance.

.4 Mock-up may remain as part of Work if accepted by Consultant. Remove and dispose of mock-ups which do not form part of Work.

.5 Upon acceptance, mock-up shall serve as a minimum standard of quality for the balance of the work of this Section.

.4 Pre-installation meetings: Arrange with manufacturer's representative and Consultant to inspect substrates, and to review installation procedures 48 hours in advance of installation.

1.5 **SITE CONDITIONS**

.1 Do not install materials when ambient air temperature is less than 5 °C, when recesses are wet or damp, or to manufacturer's recommendations.

1.6 **DELIVERY, STORAGE AND HANDLING**

.1 Arrange delivery of materials in original, unopened packages with labels intact, including batch number, and ensure that on-site storage is kept to a minimum. Do not store materials on site where there exists any danger of damage from moisture, direct sunlight, freezing and other contaminants.

1.7 **EXTENDED WARRANTY**

.1 Submit an extended warranty for Sealant work in accordance with General Conditions, except that warranty period is extended to 2 years from date of Contract Documents.

.1 Warrant against leakage, cracking, crumbling, melting, shrinkage, running, loss of adhesion and staining adjacent surfaces.

.2 Coverage: Complete replacement including affected adjacent work.

2 Products

2.1 **MATERIALS**

.1 General:

.1 All materials under work of this Section, including but not limited to, primers and sealants are to have low VOC content limits.

- .2 Use materials as received from manufacturers, without additives or adulterations. Use one manufacturer's Product for each kind of Product specified.
- .2 Sealant **Type A**: ASTM C920, Type M, Grade NS, Class 25; Two-part, Polyurethane non-sag type, in standard colours selected.
 - .1 'Sikaflex 2C-NS TG' by Sika Canada Inc.
 - .2 'Dymeric 240' by Tremco Ltd.
- .3 Sealant **Type B**: ASTM C920, Type S, Grade NS; One-part mildew-resistant silicone, in standard colours selected.
 - .1 'Dowsil 786 Mildew Resistant Silicone Sealant' by Dow Consumer Solutions.
 - .2 'Sikasil GP Mildew Resistant' by Sika.
 - .3 'Tremsil 200 Silicone Sealant' by Tremco Ltd.
- .4 Sealant **Type C**: ASTM C834; Pure acrylic siliconized sealant; in standard white colour (paintable).
 - .1 '950A Siliconized Acrylic Latex Caulk' by Sherwin Williams.
 - .2 'Tremflex 834 Siliconized Sealant' by Tremco Ltd.

2.2 ACCESSORIES

- .1 Primers: Type recommended by material manufacturers for various substrates, primers to prevent staining of adjacent surfaces encountered on project.
- .2 Joint backing: ASTM C1330; Round, solid section, closed cell, skinned surface, soft polyethylene foam gasket stock, compatible with primer and sealant materials, 30 to 50% oversized, Shore A hardness of 20, tensile strength 140 to 200 kPa. Bond breaker type surface.
- .3 Bond breaker: Type recommended by material manufacturers.
- .4 Void filler around the window frames to be one part expanding polyurethane foam.
- .5 Cleaning agents: As recommended by material manufacturer, non-staining, harmless to substrates and adjacent finished surfaces.

2.3 MIXING

- .1 Follow manufacturers instructions on mixing, shelf and pot life.

3 Execution

3.1 EXAMINATION

- .1 Verify condition and dimensions of previously installed Work upon which this Section depends. Report defects to Consultant. Commencement of work of this Section means acceptance of existing conditions.

3.2 INSPECTION

- .1 Arrange for the manufacturer of sealant to have a qualified technical representative visit the Site prior to commencement of caulking to discuss with applicator and Consultant the procedures to be adopted, to analyse conditions under which work will be done and to inspect surfaces and joints to be sealed, in order that alternative recommendations may be made should adverse conditions exist.
- .2 Verify that joint sealants, backing, and other materials containing hazardous materials have been removed.
- .3 Verify that joint substrates and adjoining materials are structurally sound.
- .4 Verify that joints to be renovated can be satisfactorily repaired with the specified methods and materials.

3.3 PREPARATION

- .1 Protect adjacent exposed surfaces to prevent smearing, staining or other damage, by masking or other means, prior to performing work. Make good any damage caused by sealant application. Remove protection upon completion and clean adjacent, exposed surfaces of any compound deposited upon such surfaces.
- .2 Prepare joints to receive sealants to manufacturer's instructions. Ensure that joints are clean and dry and ferrous surfaces are free from rust and oil.
- .3 Clean recesses to receive sealant, to be free of dirt, dust, loose material, oil, grease, form release agents and other substances detrimental to sealant's performance.
 - .1 Remove lacquer or other protective coatings from metal surfaces, without damaging metal finish, using oil-free solvents. Remove rust, mill scale and coatings from ferrous metals by wire brush, grinding or sand blasting.
 - .2 Ensure recess is dry.
 - .3 Do not apply sealants to joint surfaces treated with sealer, curing compound, water repellent, or other coatings. Remove incompatible coatings as required.
- .4 Ensure that all materials in contact with sealant are compatible. Test substrate for adhesion.
- .5 Depth of recess: Maintain depth to $\frac{1}{2}$ joint width up to a maximum of 13 mm and not less than 6 mm at centre of joint. For greater depth, use joint backing under. Where recess is less than specified depth, cut back surface of recess to specified recess depth.
- .6 Install polyethylene backing rod in joints 6 mm or more in width. Roll backing rod into joint. Do not stretch or bend backing rod. Install bond breaker to back of recess.
- .7 Prime sides of recess, in accordance with sealant manufacturer's instructions.

- .8 Condition products for use in accordance with manufacturer's recommendations.

3.4 **INSTALLATION**

- .1 Apply sealant immediately after adjoining work is in condition to receive such work. Apply sealant in continuous bead using gun with correctly sized nozzle. Use sufficient pressure to evenly fill joint.
- .2 Ensure sealant has full uniform contact with, and adhesion to, side surfaces of recess. Superficial painting with skin bead is not acceptable. Tool sealant to smooth surface, free from ridges, wrinkles, sags, air pockets, embedded impurities, dirt, stains or other defects.
 - .1 At recesses in angular surfaces, finish sealant with flat profile, flush with face of material at each side.
 - .2 At recesses in flush surfaces, finish compound with concave face, flush with face of material at each side.
- .3 Make sealant bead uniform in colour.
- .4 Cure sealants in accordance with sealant manufacturer's instructions. Do not cover up sealants until proper curing has taken place.
- .5 Immediately remove excess compound or droppings which would set up or become difficult to remove from adjacent finished surfaces, using recommended cleaners, as work progresses. Do not use scrapers, chemicals or other tools which could damage finished surfaces. Remove defective sealant.
- .6 Clean recesses and re-apply sealant.
- .7 Remove masking tape immediately after joints have been sealed and tooled.

3.5 **CLEANING**

- .1 Clean surfaces adjacent to joints, remove sealant smears or other soiling resulting from application of sealants. At metal surfaces, remove residue. Do not mar or damage finishes on materials adjacent to joints. Repair or replace marred or damaged materials.

3.6 **SCHEDULE OF LOCATIONS**

- .1 Following sealant location schedule is included for convenience and may not be complete. Examine Contract Drawings and other specification sections and determine entire extent of work of this Section. Generally seal following locations:
 - .1 Concrete, masonry, wood and stone to metal.
 - .2 Wood to masonry, concrete and stone.
 - .3 Metal to metal.
 - .4 All dissimilar materials.
 - .5 Where 'sealant' or 'caulking' is indicated on drawings.

- .2 Sealant **Type A:**
 - .1 Interior control joints, except in floors .
 - .2 Door frames and interior side.
 - .3 Protrusions through interior walls and floors, interior side, except where fire rated seals are required.
 - .4 Seal thresholds.

- .3 Sealant **Type B:**
 - .1 Control joints in vertical tiled areas.
 - .2 Between vanity and tile.
 - .3 Between vanity and mechanical fixtures/ittings.
 - .4 Between access panels and tile.
 - .5 Between tiles and adjacent materials.

- .4 Sealant **Type C:**
 - .1 Perimeter of kitchen counters.
 - .2 Perimeter of interior windows.
 - .3 Perimeter of firehose cabinets
 - .4 Junction between drywall and masonry.

END OF SECTION

1 General

1.1 **SECTION INCLUDES**

.1 Labour, Products, equipment and services necessary for metal door and frame work in accordance with the Contract Documents.

1.2 **REFERENCES**

.1 ASTM A653/A653M, Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvanealed) by the Hot-Dip Process.

.2 ASTM A924/A924M, Standard Specification for General Requirements for Steel Sheet, Metallic-Coated by the Hot-Dip Process.

.3 CAN4/ULC-S104M, Standard Method for Fire Test of Door Assemblies.

.4 CAN4/ULC-S105M, Standard Specification for Fire Door Frames, Meeting the Performance Required by CAN4/ULC-S104M.

.5 CAN/CGSB-1.198, Cementitious Primer, (for Galvanized Surfaces).

.6 CGSB 41-GP-19Ma, Rigid Vinyl Extrusions for Windows and Doors.

.7 CAN/ULC-S702, Thermal Insulation, Mineral Fibre for Buildings.

.8 CSA W47.1, Certification of Companies for Fusion Welding of Steel Structures.

.9 CSA W59-M, Welded Steel Construction (Metal Arc Welding).

.10 CSDMA, Canadian Steel Door Manufacturers Association.

1.3 **SUBMITTALS**

.1 Product data: Submit manufacturer's Product data in accordance with Section 01 00 00 indicating door and frame construction.

.2 Shop drawings:

.1 Submit shop drawings in accordance with Section 01 00 00 for each type of door and frame indicating:

.1 Thickness and type of steel.

.2 Thickness and type of core.

.3 Thickness and type of steel stiffeners and location of them within the door.

.4 Thickness and type of metal facing on edges of door and method of fastening.

.5 Location of mortises, reinforcement, anchorages, joining, welding, sleeving, exposed fasteners, openings and arrangement for hardware.

- .2 Include schedule identifying each unit with door marks and numbers relating to numbering on Contract Drawings and in door schedule. Indicate doors and frames to be fire rated.

1.4 **QUALITY ASSURANCE**

- .1 Perform work in accordance with requirements of the Canadian Steel Door Manufacturer's Association (CSDMA).

2 Products

2.1 **ACCEPTABLE MANUFACTURERS**

- .1 Daybar Industries Limited
- .2 Fleming Doors Products.
- .3 Steelcraft.
- .4 Vision Hollow Metal Limited.

2.2 **MATERIALS**

- .1 General: All materials under work of this Section, including but not limited to, primers are to have low VOC content limits.
- .2 Steel: ASTM A924/A924M, Class 1; Commercial grade steel, hot dip galvanized to ASTM A653/A653M, ZF120 galvanized coating.
- .3 Minimum base steel thickness:

.1	Frames	1.6 mm
.2	Typical doors	1.6 mm
.3	Interior stiffeners	0.9 mm
.4	Lock/strike reinforcements	1.6 mm
.5	Hinge reinforcements	2.7 mm
.6	All other reinforcement	1.6 mm
.7	Top and bottom channels	1.2 mm
.8	Glazing stops	0.9 mm
.9	Guard boxes	0.9 mm
.10	Jamb spreaders	0.9 mm
- .4 Top caps and thermal breaks: CGSB 41-GP-19Ma; Rigid PVC extrusions.
- .5 Primer: CAN/CGSB 1.198.
- .6 Core material: Mineral fibre insulation with a minimum face density of 24 kg/m³ (1.5 lbs/ft³).

- .7 Screws: Stainless steel screws with countersunk flat head.
- .8 Door silencers: Type 6-180, black neoprene.
- .9 Frame anchors:
 - .1 Frames in masonry: 1.2 mm minimum, adjustable T-strap jamb anchors.
 - .2 Frames in steel stud partitions: 0.9 mm minimum steel anchors of suitable design securely welded inside each jamb.
 - .3 Labeled frames: In accordance with ULC requirements.
- .10 Floor anchors: 1.6 mm minimum adjustable floor clip angles with 2 holes for anchorage to floor.
- .11 Labels for fire doors and door frame: Brass plate, riveted to door and door frame.
- .12 Grilles: Corrosion resistant steel with baked enamel finish. Model 61DG Series by Nailor Industries Inc or approved alternative by Hart and Cooley.
- .13 Glass and glazing: In accordance with Section 08 80 00.

2.3 FABRICATION

- .1 General
 - .1 Fabricate doors and frames in accordance with reviewed shop drawings.
 - .2 Welding: CSA W59-M to produce a finished unit with no visible seams or joints, square, true and free of distortion.
 - .3 Welding: Continuous unless specified otherwise. Execute welding by a firm fully acceptable to the Canadian Welding Bureau to requirements of CSA W47.1.
 - .4 Form profiles accurately to details shown on Contract Drawings.
 - .5 Ream and remove burrs from drilled and punched holes.
 - .6 Grind welded corners and joints to a flat plane and fill with metallic filler and sand to a uniform smooth finish. Apply one coat of primer.
- .2 Frames, windows, and screens:
 - .1 Fabricate frames of welded construction. Cut mitres and joints accurately and weld continuously on inside of frame profile.
 - .2 Construct large frame sections with provision for on Site assembly to suit Site conditions.
 - .3 Blank, reinforce, drill and tap frames for mortised, templated hardware. Protect mortised cut-outs with guard boxes.
 - .4 Reinforce frames where required for surface mounted hardware.
 - .5 Reinforce frames over 1200 mm wide with roll formed steel channels or hollow structural sections specified in Section 05 50 00 and as indicated on drawings.
 - .6 Prepare each door opening for single stud rubber door silencers, 3 for single door openings located in strike jamb, and 2 for double door openings located in head.

- .7 Install 2 channel or angle spreaders per frame, to ensure correct frame alignment. Install stiffener plates or spreaders between frame trim where required, to prevent bending of trim and to maintain alignment when setting in place.
- .8 Form channel glazing stops minimum 16 mm height, accurately cut, mitred, fitted and fastened to frame sections with stainless steel counter-sunk, flat head screws spaced at maximum 450 mm throughout and 50 mm from each end.
- .9 Provide the following requirements for electrified frame applications:
 - .1 Low voltage wire conduit for required electrified hardware devices.
 - .2 Junction boxes for all frame mounted electrified hardware devices, complete with required connectors to in frame low voltage wire conduit.
- .3 Anchorage:
 - .1 Anchor units to floor and wall construction. Locate each wall anchor immediately above or below each hinge reinforcement on hinge jamb and directly opposite on strike jamb, minimum number of anchors for each jamb:
 - .1 Frames up to 2285 mm 3 anchors.
 - .2 Frames from 2285 mm to 2440 mm 4 anchors.
 - .2 Where frames are to be set in masonry or concrete, supply adjustable anchors to trade installing frame.
 - .3 Fabricate frames for installation in steel stud partitions with steel anchors of suitable design, minimum number of anchors for each jamb :
 - .1 Frames up to 2285 mm height 4 anchors.
 - .2 Frames 2285 mm to 2440 mm 5 anchors.
- .4 General Door Requirements:
 - .1 Hollow steel construction, flush swing type, of sizes to conform to details, schedules and reviewed shop drawings with provisions for cut-outs for glass and grilles and reinforced to receive hardware fastenings.
 - .2 Blank, reinforce, drill and tap doors for mortised, templated hardware. Where required, reinforce doors for surface mounted hardware and door closers.
 - .3 Reinforce oversized doors with steel channels and plates specified in Section 05 50 00 and as indicated on drawings.
 - .4 Where openings are required, form integral cut-outs with framing, glass stop moldings and division bars.
 - .5 Install grilles to fit tight and secure into openings.
 - .6 Bevel both stiles of single doors 1 in 16.
 - .7 Reinforce doors with galvanized metal stiffeners at 150 mm o.c.
 - .8 Provide the following requirements for electrified door applications:
 - .1 In door low voltage wire raceways.
 - .2 Steel astragals for hollow metal doors.
 - .3 Reinforcement for all door mounted electrified hardware devices as required and as indicated on Contract Drawings.
- .5 Doors:
 - .1 Supply and install inverted, recessed, fully welded channels at top and bottom of doors.

- .2 Fabricate doors with joints between front and back panels meeting on stile edges. Make joints continuously welded for entire height of door. After welding has been completed, grind joints smooth to match metal. Ensure that no filler is used in joints.
- .3 Fill hollow space within door and vertical stiffeners from top to bottom with mineral fibre batt insulation.

3 Execution

3.1 **EXAMINATION**

- .1 Verify condition and dimensions of previously installed Work upon which this Section depends. Report defects to Consultant. Commencement of work of this Section means acceptance of existing conditions.

3.2 **HOLLOW METAL DOOR, FRAME, WINDOW AND SCREEN INSTALLATION**

- .1 Install hollow metal doors, frames, windows, and screens in accordance with reviewed shop drawings, manufacturer's written instructions and to meet CSDMA requirements.
- .2 Install hollow metal doors, frames, windows, and screens plumb, square, level, secure, and at correct elevation.
- .3 Install doors clear of floor finishes, and with the correct rebate opening for the door installation. Install door silencers.
- .4 Secure anchorages and connections to adjacent construction. Brace frames rigidly in position while building-in. Remove temporary steel shipping jamb spreaders. Install wood spreaders at third points of frame rebate height to maintain frame width. Supply and install vertical supports as indicated on drawings for openings over 1200 mm in width. Remove wood spreaders after frames have been built-in.
- .5 Allow for structural deflection and prevent structural loads from being transmitted to hollow metal frames.
- .6 Touch-up areas where galvanized coating has been removed or damaged with primer.

3.3 **ADJUSTING AND CLEANING**

- .1 Adjust doors for smooth and balanced door movement.
- .2 Clean doors, frames, windows and screens.

END OF SECTION

-
- 1 General
- 1.1 **SECTION INCLUDES**
- .1 Labour, Products, equipment and services necessary for finish hardware work in accordance with the Contract Documents.
- 1.2 **REFERENCES**
- .1 BHMA, Builders Hardware Manufacturing Association.
- .2 NFPA 80, Standard for Fire Doors and Other Opening Protectives.
- 1.3 **SUBMITTALS**
- .1 Product data: Submit manufacturer's Product data in accordance with Section 01 00 00 indicating compliance with reference standards, transportation, storage, handling and installation requirements.
- .2 Shop Drawings:
- .1 Submit Shop Drawings and 3 complete hardware lists in accordance with Section 01 00 00 indicating:
- .1 Door locations, sizes, hardware manufacturer's catalogue numbers, finish symbols and quantities required.
- .2 Locations and mounting heights of each type of hardware.
- .2 Supply templates and required information to door and frame manufacturer to enable accurate sizes, locations of cut-outs and reinforcement for hardware.
- .3 Submit templates to required trade to arrange for provisions for accurate setting and fitting of hardware.
- .3 Samples:
- .1 Submit 2 samples in accordance with Section 01 00 00 of each item that is different from hardware specified and include manufacturer's parts lists and installation instructions.
- .2 Submit hardware component samples illustrating style, colour and finish. Tag samples identifying applicable Specification article number, brand name and number, finish, building location, date and catalogue number.
- .3 Do not order hardware until samples have been accepted. Submit new samples to replace rejected samples. Supply hardware and finishes identical to each accepted sample.
- .4 Closeout submittals:
- .1 Submit the following in accordance with Section 01 00 00 for each Product for incorporation into Operation and Maintenance Manual:
- .1 Maintenance data.
- .2 Operating instructions and safety precautions.
- .3 Parts list with name and address of supplier.
- .4 Lubrication schedule and type of lubricant recommended.
- .5 Keys, tools and special devices.

- .6 Inspection procedures related to preventive maintenance.

1.4 **QUALITY ASSURANCE**

.1 General:

- .1 Manufacturers: Companies specializing in manufacturing door hardware and registered with BHMA.
- .2 Hardware supplier: Company specializing in supplying commercial door hardware and acceptable to manufacturer.

.2 Certifications:

- .1 Employ an Architectural Hardware Consultant to prepare hardware schedule and inspect completed installation and certify that hardware has been installed in accordance with manufacturer's printed instructions, Authorities having Jurisdiction and as specified.
- .2 Submit manufacturer's certificate that finish hardware and fire rated hardware meets specified requirements.

1.5 **DELIVERY, STORAGE, AND HANDLING**

- .1 Be responsible for packaging of hardware, on a set by set basis. As material is received from various manufacturers identify it to correspond to Hardware List symbols.
- .2 Label packages legibly, indicating manufacturer's number, types, sizes, opening number and Hardware List reference number. Wrap hardware and include in package, screws, bolts and fastening necessary for correct installation. If hardware package is not complete, pay additional charges incurred by installer.
- .3 Deliver hardware to Site packaged, labelled and cross-referenced to hardware list for each item and its scheduled installation location.
- .4 Accept Products of this Section on Site and ensure that each item is undamaged.
- .5 Catalogue and store hardware in secure area.

2 Products

2.1 **GENERAL**

- .1 Carefully check and verify Hardware List against Contract Drawings to ensure that hardware listed can be used as specified. Inform Consultant of concerns regarding quality, quantity, operation or function of hardware selected:
 - .1 Verify hand of doors, examine details on Contract Drawings and at Site to ensure hardware supplied can be correctly installed and is correct for work as constructed.
 - .2 Select hardware in accordance with applicable codes and regulations and to approval of local Fire Marshal.

- .3 Replace and pay for defective hardware including hardware which was incorrectly selected, and remedial and installation costs.
- .2 Ensure that hardware selected will function correctly, meets Contract requirements and Ontario Building Code and authorities having jurisdiction.
- .3 Ensure that each hardware item is of same type, design and by same manufacturer.
- .4 Manufacturer's names or trade marks are not permitted on exposed surfaces of hardware.
- .5 Include in packing slip a list of parts, name of supplier and door number in which lock is to be installed.
- .6 Hardware for fire rated and labelled door and frame assemblies: ULC listed or as accepted by authorities having jurisdiction.
- .7 Fire rated assemblies:
 - .1 Hardware: Selected and installed in accordance with applicable codes and regulations, NFPA-80 and to approval of Ontario Fire Marshal.
 - .2 Fire rated doors: ULC labelled hardware. Submit written certification of conformance to ULC requirements for each type of hardware prior to delivery.
 - .3 Locksets and latchsets on fire rated doors: 19 mm throw minimum.

2.2 ACCESSORIES

- .1 Items to be attached to masonry or concrete with expandable shields, lag screws, bolts or other fastening devices as required. Exposed screws: Stainless steel, Phillips or Robertson heads.

2.3 FINISHES

- .1 Metal finishes: Free from defects, clean, unstained and of a uniform colour for each type of finish required. Exposed surfaces and anchors: Specified finish symbol of item.

3 Execution

3.1 EXAMINATION

- .1 Verify condition and dimensions of previously installed Work upon which this Section depends. Report defects to Consultant. Commencement of work of this Section means acceptance of existing conditions.

3.2 INSTALLATION

- .1 Install hardware in accordance with reviewed Shop Drawings, manufacturer's installation instructions, and applicable Codes and regulations.

- .2 Install hardware in accordance with hardware templates.
- .3 Adjust fixed and operable hardware for correct clearances and function.
- .4 Mount hardware measured from finished floor to centre of hardware, unless indicated otherwise or required by Code:
 - .1 Top hinge: 250 mm from head of door to top.
 - .2 Bottom hinge: 265 mm from finished floor to bottom of hinge.
 - .3 Intermediate hinge: Equal distance between top and bottom hinge.
 - .4 Locksets, latchsets: 1000 mm.
 - .5 Panic device crossbar: 1000 mm.
 - .6 Push plates: 1100 mm to bottom of plates.
 - .7 Guard bars: 1100 mm.
 - .8 Door pulls: 1100 mm to bottom of pulls.
 - .9 Blank strike: 1450 mm.
 - .10 Blank fronts: 1450 mm.
- .5 Include for supply and installation of wiring for electric strikes from electrical junction box to electric strike hardware.
- .6 Locate door stops to contact doors 75 mm from latch edge.
- .7 Install hardware and trim square and plumb to doors.
- .8 Replace wrappings for hardware provided by manufacturer after installation.
- .9 Safeguard keys to keep them out of unauthorized hands, tag them with door number, and deliver them to person designated by Consultant at building completion.

3.3 FIELD QUALITY CONTROL

- .1 Have hardware inspected after installation by hardware supplier's representative, obtain certification in writing that hardware has been supplied and installed in accordance with Specifications and hardware manufacturer's instructions and is functioning correctly.
- .2 Inspect fire rated openings to ensure they are installed in compliance with NFPA 80 requirements and Authorities having Jurisdiction.
- .3 Test access control system and electrified hardware devices for proper operation. Verify electric door release hardware operates properly upon activation of fire alarm system.

3.4 ADJUSTING

- .1 Verify under work of this Section, that installed hardware functions properly.

- .2 Adjust hardware so that latches and locks operate smoothly and without binding, and closers act positively with the least possible resistance in use. Lubricate hardware if required by manufacturer's instructions.
- .3 Adjust doors with self closing devices or automatic closing devices for proper operation after the HVAC system is balanced and adjusted. Verify spring power of non sized door closers is properly adjusted.

3.5 **CLEANING**

- .1 Remove wrappings at completion of the Project and clean hardware in accordance with manufacturer's instructions.

3.6 **HARDWARE GROUPS/SCHEDULE**

- .1 Hardware groups/schedule for new doors.

HARDWARE GROUP NO. 01

For use on Door #(s):
D482

Provide each SGL door(s) with the following:

QTY		DESCRIPTION	CATALOG NUMBER	FINISH	MFR
3	EA	HINGE	5BB1 4.5 X 4 NRP	630	IVE
1	EA	ELEC CLASSROOM LOCK	CO-100-CY-70-KP-RHO-LD 4B BATTERY OPERATED	626	SCE
1	EA	PERMANENT CYLINDER	BY OWNER		
1	EA	SURFACE CLOSER W/ HOLD-OPEN	4040XP-3049	689	LCN
1	EA	ARMOR PLATE	8400 36" X 1 1/2" LDW B-CS	630	IVE
1	EA	WALL STOP	WS406/407CVX	626	IVE

END OF SECTION

1 General

1.1 **SECTION INCLUDES**

.1 Design, labour, Products, equipment and services necessary for gypsum board work.

1.2 **REFERENCES**

.1 ASTM A653/A653M, Specification for Steel Sheet, Zinc-coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvanealed) by the Hot-Dip Process.

.2 ASTM C475, Specification for Joint Compound and Joint Tape for Finishing Gypsum Board.

.3 ASTM C645, Specification for Nonstructural Steel Framing Members.

.4 ASTM C754, Specification for Steel Framing Members to Receive Screw-Attached Gypsum Board.

.5 ASTM C834, Standard Specification for Latex Sealants.

.6 ASTM C840, Specification for Application and Finishing of Gypsum Board.

.7 ASTM C1002, Specification for Steel Self-Piercing Tapping Screws for the Application of Gypsum Panel Products or Metal Plaster Bases to Wood Studs or Steel Studs.

.8 ASTM C1178, Specification for Glass Mat Water-Resistant Gypsum Backing Board.

.9 ASTM C1278, Specification for Fiber-Reinforced Gypsum Panel.

.10 ASTM C1396, Specification for Gypsum Board.

.11 ASTM E84, Standard Test Method for Surface Burning Characteristics of Building Materials.

1.3 **DESIGN REQUIREMENTS**

.1 Design gypsum board wall and ceiling systems with a maximum deflection of $l/360$.

.2 Design ceiling suspension system in accordance with manufacturer's printed directions and ASTM C754.

.3 Design ceiling system for adequate support of electrical fixtures as required by the current bulletin of the Electrical Safety Authority.

.4 Design hanger anchor and entire suspension system static loading not to exceed 25% of their ultimate capacity including lighting fixture dead loads.

- .5 Design suspension system to support weight of mechanical and electrical items such as air handling boots and lighting fixtures, and with adequate support to allow rotation/relocation of light fixtures.
- .6 Design subframing as necessary to accommodate, and to circumvent, conflicts and interferences where ducts or other equipment prevent the regular spacing of hangers.
- .7 Design wall framing system and reinforce as necessary to accommodate and support items attached to and supported by wall framing system.
- .8 Design wall framing system for wall assemblies with a height greater than 3000 mm and those assemblies incorporating non-standard gypsum board assemblies including, but not limited to, abuse resistant gypsum board and large format tile applications, etc.

1.4 REGULATORY REQUIREMENTS

- .1 Provide fire separations and fire protection exactly as specified in test design specification that validates the specified rating. Verify that work specified in other Sections, as a part of the entire assembly, meets applicable validating test design specification.

1.5 SUBMITTALS

- .1 Product data:
 - .1 Submit copies of manufacturer's Product data in accordance with Section 01 00 00 indicating:
 - .1 Performance criteria, compliance with appropriate reference standard, characteristics, and limitations.
 - .2 Product transportation, storage, handling and installation requirements.
 - .2 Shop Drawings:
 - .1 Submit Shop Drawings in accordance with Section 01 00 00 indicating:
 - .1 Wall assemblies, suspension systems, adjacent construction, elevations, sections and details, dimensions, thickness, finishes and relationship to adjacent construction.
 - .2 Framing and blocking for items being supported of wall systems.
 - .3 Fire rated designs.
 - .3 Certifications: Submit written certification stating that suspended ceiling system is designed for adequate support of electrical fixtures as required by the current bulletin of the Electrical Safety Authority.

1.6 QUALITY ASSURANCE

- .1 Qualifications: Execute the work of this Section by skilled, qualified, and experienced workers trained in the installation of the work of this Section.

- .2 Retain a Professional Engineer, licensed in Province of Ontario, with experience in work of comparable complexity and scope, to perform following services as part of work of this Section:
 - .1 Design of wall systems with height greater than 3000 mm and at non-standard gypsum board assemblies including, but not limited to, assemblies incorporating abuse resistant gypsum board and large format tile applications, etc.
 - .2 Design of suspended gypsum board assemblies.
 - .3 Review, stamp, and sign Shop Drawings and design calculations.
 - .4 Conduct shop and on-site inspections, prepare and submit written inspection reports verifying that this part of Work is in accordance with Contract Documents and reviewed Shop Drawings.

1.7 SITE CONDITIONS

- .1 Do not begin work of this Section until:
 - .1 Mechanical and electrical work above the ceiling is complete.
 - .2 Substrate and ambient temperature is above 15°C.
 - .3 Relative humidity is below 80 %.
 - .4 Ventilation is adequate to remove excess moisture.
- .2 Install temporary protection and facilities to maintain Product manufacturer's, and above specification, environmental requirements 24 h before, during, and 24 h after installation.

2 Products

2.1 MATERIALS

- .1 General: All materials under work of this Section, including but not limited to, sealants, adhesives, and primers are to have low VOC content limits.
- .2 Steel framing: ASTM C754; ASTM A653/A653-M, Z275; cold rolled, galvanized steel sheet.
 - .1 Bailey Metal Products Limited
 - .2 Corus Metal Profiles
- .3 Steel studs and track runners: ASTM C645; Galvanized steel studs and runners, 32 mm wide x depth as indicated on Contract Drawings. Formed from galvanized steel sheet, thicknesses as follows:
 - .1 Studs less than 3000 mm: Minimum 0.53 mm (25 ga.).
 - .2 Studs greater than 3000 mm and non-standard assemblies: Minimum 0.91 mm (20 ga.), unless stud thickness of greater thickness is required to accommodate intended loading, spans, or conditions.
 - .3 Track runners and ancillary components to match stud thickness.
- .4 Main carrying channels: ASTM C645; Formed from galvanized steel sheet, 38 x 19 mm cold rolled, channels.

-
- .5 Resilient channel: ASTM C645; 0.5 mm thick galvanized metal, 57 mm wide x 12 mm deep for walls and ceiling to reduce sound transmission.
 - .6 Furring channels: ASTM C645; Formed from galvanized steel sheet, 22 mm winged flange type, cold rolled.
 - .7 Furring channels (hat type): ASTM C645; 0.5 mm base steel thickness, galvanized. 70 mm wide x 22 mm deep hat shaped channel.
 - .8 Heavy duty furring channels: ASTM C645; 0.9 mm steel thickness, galvanized hat shaped channel with a wider and deeper size as required by manufacturers.
 - .9 Hanger wires: 4.1 mm minimum diameter galvanized pencil rod.
 - .10 Tie wire: 1.6 mm thick minimum diameter, soft annealed, galvanized steel wire.
 - .11 Corner bead, casing bead, and special shapes: Formed from 0.6 mm thick minimum, galvanized steel sheet, designed to be concealed by joint compound.
 - .12 Deflection track: ASTM C 645 top runner with 50.8-mm- deep flanges, in thickness indicated for studs and in width to accommodate depth of studs.
 - .13 Deflection track (fire rated): Provide 25 mm deep leg deflection track where indicated on rated walls. 'Fire Trak Shadowline' by Fire Trak Corporation or approved alternative.
 - .14 Ceiling clips: Hot dip galvanized partition attachment clips, in square and reveal edge; 'PAC 15 Series' to match grid system by CGC Inc. or approved alternative.
 - .15 Gaskets (acoustic partitions): Adhesive-backed, closed-cell vinyl foam strips that allow fastener penetration without foam displacement, 3.2 mm thick, in width to suit steel stud size.
 - .16 Control joint strip: Roll formed from galvanized steel sheet, with a tape protected recess, 6 mm wide x 11 mm deep.
 - .17 Screw fasteners: ASTM C1002 Type S; Corrosion resistant.
 - .18 Concrete anchors: tie wire sleeve anchors, 'Redi-Drive Anchors' by ITW Red Head or approved alternative.
 19. Batt insulation:
 - .1 Batt insulation (non-rated): CAN/ULC-S702, Type 1, friction fit; 'Unfaced Thermal and Sound Control Batts' by Johns Manville, 'EcoTouch Pink Fiberglas Insulation' by Owens Corning Canada or 'ComfortBatt' by Rockwool.

- .2 Batt insulation (fire-rated/acoustic): ASTM C665, Paperless, semi-rigid, spun stone wool fibre mats, of thickness as indicated on Contract Drawings, 'MinWool SAFB' by Johns Manville, 'SAFB Thermafiber' by Owens Corning Inc. or 'Rockwool AFB' by Rockwool.
- .20 Sealants:
 - .1 Acoustic sealant (non-rated): Non-hardening acoustic sealant for use at non-rated assemblies, ASTM C834; Lightweight, acrylic, mould resistant sealant, paintable. 'Lightweight Smoke and Acoustic Sealant CS-S SA Light' by Hilti or approved alternative.
 - .2 Fire-rated sealant: Non-hardening sealant for use at fire-rated assemblies: ASTM E84; Acrylic based firestop sealant, colour: red or white as selected by Consultant. 'Flexible Firestop Sealant CP606' by Hilti or approved alternative.
 - .3 Fire-rated seal: Non-hardening seal for use at fire-rated assemblies: ASTM E84; Flexible seal for installation between top track and substrate. 'Firestop Top Track Seal CFS-TTS' by Hilti or approved alternative.
 - .4 Standard sealants: In accordance with Section 07 92 00.
- .21 Fire rated gypsum board: ASTM C1396; gypsum board 15.9 mm thick of maximum practical lengths to minimize end joints, unless indicated otherwise. Furnish Type X Board by Certainteed Gypsum Canada, CGC Inc., or Georgia-Pacific Canada LP.
- .22 Moisture, mould, and abuse resistant panels: 12.7 mm thick unless indicated otherwise on drawings; 'AirRenew Extreme Impact Resistant with M2Tech' by Certainteed Gypsum Canada, 'Sheetrock Mold Tough AR' by CGC Inc. or 'DensArmor Plus Abuse-Resistant Interior Panel' by Georgia-Pacific Canada LP.
- .23 Tile Backer: Water resistant tile backer board meeting ASTM C1178 or ASTM C1278, thickness as indicated. 'Diamondback Tile Backer' by Certainteed Gypsum Canada, 'Fiberock Aqua-Tough Underlayment' by CGC Inc. or 'Dens Shield' by Georgia-Pacific Canada LP.
- .24 Special trim pieces: to include, but not limited to, the following:
 - .1 F reveal: Formed from extruded aluminum alloy 6063 T5. 'FDM-625-75' manufactured by Fry Reglet, Gordon Trims, or approved alternative.
 - .2 L trim: Formed from extruded aluminum alloy 6063 T5. Manufactured by Fry Reglet, Gordon Trims, or approved alternative.
 - .3 J moulding: Formed from extruded aluminum alloy 6063 T5. '1054' manufactured by Fry Reglet, Gordon Trims, or approved alternative.
 - .4 End closure: Formed from extruded aluminum alloy 6063 T5. 'DMEC-200' manufactured by Fry Reglet, Gordon Trims, or approved alternative.
- .25 Primer: Where indicated by board manufacturer, provide primer as required to achieve finishes as defined in ASTM C840.
- .26 Joint reinforcing tape:
 - .1 Standard gypsum board: ASTM C475; 50 mm wide x 0.25 mm thick, perforated paper, with chamfered edges.

- .2 Moisture resistant and tile backer boards: ASTM C475; fibreglass mat joint tape as recommended by board manufacturer to suit location.
- .27 Joint and patching compound: ASTM C475; Asbestos-free, supplied by manufacturer of gypsum board used.
- .28 Fast setting patching compound: ASTM C475; Asbestos-free, Sheetrock or Durabond by CGC Inc., 'Moisture and Mold Resistant Setting Compound with M2Tech' by Certainteed Gypsum Canada or approved alternative.
- .29 Access doors: Supplied by other Sections for installation as part of the work of this Section.

3 Execution

3.1 **EXAMINATION**

- .1 Verify condition and dimensions of previously installed Work upon which this Section depends. Report defects to Consultant. Commencement of work of this Section means acceptance of existing conditions.

3.2 **SUSPENSION FRAMING**

- .1 Install ceiling systems in accordance with reviewed Shop Drawings and manufacturer's written instructions.
- .2 Install hanger wires plumb and securely anchored to the building structural framing, independent of walls, pipes, ducts, and metal deck; install additional framing and hangers to bridge interference items.
- .3 Install hanger wires at 1200 mm maximum centres along carrying channels, not less than 25 mm, and not more than 150 mm from channel ends.
- .4 Install additional hangers at lighting fixture and ductwork locations. Do not attach hanger wires to mechanical or electrical equipment. Do not support mechanical and electrical fixtures and fitting on ceiling without the ceiling manufacturer's written acceptance.
- .5 Install main carrying channels transverse to structural framing members. Lap main carrying channels 200 mm minimum at splices and wire each end with two loops and prevent clustering or lining-up of splices.
- .6 Install furring channels at 400 mm o.c., not less than 25 mm, and not more than 150 mm from perimeter walls, at openings, at interruptions in ceiling continuity, and at change in plane. Install furring channels to a tolerance of 3 mm maximum in 3600 mm.

- .7 Install additional main carrying and furring channels to frame and to reinforce openings such as recessed lighting fixtures, access hatches, ceiling grilles, outlet boxes, ventilating outlets and similar items.

3.3 STEEL STUDS AND FURRING

- .1 Install steel studs and furring in accordance with reviewed Shop Drawings and manufacturer's written instructions.
- .2 Install steel stud partitions to underside of structure unless indicated otherwise.
- .3 Install track runners at floors, ceilings, and underside of structure; align track runners accurately and secure to structure at 600 mm centres maximum.
- .4 Install double top track runner assembly to prevent the transmission of structural loads to steel studs.
- .5 Install steel studs vertically at 400 mm o.c., unless otherwise indicated, and not more than 50 mm from abutting walls, at openings, and at each side of corners. Install studs securely to track runners.
- .6 Schedule and coordinate steel framing installation with mechanical and electrical services installation.
- .7 Install full height, double studs at door and service openings, fastened together and stiffened back to the structure to prevent vibration when doors close.
- .8 Provide double studs boxed together at all openings, sill, head and jambs and at door jambs, fastened together and stiffened back to the structure to prevent vibration. At each opening exceeding 900 mm in width, double studs shall be 20 ga. extending to structure above, and adequately anchored at each end. Provide steel studs above and below openings spaced at 400 mm oc maximum. All metal stud partitions above doors and screens over 1220 mm wide shall be secured to structure over and reinforced with sway bracing to stabilize walls to prevent lateral movement.
- .9 Erect three studs at corner and intermediate intersections of partitions. Space 50 mm apart and brace together with wired 19 mm channels.
- .10 Stiffen partitions over 2440 mm high or 3000 mm long, or both, with horizontal bracing extended for full length of partitions. Provide one line of bracing in partitions. Space lines to provide equal unbraced panels. Provide bracing for portions of partitions over door openings in partitions over 3000 mm high, and bracing both above and below openings in partitions located no greater than 150 mm from top and bottom of opening, and extending two stud spaces beyond each edge of opening for both doors and windows. Wire tie or weld bracing to studs.

- .11 Frame control joints using back to back double studs at abutting structural elements, at dissimilar backup interface, at dissimilar walls and ceilings, at structural expansion and control joints, at door and other openings, and at 9000 mm maximum spacing in continuous runs. Install control joint strips and secure in place.
- .12 Install additional support framing at openings and cutouts for built-in equipment, upper cabinet support, access panels and similar items.
- .13 Attach to framing adequate steel reinforcing members or an 1.2 mm (18 ga.) steel stud mounted horizontally and notched around furring members to support the load of, and to withstand the withdrawal and shear forces imposed by, items installed upon the work of this Section. Such items include, but are not restricted to, miscellaneous metals, coat hooks, washroom accessories, wall-hung cabinets and fitments, shelving, curtain tracks, miscellaneous specialties; Owner supplied equipment; and minor mechanical and electrical work. Heavy mechanical and electrical equipment shall be self-supporting in Divisions 21, 22, 23 and 26.
- .14 Provide for support and incorporation of flush-mounted and recessed mechanical and electrical equipment and fixtures only after consultation and verification of methods with those performing the work of Divisions 21, 22, 23 and 26.
- .15 Install cross bracing in accordance with the steel stud manufacturer's recommendations.

3.4 **FIRE RATED ASSEMBLIES**

- .1 Install Products in fire rated assemblies in strict accordance with reviewed Shop Drawings and applicable tested and approved designs required by Authorities Having Jurisdiction.
- .2 Install firestop fill material behind fire rated acoustical sealant and provide firestop identification tag.
- .3 Stiffen fire rated walls over 3.66 m high, where linear length of wall is greater than 2.44 m between perpendicular wall supports, with diagonal bracing above the ceiling extending perpendicular to wall at a 45° angle to structure above. Locate diagonal bracing at maximum 2.44 m o.c.
- .4 Where double layers of gypsum board are shown, and required for fire rating, screw first layer to studs and furring and laminate the second layer to the first using joint filler as an adhesive. Stagger joints between first and second layers.

3.5 **BATT INSULATION**

- .1 Install batt insulation in partitions, between studs, and as indicated on Contract Drawings and in accordance with the manufacturer's instructions.
- .2 Fill stud cavities to full height of partitions and carefully cut and fit required batt insulation type around services and protrusions.

3.6 **ACOUSTICAL SEALANT**

- .1 Install acoustical sealant to acoustically insulated partitions in accordance with the manufacturer's instructions and Contract Drawings.
- .2 Install acoustical sealant under floor runner track, at partition perimeter both sides and at openings, cut-outs, and penetrations, concealed from view in the final installation.
- .3 Smooth acoustical sealant with trowel prior to skin forming.

3.7 **GYPSUM BOARD**

- .1 Comply with ASTM C840. Install gypsum board in accordance with reviewed Shop Drawings and manufacturer's written instructions.
- .2 Install gypsum board vertically or horizontally, whichever results in fewer end joints. Locate end joints over supporting members.
- .3 Install gypsum board in lightly butted contact at edges and ends and with 1.6 mm maximum open space between boards; do not force gypsum board into place. Do not install imperfect, damaged or damp boards.
- .4 Install gypsum board butting paired tapered edge joints, and mill-cut or field-cut end joints; do not place tapered edges against cut edges or ends.
- .5 Install vertical joints minimum 300 mm from the jamb lines of openings and stagger vertical joints over different studs on opposite sides of partitions.
- .6 Do not locate joints within 200 mm of corners or openings, except where control joints occur at jamb lines or where openings occur adjacent to corners. Where necessary, place a single vertical joint over the centre of wide openings.
- .7 Cut, drill and patch gypsum board as may be necessary to accommodate the work of other trades.
8. Fire Separations:
 - .1 Construct gypsum board assemblies, where located, in accordance with tested assemblies to obtain required or indicated fire rated assemblies. As a minimum fire separations shall consist of metal framing covered on both sides by fire-rated gypsum board.
 - .2 Install assemblies tightly to enclosing constructions to maintain integrity of the separations. Install casing beads at all perimeter edges.

3.8 CORNER, CASING BEADS AND TRIM

- .1 Corner reinforcing bead: Install along all external angles, erect plumb, level and with a minimum of joints. Secure with screws at 225 mm o.c. apply filler over flanges flush with nose of the bead and extending at least 75 mm onto surface of board each side of corner. When filler dries, apply a thin coat of topping cement and blend onto adjoining surfaces.
- .2 Casing bead: Install where wallboard butts against a surface having no trim concealing the juncture and where shown on drawings. Erect casing beads plumb or level, with minimum joints, and secure with screws at 300 mm o.c. apply filler over flange flush with bead and extending at least 75 mm onto surface of board. When dry, apply a thin coat of topping cement and blend onto adjoining surfaces.
- .3 Recess channels and trim: Install recess channels and special metal trim where shown. Secure to substrate. Provide casing beads full height on wallboard edges at recess channels and metal trim.

3.9 JOINT TAPING AND FINISHING

- .1 Install reinforcing tape and a minimum of 3 coats of joint compound over gypsum board joints, metal trim and accessories, and screw fasteners in accordance with the gypsum board manufacturer's instructions.
- .2 Fill gaps between ,and any imperfections in, gypsum boards with joint compound, allow to dry, and sand smooth ready for painting.
- .3 Install finished gypsum board work smooth, seamless, plumb, true, flush, and with square, plumb, and neat corners.
- .4 Finish gypsum board in accordance with ASTM C840 to the following grades:
 - .1 Level 0: No taping, finishing, or accessories required. Use above suspended ceilings and within other concealed spaces, unless the assembly is fire rated, sound rated, sound or smoke controlled, or unless the space serves as an air plenum.
 - .2 Level 1: At joints and interior angles embed tape in joint compound. Leave surface free of excess joint compound. Tool marks and ridges are acceptable. Use above suspended ceilings and within other concealed spaces if the gypsum board assembly is fire rated, sound rated, sound or smoke controlled, or the space serves as an air plenum.
 - .3 Level 2: At joints and interior angles embed tape in joint compound with one separate coat of joint compound applied over joints, angles, fastener heads, and accessories. Use for water resistant gypsum board indicated for use as a substrate for ceramic tile.
 - .4 Level 3: At joints and interior angles embed tape in joint compound with two separate coats of joint compound applied over all joints, angles, fastener heads, and accessories. Apply joint compound smooth and free of tool marks and ridges. Use where heavy grade wall coverings are the final decoration.

- .5 Level 4: At joints and interior angles embed tape in joint compound with three separate coats of joint compound applied over all joints, angles, fastener heads, and accessories. Apply joint compound smooth and free of tool marks and ridges. Use for all locations except those indicated for other finish levels.
- .6 Level 5: At joints and interior angles embed tape in joint compound with three separate coats of joint compound applied over all joints, angles, fastener heads, and accessories. Apply a thin skim coat of joint compound, or a material manufactured especially for this purpose, to the entire surface. Leave surface smooth and free of tool marks and ridges. Use where semi-gloss or gloss finish coatings are the final decoration.

3.10 ACCESS DOORS

- .1 Install access doors, supplied as part of other parts of the work, in accordance with manufacturer's written instructions.

3.11 SITE TOLERANCES

- .1 Install metal support systems to ensure that, within a tolerance of +3 mm and -1.5 mm for plaster thickness, finish surfaces will be flat within 3 mm under a 3 m straightedge, and with no variation greater than 1.5 mm in any running 300 mm, and that surface planes shall be within 3 mm of dimensioned location.

3.12 WORK IN EXISTING AREAS

- .1 In existing areas, where existing gypsum board work has been demolished and/or damaged and repair work is required, provide new gypsum board finish.
- .2 Thoroughly prepare areas to be repaired. Provide neat, clean and straight cuts.
- .3 Finish all repair work as specified for new work.
- .4 In existing areas where existing openings are to be filled in with gypsum board, provide new gypsum board wall and ceiling construction. Ensure new board faces are flush with faces of abutting existing walls and ceilings.

3.13 REPAIR

- .1 Make good cut-outs for services and other work, fill in defective joints, holes and other depressions with joint compound.
- .2 Make good defective work, and ensure that surfaces are smooth, evenly textured and within specified tolerances to receive finish treatments.

END OF SECTION

1 General

1.1 **SECTION INCLUDES**

.1 Labour, Products, equipment and services necessary for resilient sheet flooring work in accordance with the Contract Documents.

1.2 **REFERENCES**

.1 ASTM D2047, Standard Test Method for Static Coefficient of Friction of Polish-Coated Floor Surfaces as Measured by the James Machine.

.2 ASTM F710, Standard Practice for Preparing Concrete Floors to Receive Resilient Flooring.

.3 ASTM F970, Standard Test Method for Static Load Limit.

.4 ASTM F1516, Standard Practice for Sealing Seams of Resilient Floor Products by the Heat Weld Method.

.5 ASTM F1869, Standard Test Method for Measuring Moisture Vapor Emission Rate of Concrete Subfloor Using Anhydrous Calcium Chloride.

.6 ASTM F2170, Standard Test Method for Determining Relative Humidity in Concrete Slabs Using in-situ Probes.

.7 CAN/ULC-S102.2-M, Method of Test for Surface Burning Characteristics of Flooring, Floor Coverings, and Miscellaneous Materials and Assemblies.

.8 ISO 717-2., Acoustics - Rating of Sound Insulation in Buildings and of Building Elements - Part 2: Impact Sound Insulation.

1.3 **SUBMITTALS**

.1 Product data:

.1 Submit copies of manufacturer's Product data in accordance with Section 01 00 00 indicating:

.1 Performance criteria, compliance with appropriate reference standard, characteristics, and limitations.

.2 Product transportation, storage, handling and installation requirements.

.2 Shop drawings: Submit shop drawings indicating seam layout and welding procedures in accordance with Section 01 00 00.

.3 Samples:

.1 Submit samples in accordance with Section 01 00 00:

.1 Two 250 x 200 mm samples of each type of sheet material and colour.

.2 Two 250 mm long samples of each accessory and colour.

.4 Extended warranties: Submit extended warranties signed and registered by the manufacturer providing the warranties in the name of the Owner for the timeframe and coverage specified in this Section.

.5 Closeout submittals: Submit maintenance and cleaning data for incorporating into Operations and Maintenance Manuals in accordance with Section 01 00 00.

1.4 **SITE CONDITIONS**

.1 Maintain air temperature and structural base temperature at flooring installation area above 20°C for 48 hr before, during and 48 hr after installation.

.2 Store materials for 2 days prior to installation in area of Work to achieve temperature stability.

.3 Do not lay flooring in conditions of high humidity or where exposed to cold drafts. In hot weather, protect from direct sunlight.

.4 Provide adequate ventilation during installation.

1.5 **EXTENDED WARRANTY**

.1 Manufacturer's warranty: Provide flooring manufacturer's warranty naming Owner as beneficiary, covering excessive wear for a period of 5 years from the date Work is certified as Substantially Performed.

1.6 **MAINTENANCE**

.1 Submit extra 5% or to nearest full roll of each colour, pattern and type of flooring material required for maintenance use. Identify each roll. Store where directed. Submit maintenance material in one piece and of same production run as installed materials.

2 Products

2.1 **MATERIALS**

.1 All materials under work of this Section, including but not limited to, primers and adhesives are to have low VOC content limits.

.2 Sheet vinyl flooring (VS-1):

.1 ASTM F1303; Type 1, Grade 1, Class A, Thickness: 2.5 mm unless indicated otherwise. Homogeneous resilient flooring, made from natural ingredients, with non-woven polyester/cellulose glass fiber reinforcement scrim backing.

.2 Slip resistance: Static coefficient of slip resistance meets or exceeds 0.8 dry and 0.9 wet, when tested in accordance with ASTM D2047.

- .3 Static load limit: 2000 pounds per square inch when tested in accordance with ASTM F970.
- .4 Colour and Finish: Refer to Finish/Material/Product Schedule.
- .5 Acceptable manufacturer: 'Reliance 25' by Altro approved alternative.

- .3 Base (WB-1): ASTM F1861, Type TP, Group 1, rubber wall base, approximately 100 mm high x 3 mm thick, coved profile, in lengths as long as possible including premoulded end stops and inner and outer corners. Colour: As selected by Consultant. 'Mandalay Wall Base' by Tarkett or approved alternative.
- .4 Welding rod: type recommended by flooring manufacturer to complement flooring.
- .5 Cove fillers and top edge caps: As recommended by flooring manufacturer.
- .6 Primers and adhesives: Low VOC, waterproof, of types recommended by flooring manufacturer for specific material on applicable substrate, above, on or below grade.
- .7 Reducing edge strips, thresholds: Nitrile rubber plasticized vinyl, 80-95 Shore A Durometer, adhesive as recommended by manufacturer.
- .8 Concrete skim coat compound: High-performance, rapid-setting cement based skim coating compound. 'Ultra SkimCoat' by Mapei or approved alternative for filling minor voids and leveling existing substrate.
- .9 Stain sealer and polish: Type recommended by flooring manufacturer.

3 Execution

3.1 **EXAMINATION**

- .1 Verify condition and dimensions of previously installed Work upon which this Section depends. Report defects to Consultant. Commencement of work of this Section means acceptance of existing conditions.
- .2 Ensure concrete floors meet the following minimum requirements and requirements of the flooring manufacturer. If there is a conflict between these requirements and those of the flooring manufacturer, the more stringent shall apply.
 - .1 Internal Relative Humidity Test: Perform internal relative humidity testing in accordance with ASTM F2170. Results shall not exceed 80% RH.
 - .2 Moisture Test: Moisture emissions from concrete subfloors (cured for a minimum of 28 days) must not exceed 3 lbs per 1000sf per 24 hours (1.4 kg H₂O/24 hr/93 m²) for acrylic adhesive and 5lbs for polyurethane adhesive via the Calcium Chloride Test Method (ASTM F1869).
 - .3 The pH level of the subfloor surface shall not be higher than 9.9. If higher, subfloor must be neutralized.
- .3 Ensure that sub-floors have been provided as specified without holes, protrusions, cracks, depressions or other major defects.

- .4 Ensure that control joints have been filled and levelled.
- .5 Defective work resulting from application to unsatisfactory surfaces will be considered the responsibility of those performing the work of this Section.

3.2 SUBFLOOR TREATMENT

- .1 Flooring shall be installed over subfloors conforming to ASTM F710 for concrete.
- .2 Remove sub-floor ridges and bumps. Fill low spots, cracks, joints, holes and other defects with sub-floor filler.
- .3 Apply sub-floor filler to low spots and cracks to achieve floor level to a tolerance of 1:1000, allow to cure.
- .4 Meet ASTM F710 Standard for Concrete or other monolithic floors.
- .5 Clean and remove all deleterious materials from surfaces to receive this work in accordance with the adhesive manufacturer's recommendations.
- .6 Prime concrete to flooring manufacturer's printed instructions.

3.3 RESILIENT SHEET FLOORING APPLICATION

- .1 Install resilient sheet flooring in accordance with manufacturer's written instructions.
- .2 Apply adhesive uniformly using recommended trowel in accordance with flooring manufacturers instructions. Do not spread more adhesive that can be covered by flooring before initial set takes place.
- .3 Run sheets in direction of traffic. Double cut sheet joints and continuously seal according to manufacturer's printed instructions. Remove adhesive seepage of seams or surface while adhesive is still wet.
- .4 Heat weld seams in accordance with ASTM F1516 and manufacturer's printed instructions.
- .5 As installation progresses and after installation, roll flooring with minimum 45 kg roller to ensure full adhesion.
- .6 Cut flooring neatly around fixed objects.
- .7 Terminate flooring at centreline of door in openings where adjacent floor finish or colour is dissimilar.
- .8 Provide 100 mm coved base at room perimeter and at built-in fitment locations complete with cove fillers and top caps as required. Form cove with 25 mm radius.

- .9 Install reducing edge strips at unprotected or exposed edges where flooring terminates or where there are two finishes of different thicknesses.

3.4 **RESILIENT BASE APPLICATION**

- .1 Resilient base: In accordance with Section 09 65 00. Coordinate with noted Section as required for installation of resilient base with resilient sheet flooring.

3.5 **ACCESSORIES AND WHEELED TRANSITION APPLICATION**

- .1 Install accepted adaptors between different flooring materials in accordance with manufacturer's instructions.
- .2 Ensure that adaptors have been clipped into place properly to provide a smooth, gradual transition between floors of different height.
- .3 Install accessories in accordance with manufacturer's written instructions.

3.6 **CLEANING AND SEALING**

- .1 Forty-eight hours after installation, clean sheet flooring surfaces with a mild soap solution approved by finish manufacturer. Rinse clean and allow to dry.
- .2 Apply stain sealer and allow to dry. Apply three to five coats of sealer as recommended by flooring manufacturer and polish thoroughly.

3.7 **PROTECTION OF FINISHED WORK**

- .1 Protect floors and bases from time of final set of adhesive until accepted by Consultant.
- .2 Prohibit traffic on floor for 48 hours after installation.
- .3 Cover cleaned surfaces with fibre reinforced, clean, non-staining clean, kraft paper. Secure in position with gummed tape to prevent drifting. Remove covering when directed by Consultant.

END OF SECTION

- 1 General
- 1.1 **SECTION INCLUDES**
 - .1 Labour, Products, equipment and services necessary for epoxy flooring work in accordance with the Contract Drawings.
- 1.2 **SUBMITTALS**
 - .1 Product data: Submit manufacturer's Product data in accordance with Section 01 00 00 indicating:
 - .1 Two copies of manufacturer's Product data on characteristics, performance criteria, and limitations.
 - .2 Preparation, installation requirements and techniques, Product storage, and handling criteria.
 - .2 Samples: Submit duplicate samples of each type and colour of epoxy flooring mounted on 250 x 200 mm hardboard in accordance with Section 01 00 00.
 - .3 Reports: Submit manufacturer's acceptance of substrate prior to installation in writing. Submit verification of moisture content of floor prior to installation.
 - .4 Close-out submittals: Submit maintenance data for incorporation into Operations and Maintenance manuals in accordance with Section 01 00 00.
- 1.3 **QUALITY ASSURANCE**
 - .1 Perform work of this Section by a company that has a minimum of five years proven experience in installations of a similar size and nature and that is approved by manufacturer. Submit to Consultant, applicator's current certificate of approval by the material manufacturer as proof of compliance.
 - .2 Mock-up:
 - .1 Construct one 3 m² mock-up of each type and colour of epoxy flooring in location acceptable to Consultant.
 - .2 Arrange for Consultant's review and acceptance, allow 48 hours after acceptance before proceeding with work.
 - .3 Mock-up may remain as part of Work if accepted by Consultant. Remove and dispose of mock-ups which do not form part of Work.
 - .4 Upon acceptance, mock-up shall serve as a minimum standard of quality for the balance of the work of this Section.
 - .3 Pre-installation meetings: Arrange with manufacturer's representative and Consultant to inspect substrates, and to review installation procedures 48 hours in advance of installation.

1.4 **SITE CONDITIONS**

- .1 Do not install the work of this Section outside of the following environmental ranges without Product manufacturer's written acceptance:
 - .1 Ambient air and surface temperature: 15°C to 30°C.
 - .2 Relative Humidity: In accordance with manufacturers' requirements.
 - .3 When no dust is being raised.
 - .4 In well-ventilated and broom clean areas.
- .2 Do not apply epoxy flooring over materials that contain over 4% moisture.
- .3 Install temporary protection and facilities to maintain the Product manufacturer's, and the above specification, environmental requirements for 24 hours before, during, and 24 h after installation.
- .4 Post do not enter and appropriate warning signs at conspicuous locations.

1.5 **DELIVERY, STORAGE, AND HANDLING**

- .1 Package, seal and label each epoxy flooring material to show manufacturer's and product name, and colour.
- .2 Store materials at site in an area specifically set aside for purpose that is locked, ventilated, and maintained at a minimum temperature of 16°C.
- .3 Ensure that health and fire regulations are complied with in storage area, and during handling and application.

2 Products

2.1 **MATERIALS**

- .1 General:
 - .1 All materials under work of this Section, including but not limited to, primers and epoxy flooring are to have low VOC content limits.
 - .2 Each material used in the application of each flooring system shall be as recommended or manufactured by the supplier of the flooring system.
- 2. Epoxy flooring and base:
 - .1 Trowelled applied heavy duty epoxy system, seamless, minimum 3 mm thick, broadcast and sealed epoxy floor, composed of multicoloured quartz aggregates finished with transparent top coats. Quartzite HDB system by Sika Canada Inc. Provide base coat of 100% solids, two component, flexible polyurethane membrane 'Sikalastic-390' by Sika Canada Inc. 100% solids, two component, flexible polyurethane membrane 'Sikalastic-390' by Sika Canada Inc. or approved alternative by Master Builders Solutions.

- .3 Primer: As recommended by manufacturer.

- 3 Execution

- 3.1 **EXAMINATION**
 - .1 Verify condition of previously installed Work upon which this Section depends. Report defects to Consultant. Commencement of work of this Section means acceptance of existing conditions.
 - .2 Verify that concrete floor has cured 28 days minimum and that substrate is acceptable to epoxy manufacturer.
 - .3 Test surfaces for moisture content to ensure that they are suitable for application.

- 3.2 **PREPARATION**
 - .1 Prepare substrate using steel aggregate blast method and vacuum substrate free of debris and dust.
 - .2 Fill minor cracks and voids and prime surfaces in accordance with manufacturer's recommendations.
 - .3 Protect adjacent surfaces from damage resulting from this work. Mask and/or cover adjacent surfaces, fixtures, and equipment as necessary.
 - .4 Fill open control joints, and other cracks and voids with material compatible with epoxy materials.
 - .5 Clean prime and seal surfaces as recommended by epoxy manufacturer.

- 3.3 **APPLICATION**
 - .1 Apply epoxy flooring in accordance with manufacturer's printed instructions. Epoxy manufacturer shall supervise application.
 - .2 Stop epoxy in a straight line on each side of control joints; fill space over expansion joint with a self-levelling, non-sag polyurethane sealant.
 - .3 Apply epoxy with care to ensure that no laps, voids, or other marks or irregularities are visible, and with an appearance of uniform colour, sheen and texture, all within limitations of materials and areas concerned.
 - .4 Match colours and textures of approved samples.
 - .5 Make clean true junctions with no visible overlap between adjoining applications of epoxy.

.6 Chase edge of adjacent floor systems so that epoxy finishes flush with adjacent floor systems.

.7 Provide 100 mm coved base with plastic cove strip top cap at room perimeter and at built-in fitment locations. Form cove with 25 mm radius.

3.4 **SITE TOLERANCES**

.1 Finish surfaces shall be level, or straight where sloped to drains, within a tolerance of 1.5 mm in 3 m, and shall not vary more than 0.8 mm in any running 300 mm.

3.5 **REPAIR**

.1 Touch-up and refinish minor defective work. Refinish entire coated surface areas where finish is damaged or otherwise unacceptable.

3.6 **CLEANING**

.1 Remove promptly as work progresses spilled or spattered materials from surfaces of work performed under other Sections. Clean floors on completion of work. Do not mar surfaces while removing.

.2 Leave storage and mixing areas in same condition as equivalent spaces in project.

3.7 **PROTECTION**

.1 Erect barriers to prevent the entry and presence of personnel not performing work of this Section during application of epoxy flooring, and for 48 hours following completion of application.

END OF SECTION

- 1 General
- 1.1 **SECTION INCLUDES**
 - .1 Labour, Products, equipment and services necessary for hygienic wall cladding work in accordance with the Contract Documents.
- 1.2 **SUBMITTALS**
 - .1 Product data:
 - .1 Submit duplicate copies of manufacturer's Product data in accordance with Section 01 00 00 indicating:
 - .1 Performance criteria, characteristics, and limitations.
 - .2 Product transportation, storage, handling and installation requirements.
 - .2 Shop drawings:
 - .1 Submit shop drawings in accordance with Section 01 00 00 indicating:
 - .1 Elevations, sections, details, materials, dimensions, thicknesses, trim and accessory pieces, and interfacing with adjacent construction.
 - .3 Samples:
 - .1 Submit following samples in accordance with Section 01 00 00.
 - .1 Two 300 x 300 mm samples of wall cladding.
 - .2 Two 300 mm samples of each trim and accessory proposed for use.
 - .4 Certificates: Submit certification from material manufacturer that installation is in accordance with manufacturer's instructions.
 - .5 Closeout submittals: Submit maintenance and cleaning instructions for incorporation into Operations and Maintenance Manuals in accordance with Section 01 00 00.
 - 1.3 **QUALITY ASSURANCE**
 - .1 Installers qualifications: Perform work of this Section by a company that has a minimum of three years proven experience in the installation of wall cladding on projects of a similar size and nature and that is approved by manufacturer. Submit to Consultant, installer's current certificate of approval by the cladding manufacturer as proof of compliance.
 - .2 Mock-up:
 - .1 Construct one 2 m² mock-up of wall cladding system in location acceptable to Consultant.
 - .2 Arrange for Consultant's and manufacturer's review and acceptance prior to start of installation.
 - .3 Mock-up may remain as part of Work if accepted by Consultant. Remove and dispose of mock-ups which do not form part of Work.
 - .4 Upon acceptance, mock-up shall serve as a minimum standard of quality for the balance of the work of this Section.

1.4 **SITE CONDITIONS**

- .1 Do not install work of this Section outside of following environmental ranges without Consultant's and Product manufacturer's written acceptance:
 - .1 Ambient air and surface temperature: 15^oC to 30^oC.
 - .2 Relative Humidity: 45%.
- .2 Supply and install temporary protection and facilities to maintain Product manufacturer's, and above specified environmental requirements for 24 hours before, during, and 24 hours after installation.

2 Products

2.1 **MATERIALS**

- .1 All materials under work of this Section, including but not limited to, sealants and adhesives are to have low VOC content limits.
- .2 Wall Protection (WP-#)
 - .1 Extruded rigid PVC sheets, coloured throughout, smooth finish, Agriculture and Agri-Food Canada Approved, 2440 mm x 1220 mm x 2.5 mm thick. 'Altro Tegulis' by Altro or approved alternative.
 - .2 Wall cladding to come complete with thermoformed corners and all accessories required to provide a complete system.
 - .3 Colour: to be determined by Consultant.
- .3 Adhesive and Sealant: Types as recommended by cladding manufacturer to suit intended application.

3 Execution

3.1 **EXAMINATION**

- .1 Verify condition and dimensions of previously installed Work upon which this Section depends. Report defects to Consultant. Commencement of work of this Section means acceptance of existing conditions.

3.2 **PREPARATION**

- .1 Verify substrate surfaces are solid, free of moisture, dust, oil, grease, scaling or laitance, projections and any other foreign matter detrimental to performance. Obtain manufacturer's approval of substrate in writing, submit copy to Consultant.

3.3 **INSTALLATION**

- .1 Install wall cladding in accordance with reviewed shop drawings and manufacturer's written instructions.

- .2 Dry-fit sheet prior to fixing.
- .3 Bevel leading edges of sheet prior to fitting joint and cap strips.
- .4 Apply adhesive to back of sheet uniformly using a 4.5 mm 'V' notched trowel. Allow adhesive to dry tacky to the touch.
- .5 Offer sheet to wall substrate. Roll sheet thoroughly with a wall roller to ensure full adhesion.
- .6 Cut sheet neatly to accommodate pipes, electrical boxes, etc., providing a 3 mm gap for expansion.
- .7 Fit sheets neatly at door and window trim providing a 3 mm gap for expansion.
- .8 Thermoform all inside and outside corners and specific shapes to fit building contours.
- .9 Install joint strips to each sheet as installation progresses.
- .10 Provide water tight seal to all pipes, projections, door and window trims with sealant.

3.4 **CLEANING**

- .1 Upon completion of installation, remove the protective film and wash with a dilute soap/detergent solution and rinse with clean water.

END OF SECTION

-
- 1 General
- 1.1 **SECTION INCLUDES**
- .1 Labour, Products, equipment and services necessary for painting work in accordance with the Contract Documents.
- 1.2 **REFERENCES**
- .1 Master Painters Institute (MPI), Painting Specification Manual.
- .2 SSPC Steel Structures Painting Council, Standards.
- 1.3 **SUBMITTALS**
- .1 Product data:
- .1 Submit copies of manufacturer's Product data in accordance with Section 01 00 00 indicating:
- .1 Performance criteria, compliance with appropriate reference standard, characteristics, limitations.
- .2 Product transportation, storage, handling and installation requirements.
- .2 Submit listing of manufacturer's Product types, Product codes, and Product names, number of coats, and dry film thicknesses, corresponding to each Painting Schedule code; submit listing minimum of 8 weeks before materials are required.
- .2 Samples:
- .1 Submit following samples in accordance with Section 01 00 00:
- .1 Three 300 x 300 mm draw downs of each colour minimum 4 weeks before paints are required.
- .2 Identify each sample with Contract number and title, colour reference, sheen, date, and name of applicator.
- .3 Certificates:
- .1 Submit certification from paint manufacturer, on company letterhead, indicating each product proposed for use is Manufacture's premium grade, first line Product.
- .2 Submit certified documentation to confirm each airless spray painter has minimum of 5 years experience on applications of similar complexity and scope.
- .3 Submit certified documentation to confirm each worker has Provincial Tradesman Qualification certificate of proficiency.
- .4 Reports:
- .1 Submit written field inspection and test report results after each inspection.
- .2 Submit Field Quality Control test result reports for alkali content, substrate moisture, and dry film thickness.
- .3 Submit electronic moisture meter manufacturer's specifications including tolerances. Submit record of latest meter calibration to meet manufacturer's recommendations.

1.4 QUALITY ASSURANCE

- .1 Finishing work: Perform work to MPI requirements for premium grade.
- .2 Supervision: Have work supervised by a full-time qualified foreperson who has 10 years minimum experience on Contracts of similar complexity and scope.
- .3 Mock-up:
 - .1 Construct three 3 m² mock-ups of different Paint Schedule code systems, selected by Consultant, in locations acceptable to Consultant to demonstrate installation workmanship, colour, and hiding power of Products.
 - .2 Obtain Consultant's acceptance in writing before proceeding with the work of this Section.
 - .3 Mock-ups may remain as part of the Work if acceptable to Consultant and will serve as a standard for similar code systems.
 - .4 Repaint over mock-ups which do not form part of the Work.

1.5 DELIVERY, STORAGE, AND HANDLING

- .1 Install correct, safe temporary storage for paint, thinner, solvents, and other volatile, corrosive, hazardous, and explosive materials in accordance with requirements of authorities having jurisdiction.
- .2 Post hazard warning signage in areas of storage and mixing. Install and maintain sufficient CO₂ fire extinguishers of minimum 9 kg capacity, accessible in each storage mixing and storage areas.
- .3 Maintain storage enclosures at minimum 10°C ambient temperature and to manufacturer's instructions.

1.6 SITE CONDITIONS

- .1 Apply coatings under the following conditions:
 - .1 Interior coatings: 7°C minimum.
 - .2 Relative humidity: 85% maximum.
 - .3 Not in direct exposure to sun light.
- .2 Maintain temperature conditions indicated above for 24 hours before, during and 24 hours after painting.
- .3 Install clean plywood sheets to protect floors and walls in storage and mixing areas, from paint drips, spatters, and spills.
- .4 Apply sufficient masking, clean drop cloths, and protective coverings for full protection of work not being painted including, but not limited to, the following:
 - .1 Light fixtures, fire and smoke detectors.
 - .2 Data cabling and data infrastructure.
 - .3 Sprinkler heads.
 - .4 Prepainted diffusers and registers.

- .5 Prepainted equipment.
- .6 Fire rating labels and equipment specification plates.
- .7 Finished surfaces.

1.7 MAINTENANCE

- 1. Deliver to Owner's place of storage on completion of work, sealed containers of each finish painting material applied, and in each colour. Label each container as for original, including mixing formula. Provide the following:
 - .1 1 L of extra materials when less than 50 L are used for Project;
 - .2 3.78 L of extra stock when 50 to 200 L are used;
 - .3 7.57 L of extra stock when over 200 L are used.

2 Products

2.1 MATERIALS

- .1 Paint:
 - .1 All materials under work of this Section, including but not limited to, primers, stains, and paints are to have low VOC content limits.
 - .2 Products in accordance with the MPI Painting Specification Manual, Exterior and Interior Systems;
 - .1 For each MPI paint code, manufacture's premium grade, first line Products is to be use.
 - .2 Uniform dispersion of pigment in a homogeneous mixture.
 - .3 Ready-mixed and tinted whenever possible.
 - .3 Products within each MPI paint system code: From single manufacturer.
 - .4 Acceptable manufacturers:
 - .1 AkzoNobel.
 - .2 Benjamin Moore.
 - .3 PPG Industries Inc.
 - .4 Sherwin Williams.

2.2 COLOUR SCHEDULE

- .1 Consultant will select choice of colours and gloss when compiling a Colour Schedule after award of Contract; allow for colour selection beyond paint manufacturer's standard colour range.
- .2 Refer to Finish/Material/Product Schedule for selected colour references.
- .3 Conform to gloss reflectance definitions listed in MPI Specification Manual.

2.3 PAINTING AND FINISHING SCHEDULE

- .1 Refer to Table 1, MPI Painting and Finishing Schedule coded systems, comply with MPI Painting Specification Manual.

Table 1: Painting and Finishing Schedule				
INTERIOR SUBSTRATES	Typical substrates (Including but not limited to)	MPI Manual Ref.	MPI Finish System Code	Topcoat
Concrete floors		INT 3.2	INT 3.2C	Epoxy
Concrete block masonry		INT 4.2	INT 4.2J	Epoxy-modified latex
Galvanized Metal	HM doors & door frames	INT 5.3	INT 5.3D	Epoxy-modified latex
Galvanized Metal	HM doors and frames	INT 5.3	INT 5.3M	High performance latex
Wood paneling & casework	Millwork	INT 6.4	INT 6.4E	Poly-urethane
Gypsum board	Drywall, walls, ceilings	INT 9.2	INT 9.2B	High performance latex
Gypsum board	Wet areas	INT 9.2	INT 9.2F	Epoxy-modified latex

3 Execution

3.1 EXAMINATION

- .1 Verify condition of previously installed Work upon which this Section depends. Report defects to Consultant. Commencement of work of this Section means acceptance of existing conditions.

3.2 PREPARATION

- .1 General:
- .1 Clean substrate surfaces free from, dust, grease, soiling, or extraneous matter, which are detrimental to finish.
 - .2 Patch, repair, and smoothen minor substrate defects and deficiencies e.g. machine, tool and sand paper marks, shallow gouges, marks, and nibs.
 - .3 Clean, sweep, and vacuum floors and surfaces to be painted, debris and dust-free prior to painting.

-
- .4 Refer to manufacturer's written instructions and MPI Painting Specification Manual for surface preparation requirements of substrates not listed here.
 - .2 Where finish hardware has been installed remove, store, re-install finish hardware, to accommodate painting. Do not clean hardware with solvent that will remove permanent lacquer finishes.
 - .3 Alkali Content tests and neutralization:
 - .1 Test for ph level using litmus paper on dampened substrate.
 - .2 Neutralize surfaces over 8.5 ph with 4% solution of Zinc Sulphate for solvent based systems and tetrapotassium pyrophosphate for latex based systems, to below 8.0 ph, and allow to dry.
 - .3 Brush-off any residual Zinc Sulphate crystals.
 - .4 Coordinate paint system primer / sealer to be alkali-resistant.
 - .4 Substrate moisture tests:
 - .1 Test for moisture content over entire surface to be painted, minimum one test/ 2 m² in field areas and one test/600 mm along inside corners including at ceiling to wall juncture.
 - .2 If any test registers above 10% allow entire substrate surfaces, within the plane, to dry further before paint system application. Install temporary drying fans if necessary.
 - .3 Re-test employing same criteria.
 - .5 Mildew removal: Scrub with solution of trisodium phosphate and sodium hypochlorite (Javex) bleach, rinse with water, and allow to dry completely.
 - .6 Cementitious and masonry (existing): Clean existing surfaces by pressure washing where indicated on drawings with a TSP solution and pressure range of 1500 - 4000 PSI at 6 - 12". Rinse areas with clean water and allow to thoroughly dry. Provide for collection and disposal of water.
 - .7 Concrete floors (existing): Clean existing surfaces by pressure washing where indicated on drawings with a TSP solution and pressure range of 1500 - 4000 PSI at 6 - 12". Rinse areas with clean water and allow to thoroughly dry. Provide for collection and disposal of water.
 - .8 Cementitious and masonry (Concrete, block, brick, stucco, cement rendering):
 - .1 Allow 28 days cure before painting.
 - .2 Coordinate repair of protrusion-chipping and grinding, and honeycomb filling with responsible trades.
 - .3 Remove dirt, loose mortar, scale, powder, efflorescence, and other foreign matter.
 - .4 Remove form oil and grease with trisodium phosphate, rinse, and allow to dry thoroughly.
 - .5 Remove rust stains with solution of sodium metasilicate after thorough wetting; allow to dry thoroughly.

- .9 Galvanized steel sheet:
 - .1 Z275 (Satin & Spangled Sheet): SSPC SP7 brush blast.
 - .2 ZF075 (Wiped Coat): Remove contamination, wash with Xylene solvent.
 - .3 Touch-up damaged galvanized areas with organic zinc rich primer.

- .10 Galvanized iron and steel: Prepare galvanized and ungalvanized metal surfaces as follows:
 - .1 Unpassivated, unweathered and weathered: Remove contamination, wash with Xylene or Toluol solvent, allow to dry thoroughly. Make paint system primer/sealer an etching type primer.
 - .2 Manufacturer pre-treated (including passivated): SSPC SP7.
 - .3 Touch-up damaged galvanized areas with organic zinc rich primer.

- .11 Wood and Millwork:
 - .1 Wood surfaces to be clean and dry with a moisture content of less than 15%.
 - .2 Remove foreign matter prior to prime coat; spot coat knots, pitch streaks and sappy sections with sealer.
 - .3 Fill nail holes and fine cracks after primer has dried.
 - .4 Backprime interior and exterior woodwork.

- .12 Gypsum board (existing):
 - .1 Remove dust, dirt, oil, grease, glue and all foreign material. Clean with stiff fibre brush prior to applying primer coat.
 - .2 Coordinate repairs and touch-ups with the responsible trade.
 - .3 Lightly sand surface to smooth out ridges and provide neat smooth surface.

- .13 Gypsum board:
 - .1 Apply primer/sealer paint to reveal defects and deficiencies and to equalize absorption areas.
 - .2 Coordinate repairs and touch-ups with the responsible trade.
 - .3 Re-prime repairs.

- .14 Coordinate with other trades to prevent:
 - .1 Damage, and inadvertent activation of fire and smoke detectors.
 - .2 Odour and dust distribution by permanent HVAC systems including fouling of ducts and filters.

- .15 Field-mix Products in accordance with manufacturer's written instructions.

3.3 APPLICATION

- .1 Apply painting systems in accordance with manufacturer's written instructions and the MPI Painting Specification Manual. Apply each Product to manufacturer's recommended dry film thickness.
- .2 Painting systems listed are required minima, apply additional coats if necessary to obtain substrate hiding acceptable to the Consultant.

- .3 Tint intermediate coats lighter than final top coats for identification of each succeeding coat and to facilitate inspections. Include only manufacturer's recommended reducing and tinting accessories. Do not add adulterants.
- .4 Primer to be specialized primer coating system as required by manufacturer for selected colour. Standard primer being tinted shall be tinted to a maximum of 1.5% by volume.
- .5 Sand lightly between coats to achieve a tooth or anchor for subsequent coats.
- .6 Apply paint uniformly in thickness, colour, texture, and gloss, as determined by the Consultant under adequate illumination and viewed at a distance of 1500 mm. Apply finishes free of defects in materials and application which, in the opinion of the Consultant, affect appearance and performance. Defects include, but are not limited to:
 - .1 Improper cleaning and preparation of surfaces.
 - .2 Entrapped dust, dirt, rust.
 - .3 Alligating, blisters, peeling.
 - .4 Scratches, blemishes.
 - .5 Uneven coverage, misses, drips, runs, and poor cutting in.
- .7 Do not apply coatings on substrates which are not sufficiently dry. Unless indicated otherwise, allow each painting system coat to cure dry and hard before following coats are applied.
- .8 Repaint entire areas of damaged or incompletely covered surfaces, to the nearest inside or outside corner; patching will not be permitted.
- .9 Miscellaneous painting requirements:
 - .1 Paint projecting ledges, and tops, bottoms and sides of doors both above and below sight lines to match adjacent surfaces.
 - .2 Paint door frames, access doors and frames, door grilles, prime coated butts, and prime coated door closers to match surface in which they occur.
 - .3 Finish closets and alcoves as specified for adjoining rooms.
 - .4 Paint interior columns to match walls of room.
 - .5 Unless otherwise indicated, allow for:
 - .1 2 wall colours per room, one ceiling colour per room.
 - .2 Different door colours in each functionally different area.
 - .3 Different colours on both sides of same door.
- .10 Mechanical, electrical and other painting coordination:
 - .1 Paint following items unless specified or indicated on drawings not to be painted.
 - .2 Paint mechanical services in accordance with Mechanical Identification Division 21, 22 and 23.
 - .3 Coordinate painting of pipes, ducts, and coverings with the work of Division 21, 22 and 23 to precede pipe colour banding, flow arrows, and other pipe identification labeling installation.

- .4 Paint exposed conduit, pipes, hangers, ductwork, grilles, gratings, louvres, access panels, fire hose cabinets, registers, enclosures, and other mechanical and electrical equipment including services concealed inside cupboard and cabinet work; apply colour and sheen to match adjacent surfaces, except as noted otherwise.
- .5 Paint portions of surfaces such as duct interiors, piping, ductwork, hangers, insulation, walls, and similar items, visible through grilles, louvres, convector covers etc., matte black in colour.
- .6 Remove the following to accommodate painting, carefully store, clean, then re-install on completion of each area and when dry:
 - .1 Switch and receptacle plates, fittings and fastenings, grilles, gratings, louvres, access panels, and enclosures .

3.4 FIELD QUALITY CONTROL

- .1 Dry film thickness tests:
 - .1 Test for film thickness over entire surface to be painted, minimum one test/2 m² in field areas and one test/600 mm along inside corners including at ceiling to wall juncture.
 - .2 If any test registers below specified thickness, re-apply paint to entire surface to nearest inside and outside corners.
 - .3 If test registers more than 50% above specified thickness, consult with paint manufacturer, determine if problem exists, offer solutions to Consultant, and repair as directed.
 - .4 Re-test employing same criteria after repair.

3.5 CLEANING

- .1 Remove spilled, splashed, and spattered paint promptly as work proceeds and on completion of work. Clean surfaces soiled by paint spillage and paint spatters. Repair or replace damaged work, as directed by Consultant.

3.6 PROTECTION

- .1 Post Wet Paint signs during drying and restrict or prevent traffic where necessary.
- .2 Post sign, after Consultant's inspection and acceptance of each room, reading: PAINTING COMPLETE - NO ADMITTANCE WITHOUT CONTRACTOR'S PERMISSION.

END OF SECTION

1 General

1.1 **SECTION INCLUDES**

.1 Labour, Products, equipment and services for washroom accessories work as listed below in accordance with the Contract Documents.

- .1 Grab bar
- .2 L-shaped Grab bar
- .3 Swing up/fold down grab bar.
- .4 Tilted Mirror.
- .5 Folding shower seat.
- .6 Heated Towel Rail.

1.2 **REFERENCES**

- .1 ASTM A167, Specification for Stainless Steel and Heat-Resisting Chromium-Nickel Steel Plate, Sheet, and Strip.
- .2 ASTM A312, Specification for Seamless and Welded Austenitic Stainless Steel Pipes.
- .3 ASTM A653/A653M, Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvanealed) by the Hot-Dip Process.
- .4 CAN/CSA B651-M, Accessible Design for the Built Environment.

1.3 **SUBMITTALS**

- .1 Product data: Submit Product data to requirements of Section 01 00 00 indicating each washroom accessory describing size, finish, details of function, attachment methods, hardware and locks, description of rough-in frame, and building-in details of anchors for grab bars.
- .2 Closeout submittals:
 - .1 Submit for each Product operation and maintenance instructions for incorporating into the Operations and Maintenance Manuals in accordance with Section 01 00 00.
 - .1 Supply 2 keys for each lockable washroom accessory to Consultant.
 - .2 Master key washroom accessories which are keyed.
- .3 Extended warranty: Submit extended warranty signed and registered by the manufacturer providing the warranty in the name of the Owner for the timeframe and coverage specified in this Section.

1.4 **DELIVERY, STORAGE AND HANDLING**

- .1 Deliver materials in sealed cartons and containers with manufacturer's name and product description clearly marked.

1.5 **EXTENDED WARRANTY**

- .1 Submit an extended warranty for washroom accessories work in accordance with the General Conditions, except that the warranty period is extended to 10 years.
 - .1 Against cracked or scratched mirrors, spoiling or deterioration of silvering or backing, loosening of fastenings or adhesive
 - .2 Coverage: complete replacement including effected adjacent work.

1.6 **MAINTENANCE**

- 1. Maintenance Tools: Provide special tools necessary for accessing, assembly/disassembly or removal of toilet, bath and cleaning accessories in accordance with Section 01 00 00.

2 Products

2.1 **MATERIALS**

- .1 Stainless steel:
 - .1 Sheet metal: ASTM A167, Type 304.
 - .2 Tubing: ASTM A312, Type 304.
- .2 Sheet steel: ASTM A653M, Z275; Cold rolled, commercial quality, surface preparation and pretreatment as required for applied finish.
- .3 Fasteners, screws and bolts: ASTM A167, Type 304 stainless steel, tamper-proof.

2.2 **ACCESSORIES**

- .1 Refer to drawings for quantity and location of washroom accessories.
- .2 Grab bar (GB-1):
 - .1 Series B-6806-99 by Bobrick or #3800-P Series by ASI Group Canada; 38 mm diameter, 1.2 mm thick, concealed mounting with snap flange, complete with escutcheons. Lengths and configurations as indicated on drawings.
 - .2 Finish: Type 304 stainless steel with a satin finish and peened grip.
- .3 L-shaped Grab bar (GB-2):
 - .1 'Series 6898-99 - L30x30' by Bobrick Washroom Equipment or approved alternative; 38 mm diameter, 1.2 mm thick, concealed mounting with snap flange, complete with escutcheons.

-
- .2 Length and configuration: 762 x 762 mm, in L-shaped configuration as shown on Contract Drawings.
 - .3 Finish: Type 304 stainless steel with a satin finish and peened grip.
 - .4 Swing up/fold down grab bar (GB-3):
 - .1 #B-4998 Swing-Up Grab Bar by Bobrick Canada or approved alternative; 38 mm diameter, 1.2 mm thick, 762 mm long in location as indicated. Installation to include anchor plate or blocking as required.
 - .2 Finish: Type 304 stainless steel with a satin finish.
 - .5 Tilted Mirror (MIR-1): 6 mm thick, mirror quality float glass.
 - .1 #B-293 Series by Bobrick or #0535 Series by ASI Group Canada; mitred corners welded, and polished smooth.
 - .2 Dimensions: Sizes and locations as indicated on the Contract Drawings.
 - .3 Frame finish: Type 304 stainless steel satin finish.
 - .6 Shower seat (SS-1):
 - .1 #B-5191 by Bobrick or #8203 Series by ASI Group Canada; surface wall mounted seat with 8 mm thick water-resistant, ivory coloured solid phenolic.
 - .2 Dimensions: 405 mm deep x 460 mm wide.
 - .3 Finish: Type 304 stainless steel frame.
 - .7 Heated Towel Rail (TR-1):
 - .1 'K4013W Konyour Linear Electric Towel Warmer' by ICO Bath or approved alternative, 610 mm x 686 mm, wall mounted, hardwired linear bathroom towel warmer.
 - .2 Finish: Chrome
 - .3 Coordinate with Electrical Consultant for installation.
- 3 Execution
- 3.1 **EXAMINATION**
- .1 Verify condition and dimensions of previously installed Work upon which this Section depends. Report defects to Consultant. Commencement of work of this Section means acceptance of existing conditions.
- 3.2 **INSTALLATION**
- .1 Verify and coordinate templates, inserts, and rough-in frames and verify exact location of washroom accessories for installation.
 - .2 Verify there is adequate supports and/or blocking in gypsum wall assemblies prior to installation of washroom accessories. Provide addition support/ blocking in gypsum wall assemblies if necessary.
 - .3 Provide fastening and mounting kits for washroom accessories.

- .4 Locate washroom accessories where indicated on Drawings and where directed by Consultant.
- .5 Install washroom accessory fixtures, accessories, and items in accordance with manufacturer's instructions and CAN/CSA B651-M. Provide exposed tamper-proof screws of stainless steel to match units.
- .6 Install washroom accessories plumb, level, and securely and rigidly anchored to substrate surfaces and framing. Adjust accessories for proper operation and verify mechanisms function smoothly.
- .7 Clean and polish exposed surfaces and fill accessories with necessary supplies prior to acceptance by Consultant.

END OF SECTION

-
- 1 General
- 1.1 **SECTION INCLUDES**
- .1 Labour, Products, equipment and services necessary for miscellaneous specialties work in accordance with the Contract Documents.
- 1.2 **SUBMITTALS**
- .1 Product data:
- .1.1 Submit duplicate copies of manufacturer's Product data for each Product specified in accordance with Section 01 00 00 indicating:
- .1.1.1 Performance criteria, compliance with appropriate reference standard(s), characteristics, and limitations.
- .1.2 Product transportation, storage, handling and installation requirements.
- .2 Shop drawings:
- .2.1 Submit shop drawings in accordance with Section 01 00 00 indicating elevations, sections, details, dimensions, materials, gauges, and finishes.
- .2.2 Provide shop drawings indicating surrounding construction and installation requirements for saunas.
- .3 Closeout submittals: Submit cleaning and maintenance instructions for miscellaneous specialties for incorporation into Operations and Maintenance Manuals in accordance with Section 01 00 00.
- 1.3 **DELIVERY, STORAGE, AND HANDLING**
- .1 Package or crate, and brace products to prevent distortion in shipment and handling. Label packages and crates, and protect finish surfaces by sturdy wrappings.
- 2 Products
- 2.1 **MANUFACTURED UNITS**
- .1 Stainless steel corner guard (CG-1): 51 mm x 51 mm x 90°, stainless steel corner guard. Surface mounted 'CO-8' by C/S Group or approved alternative by McGill Architectural Products.
- .2 Door frame protection (DP-1): Two-piece custom formed door frame protector manufactured from 1.02 mm thick Acrovyn sheet, system shall come complete with standard adhesive or optional factory applied double face tape and all accessories to provide a complete installation; 'Model A1/A2-DFP' by C/S Group or approved alternative. Colour: to be selected by Consultant.

-
- 3 Execution
- 3.1 **EXAMINATION**
- .1 Verify condition and dimensions of previously installed Work upon which this Section depends. Report defects to Consultant. Commencement of work of this Section means acceptance of existing conditions.
- 3.2 **PREPARATION**
- .1 Verify substrate surfaces are solid, free from surface water, dust, oil, grease, projections and other foreign matter detrimental to performance.
- .2 Items to be built-in: Provide information and templates required for installation of work of this Section, and assist or supervise, or both, the setting of anchorage devices, and construction of other work incorporated with products specified in this Section in order that they function as intended.
- .3 Verify there is adequate supports and/or blocking in gypsum wall assemblies prior to installation of miscellaneous specialty items as required.
- 3.3 **INSTALLATION**
- .1 Install miscellaneous specialties level and securely and rigidly anchored to substrate in accordance with authorities having jurisdiction, reviewed shop drawings, and manufacturer's written instructions.
- .2 After installation, adjust miscellaneous specialties in accordance with manufacturer's written instructions.
- 3.4 **CLEANING**
- .1 Clean and polish exposed surfaces prior to acceptance by Consultant.

END OF SECTION

PART 1 GENERAL

1.1 RELATED DOCUMENTS

.1 Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections apply to this Section.

.2 The General Contractor shall be responsible for coordinating all work contained in this section of the specification including the work provided by the:

1. Foodservice Division 11 40 00;
2. Electrical Division 26 00 00;
3. Plumbing Division 22 00 00;
4. Mechanical Division 23 00 00;
5. Structural Division 30 00 00, 40 00 00 and 50 00 00;
6. Architectural Millwork Division 62 00 00 ; and
7. Other trades subcontractors.

.3 ABBREVIATIONS

S.S.	-	Stainless Steel
C/W	-	Complete With
A.F.F.	-	Above Finished Floor
A	-	Amperes
V	-	Volts
CY	-	Cycle
P	-	Phase
Pl. lam.	-	Plastic Laminate
Kw	-	Kilowatt
kPa	-	Kilopascals
J.B.	-	Junction Box
CFM	-	Cubic Feet per Minute
L.E.D	-	Light Emitting Diode
in	-	Inches
ft	-	feet
F	-	Fahrenheit
C.P.	-	Chrome Plated
I.P.S.	-	Inside Pipe Size
N.I.C.	-	Not in Contract (for Section 114000)
L.C.	-	Load Center
CBP	-	Circuit Breaker Panel
KEC	-	KEC

.4 Delivery and installation, removal, storage and relocation of all food service equipment, included in this specification to be as per the schedule set out by the General Contractor or other designated party.

1.2 RELATED TYPICAL WORK BY OTHER TRADES

.1 WORK PROVIDED BY ELECTRICAL DIVISION 26 00 00

1. Supply, rough-in, installation and connection of all necessary electrical wiring in liquid tight flexible conduit (AC-90) required for the operation of, but not limited to the foodservice equipment, prefabricated insulated walk-in refrigerated and frozen room assemblies, mechanical refrigeration systems, foodservice conveyors and ware washing/waste management systems unless otherwise stated in Part 1.3 of this Section of the Specification.
2. Supply and installation of electrical wiring from the building source or distribution point of power, through disconnect switches to the terminals, connection box, circuit- breaker panel or plug receptacles located on the equipment. Equipment manufacturer's control panels and switches are not considered to be disconnect switches unless specifically permitted by applicable codes.
3. Supply, installation and co-ordination of all required disconnect switches, except those provided by the KEC for evaporator coils inside walk-in refrigerators and freezers, and power distribution panels.
4. Supply and installation of receptacles in all food service areas. All receptacles in wet areas such as the dish-room and pot wash areas must be waterproof and must have ground fault interrupters.
5. Supply and installation of all electrical wiring from power source through disconnect switches and ground fault interrupters to the various components of the ware washing and waste management system including but not limited to the control panel on the scrapping table, the dish washing machines, the waste collector and the waste collector control panel.
6. Supply and installation of water-proof emergency stop push button(s) for all ware washing equipment, location to be determined on site.
7. Supply and installation of electrical wiring from power source through disconnect switches to the control panel(s) for exhaust ventilator(s) and hood(s).
8. Supply and installation of electrical inter-wiring of control panel(s) for all exhaust ventilator(s) and hood(s) from the control panel to the exhaust ventilator(s) and hood(s) and from the control panel to the magnetic contactor on the exhaust and make up air fan(s).
9. Supply and installation of all inter-wiring required for the kitchen ventilation and fire suppression system components including but not limited to the following: exhaust ventilator(s) hood(s), control panel(s), pull stations, surface fire suppression detector(s) in each exhaust ventilator and hood, fire suppression building alarm fire and trouble interlocks as required, exhaust fans, makeup air units, cooking equipment shut down devices, and interlocks to Building Management Control Systems.
10. Supply and installation of electrical wiring from power source to components of the fire control system as required.

11. Supply and installation of wall switches for exhaust ventilator(s) and hood(s) lights and the supply and installation of inter-wiring between the wall switch and junction boxes on each ventilator or hood section.
12. Supply and installation of all inter-wiring for exhaust and make-up air fans, exhaust ventilator control panel(s), magnetic contactors and shunt trips etc. so as to shut down power to electric cooking equipment in the event of a fire condition in conjunction with the fire suppression system.
13. Supply and installation of electrical wiring from power source through disconnect switches or MCC to the exhaust and make-up air fans.
14. Supply and install the reset relay or shunt trip to shut down electricity to the cooking equipment in the event of activation of the surface fire suppression system.
15. Supply and installation of all electrical wiring from power source through disconnect switches to the various components of the mechanical refrigeration system for the walk in refrigerators and freezers, including but not limited to compressors, refrigeration rack, air cooled condensers, compressor room gas detection system and any other devices or equipment items required to form a complete and operating system as specified in Part 2 of this specification.
16. Supply and installation of electrical wiring from power source to a junction box(es) on top of the prefabricated walk-in refrigerator and freezer for power supply to each interior light fixture. Division 260000 to supply and install all interconnections between individual light fixtures and junction box for the light switch located on top of the prefabricated walk-in refrigerated and freezer rooms. Division 114000 to physically mount all interior light fixtures and run electrical wiring within conduit from each interior light fixture to a junction box located on top of the prefabricated walk-in refrigerated and frozen room assembly.
17. Supply and installation of electrical wiring from power to a junction box(es) on top of each prefabricated walk-in refrigerator and freezer for power supply to door heaters. Division 114000 to factory pre-wire door heaters within pre-fabricated insulated wall panels and run wiring to a junction box located on top of the walk-in room assembly.
18. Supply and installation of electrical wiring from power source to a junction box(es) on top of each prefabricated walk-in refrigerator and freezer for power supply to temperature alarms. Division 114000 to factory pre-wire all temperature alarms within pre-fabricated insulated wall panels and run wiring to a junction box located on top of the walk-in room assembly. Division 26 to supply and install all necessary wiring interconnections within conduit between temperature alarms and building annunciation system and/or building control management system.
19. Supply and installation of electrical wiring from power source to a junction box(es) on top of each prefabricated walk-in refrigerator and freezer for power supply to interior electrical receptacles. Division 114000 to supply and install all electrical receptacles within the walk-in room assemblies. Division 114000 to factory pre-wire electrical receptacles within pre-fabricated insulated wall panels and run wiring to a junction box located on top of the walk-in room assembly.

20. Supply and installation of all electrical wiring from power source to a junction box on top of each prefabricated walk-in freezer for power supply to drain line heaters. Division 114000 to provide receptacle recessed in pre-fabricated insulated panel for drain line heater. Division 114000 to run wiring from receptacle to a junction box on top of room ready for final connection by Division 260000.
21. Supply, rough-in and installation of all electrical wiring required for "Owners Supplied", "Existing", "Relocated" or "NIC" designated equipment, as well as final hook-up and connections.
22. Supply, rough-in and capping off of electrical wiring required for any equipment designated as "Future".
23. Supply and installation of all electrical receptacles located in floors, ceilings or walls.
24. Supply and installation of all ceiling hung twist lock type receptacles as required.
25. Supply and installation of emergency stop button mounted on wall capable of interrupting power supply to dishwasher, waste reduction system, waste disposer, waste disposer control panel and scrapping table. Number and location of emergency stop buttons to be confirmed with owner on-site.

.2 WORK PROVIDED BY PLUMBING - DIVISION 22 00 00

1. Supply, installation, rough-in and connection of all domestic hot and cold water, drains, vents, gas supply lines, steam supply and condensate return lines as per code from building supply to the point of connection required for the complete operation of, but not limited to, the foodservice equipment, mechanical refrigeration systems, the pre-fabricated, insulated walk-in refrigerated and frozen room assemblies, foodservice conveyors and the ware washing/waste management systems.
2. Supply and installation of domestic hot and cold water lines complete with shut off valves, back flow preventers, line strainers, shock absorbers, pressure, temperature and pressure gauges and control valves or devices (unless otherwise stated and/or supplied with the equipment of this section). This project will be constructed, using components (valving and piping) which satisfies the requirements for a "Lead Free" domestic water supply system as defined by the province of British Columbia. All valves, piping, and fittings 2" and smaller, used in domestic water piping serving faucets or plumbing fixtures used to dispense water for drinking or food preparation shall conform to the province of British Columbia requirements.
3. Supply, installation, rough-in and connection of all domestic hot and cold water and drains as per code from building supply to the point of connection required for the complete operation of hand sinks and work tables with sinks within the pre-fabricated insulated walk-in refrigerated and frozen room assemblies. Division 230000 shall identify all penetrations/holes required in the pre-fabricated wall and/or ceiling panels to accommodate any plumbing or drain lines and request Division 114000 to cut penetrations/holes as required. Division 23000 shall also inform Division 114000 after the plumbing and drainage is complete in order that Division 114000 can seal all penetrations/holes appropriately.

4. Supply and installation of drain lines complete with traps, vent piping and clean outs.
5. Supply and installation of drain lines, traps, vent piping, clean outs and grease traps, drains for floor pans, connected drains for equipment, floor drains with funnels for open drains on equipment and exhaust ventilators.
6. Supply and installation of combination funnel floor drains required for the condensate drain lines from each evaporator coil inside prefabricated, insulated walk-in refrigerated and frozen room assemblies.
7. Supply and installation of all indirect drain lines including, but not limited to those required for foodservice equipment, mechanical refrigeration systems, conveyors, ware washing and waste management systems and any other open or indirect type connections from custom fabricated stainless steel equipment to a hub, funnel or combination drain at a rate of not less than 1" in 24".
8. Extend all open or connected drains on foodservice equipment, mechanical refrigeration systems, conveyors and ware washing/waste management systems to above funnel floor drains using chrome plated piping.
9. Supply and installation of all floor drains for general drainage purpose, maintenance and cleaning. Finished floor to slope to all floor drains to ensure proper drainage and prevent pooling.
10. Supply and installation of water softener and condensate return pump for dishwashing equipment.
11. Interconnection between refrigerant leak detector system (supplied by Division 114000) and ventilation system for mechanical room and B.A.S. system.
12. Supply and installation of all hand sinks, slop sinks, janitorial sinks, drinking fountains, grease traps and general sanitizing stations as noted in the drawings.
13. Supply and installation of gas lines with manifolds to each piece of gas fired foodservice equipment complete with shut off valves. Installation of mechanical gas valve(s) as specified under the Foodservice Section of Division 114000, in conjunction with the fire suppression system. Install pressure regulating valves as specified under the Foodservice section of Division 114000.
14. Supply and installation of grease traps.
15. Supply and installation of sediment interceptors before grease traps.
16. Installation of water filters provided by Division 114000 for coffee machines, hot water machines, combi ovens, soda machines and ice/water dispensers.
17. Supply and inter-connection of water lines between hose reel control panels and hose reels.
18. Connection of all equipment designated as "Owner Supplied".
19. Disconnection and later reconnection of any equipment designated as "Existing Equipment to Be Relocated or Reused".
20. Capping off of all mechanical services for all equipment designated to be removed.

21. Roughing-in and capping off of mechanical services required for any equipment designated as "Future".

22. Use chrome plated piping wherever exposed.

.3 WORK PROVIDED BY THE MECHANICAL HVAC - DIVISION 23 00 00 FOR KITCHEN EXHAUST SYSTEMS – NOT APPLICABLE

.4 WORK PROVIDED BY MECHANICAL CONTROL AND INTEGRATED AUTOMATION - DIVISIONS 23 00 00 and 25 00 00 – NOT APPLICABLE

.5 WORK PROVIDED BY OTHER TRADES

1. Construction of all walls, partitions or ceilings, openings therein and finishes thereon.

2. Demolition and make good of any existing wall, partitions or ceilings, openings there in and finishes there on required to accommodate the revised plan/layout.

3. Supply and installation of floors, floor levelling materials and floor finishes throughout the foodservice areas as well as those required for, but not limited to, prefabricated insulated walk-in type refrigerated and frozen room assemblies.

4. Finished floors to slope to all floor drains to ensure proper drainage and prevent pooling.

5. Provision of all floor depressions required for foodservice equipment, prefabricated walk in-type refrigerated or frozen room assemblies, trench drains etc. as required or indicated on drawings.

6. Provision of concrete curbs and bases under foodservice equipment, and mechanical refrigeration systems.

7. Provision of concrete bases or pads with vibration isolation for outdoor condenser, if required.

8. Provision of all building floor levelling, grouting, finishing, cutting and patching required to accommodate installation of prefabricated insulated walk-in refrigerated and frozen room assemblies.

9. Provision of all building floor slab toppings for prefabricated, insulated walk-in refrigerated or frozen room assemblies where specified.

10. Supply and installation of in-fill concrete topping inside prefabricated, insulated walk-in refrigerated and frozen room assemblies which have depressed prefabricated insulated floor panels so as to make floor level with outside floors (allowing for floor finish thickness).

11. Supply and installation of all floor tile or other specified flooring finishes inside prefabricated, insulated walk in type refrigerated and frozen room assemblies including coving up inside and outside of prefab walls.

12. Provision of all core hole drilling through building structural slab, walls or roof to accommodate refrigeration lines, electrical conduit, plumbing lines, steam supply

and condensate return lines, gas lines, detergent lines and exhaust/make-up air ducting etc.

13. Supply and installation of grout under and around floor sump pans and depressions.
14. Supply and setting of sleeves in floors, walls and ceiling (as well as any related core drilling) for electrical, mechanical refrigeration, plumbing, gas and beverage lines etc.

1.3 WORK INCLUDED BY FOODSERVICE DIVISION 114000 CONTRACTOR

.1 GENERAL

1. The work listed here includes, but is not limited to, the provision of all equipment indicated on the drawings and listed in the specifications together with labour, material, tools, plant, delivery, un-crating, setting-in-place of equipment, erecting of prefabricated insulated walk-in type refrigerated and frozen room assemblies, leveling, final assembly of equipment items shipped knocked down or in sections and cleaning herein ready for final connection of services by mechanical and electrical trades.
2. The work listed here includes coordination of the schedule for the manufacture, delivery and setting into place of the food service equipment in conjunction with the overall construction schedule being maintained by the General Contractor. This also includes the delivery and set-into-place of all large foodservice equipment that may not fit through normal building doorways such as but not limited to mechanical refrigeration system components, dishwashing and waste management system components or exhaust ventilators. Ensure that there is sufficient access into the building for the delivery and set into place of all foodservice equipment, mechanical refrigeration system components, prefabricated insulated panels for walk-in refrigerated and frozen rooms, conveyors or ware washing equipment etc.
3. Attend project site meetings when requested by the General Contractor, food service consultant, owner and/or architect and provide coordination with the other construction team members as required.
4. Oversee the scheduling, performance and delivery of all work and products being supplied by sub-contractors hired by the KEC.
5. Provide all required drawings including by not limited to: plans, elevations, construction and fabrication details, refrigeration shop drawings, mechanical and electrical rough in and connection drawings in conjunction with the project schedule as maintained by the General Contractor. Note the KEC is to show services for owner supplied owner installed equipment on their shop drawings.

.2 ELECTRICAL

1. All work shall comply with the standards for material and workmanship specified under Division 26 00 00.
2. Supply and installation of low water cut-off devices for any equipment in which immersion type electric heating elements are utilized.

3. Supply and installation of all motors integral with equipment complete with starters, motor control centers and internal thermal overload protection.
4. Supply and installation of all internal wiring on custom fabricated items in a concealed and well supported manner and terminated inside circuit breaker panels or junction boxes ready for final connection by the electrical trades. All equipment shall be inspected by the local hydro authority and carry LOCAL and UL approval
5. Supply and installation of all necessary junction boxes and circuit breaker panels (electrical load centers) required to terminate internal wiring within custom fabricated equipment, refrigeration system, exhaust ventilator(s) exhaust hood(s) and conveyors etc.
6. Tag each multiple electrical wire or cable used in any custom fabricated piece of equipment to indicate the item serviced. When circuit breaker panels are used, identify each circuit.
7. Supply and installation of waterproof wiring, outlets, panels and controls in all wet areas.
8. Supply and installation of cords and plugs on equipment as required and match the plug with the respective receptacle.
9. Supply and installation of waterproof electrical outlets on all custom fabricated equipment, prefabricated insulated walk-in type refrigerated and frozen room assemblies, conveyors and ware washing/waste management equipment. Mount electrical plug receptacles with stainless steel cover plates and casings. Furnish and install waterproof wiring. On open tables, recess outlets in stainless steel housing under table top. On enclosed tables and counters, recess outlets in stainless steel insert pans in counter front.
10. Supply and installation of switches for all lights in custom fabricated items.
11. Supply and installation of all necessary cords and plugs to match designated receptacles.
12. Supply and mount interior Low Temperature LED lights with quick starter ballasts within prefabricated walk-in refrigerator and frozen room assemblies. Physically mount all interior lights and run electrical wiring within conduit from each interior light to a junction box located on top of the prefabricated walk-in refrigerated and frozen room assembly. Supply and install junction box, ready for final connection by Division 260000.
13. Supply and installation of interior light switches within pre-fabricated insulated walk-in refrigerated and frozen room assemblies. Factory pre-wire light switches within pre-fabricated insulated wall panels and run wiring to a junction box located on top of the walk-in room assembly.
14. Factory pre-wire door heaters within pre-fabricated insulated wall panels and run wiring to a junction box located on top of the walk-in room assembly.
15. Supply and installation of temperature alarms. Factory pre-wire all temperature alarms within pre-fabricated insulated wall panels and run wiring to a junction box located on top of the walk-in room assembly. Section 114000 to supply and install

all necessary control wiring interconnections within conduit between temperature alarms and refrigeration system.

16. Supply and installation of electrical waterproof receptacles within pre-fabricated insulated walk-in refrigerated and frozen room assemblies. Supply and install all electrical receptacles within the walk-in room assemblies. Factory pre-wire electrical receptacles within pre-fabricated insulated wall panels and run wiring to a junction box located on top of the walk-in room assembly.
17. Supply and installation of electrical waterproof receptacles within pre-fabricated insulated walk-in refrigerated and frozen room assemblies for connection of drain line heaters. Factory pre-wire electrical receptacles within pre-fabricated insulated wall panels and run wiring to a junction box located on top of the walk-in room assembly.
18. Supply and installation of all drain line heater cables and insulation required for the walk-in refrigerated and/or frozen room assemblies.
19. Supply and installation of electrical wiring from contacts on evaporator coils through disconnect switches (supplied and installed by KEC) to a junction box located on top of the walk-in refrigerator and freezer assembly ready for final electrical connection from refrigeration rack by KEC.
20. Supply and installation of all electrical control wiring required for the mechanical refrigeration systems including but not limited to inter-connections from remote compressor(s), compressor(s), parallel pack(s), evaporative condensor(s), evaporator coils and temperature alarms.
21. Supply and installation of control wiring required for the refrigeration system or for any other device or equipment item included as part of the mechanical refrigeration system such as, but not limited to pumps, receivers, suction accumulator and liquid refrigerant sub-coolers etc.

.3 MECHANICAL

1. All work shall comply with the standards for material and workmanship specified under Division 22 00 00 and 23 00 00.
2. This project will be constructed, using components (valving and piping) which satisfies the requirements for a "Lead Free" domestic water supply system as defined by the province of British Columbia. All valves, piping, and fittings 2" and smaller, used in domestic water piping serving faucets or plumbing fixtures used to dispense water for drinking or food preparation shall conform.
3. Supply and installation of hard drawn copper condensate drain lines from each evaporator coil inside prefabricated, insulated walk-in refrigerated and frozen room assemblies complete with traps to building funnel floor drains. Wrap freezer evaporator coil drain lines with drain line heaters from coil to exterior of walk-in freezer. Evaporator fan coil condensate drain lines to be pitched down from drip pan connection to funnel floor drain at a rate of not less than 1" in 24". Wrap all condensate drain lines with insulated white PVC covering.
4. Provision and installation of all faucets complete with aerators and replaceable seats, ready for connection by appropriate contractor.

5. Supply and installation of chrome plated overflow assemblies, drain fittings and traps with tail pieces for all sink type assemblies.
6. Supply and installation of chrome plated blow down piping from items with relief or safety valves, extend piping to nearest hub or floor drain approximately 4" above drain.
7. Supply of any pressure regulating valves on domestic hot and cold water, low temperature chilled water, gas, steam or condensate lines for equipment supplied herein.
8. Conceal and support of all piping and accessories within custom fabricated equipment.
9. Interconnection of drains and water lines between common multiple pieces of equipment. i.e. exhaust ventilator(s) (hoods), steam equipment, dishwashers and waste collector etc.

.4 PREFABRICATED, INSULATED WALK IN TYPE REFRIGERATED AND FROZEN ROOM ASSEMBLIES – NOT APPLICABLE

.5 MECHANICAL REFRIGERATION SYSTEMS - NOT APPLICABLE

.6 EXHAUST VENTILATOR(S), (HOODS) AND FIRE SUPPRESSION SYSTEMS – NOT APPLICABLE

.7 WAREWASHING AND WASTE MANAGEMENT SYSTEM

1. The KEC will be responsible for the manufacture, supply, relocation and set-in-place and on-site commissioning of the entire ware washing and waste management system.
2. The KEC will be responsible to ensure that all these items function together as a complete and inter-related system, the entire system is fully operational and that all of the system sub-component parts are properly integrated.
3. The scrapping table will be used to disassemble patient/resident and cafeteria soiled meal trays, loading soiled meal service wares into 20" x 20" plastic dish machine racks and loading cutlery from flat racks into plastic type bins. It will also be used for source separation of organic and non-organic food waste materials, transfer of organic food waste to the waste decomposer, transfer of dish racks to the main dishwashing machine. KEC is required to interconnect the disposer on the dishtable to the waste decomposer.
4. The electrical circuit that provides power to the main system control panel mounted on the scrapping table must have electrical ground fault protection (GFI) protection.

1.4 MISCELLANEOUS

- .1 Supply and installation of all hardware and standard accessories normally part of the equipment whether shown and/or specified or not; ie locks, catches, handles, hinges, etc.
- .2 Provision of rubber button feet or pads under any piece of equipment that will rest on a counter.

- .3 Caulking and sealing of equipment to walls, curbs, bases, adjacent units and between any dissimilar materials. Use an approved silicone sealer for gaps under 0.33" and stainless steel trim strips and sealer for wider gaps. Prepare area being siliconed prior to silicone application.
- .4 Securing of all permanent equipment to floor or base. Use stainless steel shims for levelling.
- .5 Supply and installation of all stainless steel strips and filler pieces necessary to properly finish any individual or combined set of pieces of equipment as part of the contract.
- .6 Protection, identification and recessing of all controls, pilot lights, switches and valves on any item of equipment.
- .7 Provision of all necessary access panels within each piece of equipment to allow for proper maintenance and service. Allow access when two (2) or more units are adjacent to each other.
- .8 Supply of all standard equipment accessories normally furnished with all items specified whether indicated or not.
- .9 Provision of all inserts, bolts, anchors, sleeves, ferrules, sleepers and other assorted hardware as may be necessary for the proper anchorage, fixing or attachment of equipment to the building.
- .10 Verification of the dimensions and services of all pieces of equipment that may be supplied by the Owner but are to become a part of a unit specified under this work in order to ensure a proper fit and co-ordination of installation.

1.5 QUALITY ASSURANCE

- .1 The work of this section shall be executed by qualified Foodservice Equipment Sub-Contractors such as foodservice equipment dealer/custom stainless steel fabricator, manufacturer of prefabricated insulated walk-in type refrigerated and frozen room panels, foodservice refrigeration specialists, manufacturer of blast chillers, manufacturers of ware washing/waste management systems and conveyor systems.
- .2 If the Foodservice Equipment Sub-Contractor performing the work included in this specification is an equipment dealer only, the firm shall at the time of tendering, provide in writing the name, address and qualifications of the fabricator proposed for the manufacturing and installation of custom stainless steel equipment.
- .3 If the Foodservice Equipment Sub-Contractor performing the work included in this specification intends to further sub contract out any portions of the work they are to perform to another individual or firm including but not limited to research and development, design, sub-fabrication, stamping, sub-assembly, electrical wiring or controls and any parts or all of the installation, the name of the proposed individual or firm who the Foodservice Sub-contractor intends to further sub-contract work to, must be identified at the time of tender. No further subcontracting will be permitted after tender award without written authorization by the food service consultant.
- .4 If the Foodservice Equipment Sub-Contractor performing the work for the prefabricated insulated walk-in panels also proposes to supply the mechanical refrigeration systems, the firm shall at the time of tendering provide in writing the name, address and qualifications of the company proposed to supply and install the mechanical refrigeration systems.

- .5 No company will be considered for the supply and installation of the mechanical refrigeration systems without having a Local authorized service agency. At the time of tendering, the name of the authorized service agent for each and every component of the mechanical refrigeration system must be identified as well as the terms and conditions of the warranty.
- .6 Before submitting tenders, it is the responsibility of the bidder to carefully examine the drawings, specifications and the site to become aware of all existing conditions and limitations and to ensure that all of the work called for will be included in the tender submission.
- .7 All equipment and components supplied from manufacturers shall be the latest model or issue and shall be new and unused in every respect.

1.6 TENDER FORMAT

- .1 Comply with Division 1, General Requirements and all documents referred to therein.
- .2 Conform to the tender form provided at the end of this specification.
- .3 Submit an itemized price breakdown of the cost for each piece of equipment specified, including labor and materials. Separately indicate the total Sales Taxes if applicable and a separate cost for transportation, delivery, un-crating and setting into place.
- .4 Prices tendered shall be for the manufacturer as specified in the first instance for each piece of equipment listed in the item specification section and shall form a base stipulated price bid.
- .5 Prices tendered for the other acceptable manufactures as indicated in the item specification shall be included on a separate form and shown as either an addition to, or deletion from, the base stipulated price bid.
- .6 List the item number, name and quantity of each item together with the manufactures name and model number.
- .7 Failure to provide the itemized list of equipment with identification of the manufacturer, model number and individual price forming the base stipulated price bid will automatically disqualify the tender submission.

1.7 ALTERNATIVES AND SUBSTITUTIONS

- .1 Refer to Division 1 - General Requirements.
- .2 The specifications, drawings and mechanical and electrical services etc., have been prepared on the basis of the brand names and models identified in the first instance for each individual piece of equipment as listed in the item specification. The tender must include a base stipulated price bid for the foodservice equipment as specified in the first instance for each individual piece of equipment. Tenders which include any other brand or model other than what was specified in the first instance for any individual piece of equipment in the base stipulated price bid, will be automatically rejected.
- .3 Should the bidder elect to use one of the acceptable alternative manufactures listed in the item specification, he/she may do so by submitting an alternative price for this item together with the chosen manufacturer and model number etc. Acceptable alternative

manufacturers proposed for any equipment item must be listed on a separate page for "Acceptable Alternative Manufactures" located at the end of the tender form. Acceptable alternatives proposed, must indicate the addition to, or deletion from, the cost of the base stipulated price bid. The alternative price must also show and include the cost of all changes or modifications in the building necessary to accommodate the installation of the alternative item.

- .4 Alternatives proposed other than those listed in the specification as being acceptable alternative manufacturers may be submitted for review and consideration by the Owner and/or Consultant. These must be submitted in advance of the tender close and must be pre-approved in writing by the Owner and/or Consultant in order to be considered.
- .5 If an alternative other than those listed in the specification as being acceptable alternative manufacturers is proposed, the item must be submitted on a separate page included at the end of the tender form for "Other Pre-Approved Acceptable Manufactures" together with the chosen manufacturer and model number etc. Other pre-approved acceptable alternatives must indicate the addition to, or deletion from, the cost of the base stipulated price bid.
- .6 Alternatives proposed other than acceptable alternative manufacturers, must meet the physical and technical requirements of the specified item, be of a known and recognized manufacturer and satisfy the performance criteria and design intent originally determined by the Consultant in conjunction with the Owner.
- .7 Any alternative that is judged not to meet the above requirements, criteria or intent for whatever reasons shall be rejected and the model and manufacturer originally specified shall be supplied and installed at no additional cost to the Contract.
- .8 The proposed alternative and costs will be evaluated against the requirements set for the original specified manufacturer or model and a final decision made prior to the signing of a contract.
- .9 If any alternative is accepted, it is the responsibility of the respective Foodservice Equipment Sub-contractor to coordinate and bear all costs for mechanical, electrical, structural, architectural and any other adjustments necessary as a result of the substitution.
- .10 The Foodservice Equipment Sub-contractor awarded the work under Section 114000, shall also pay the costs of all professional fees and disbursements required to make necessary adjustments to the plans, specifications, mechanical and electrical requirement schedules or other information as a result of the substitution and for any coordination that must be done by the other project Consultants to accommodate any alternatives that are accepted.

1.8 REJECTION OF TENDERS

- .1 The Owner or Consultant reserves the right to reject any or all tenders without explanation.
- .2 The lowest tender in terms of cost, will not necessarily be accepted.
- .3 Tenders not conforming to any or all instructions may be rejected.

1.9 ADDENDA

- .1 The tender shall include any and all addenda that may change the original plans, specifications or other coordination information.

- .2 It is the responsibility of the bidder to report in writing any and all discrepancies, errors, omissions, contradictions or ambiguities to the Consultant. The necessary clarification will be issued in an addendum or bulletin to all bidders. If any uncertainty remains, base price on the most expensive interpretation.
- .3 The Owner, Food Service Consultant, Architects or Engineers will not be responsible for oral instructions.

1.10 CERTIFICATES OF APPROVAL

- .1 All work and materials shall be in accordance with the latest rules and/or regulations of agencies/ authorities having jurisdiction. All regulations, including building codes, and other codes applying to this jurisdiction should be followed. In addition, all equipment shall comply with the following:
 1. National Electric Manufacturer's Association, (N.E.M.A.).
 2. Underwriter's Laboratories Inc. (U.L.), must bear label.
 3. National Electric code, (N.E.C.).
 4. National Sanitation Foundation, (N.S.F.), must bear label.
 5. American Society of Mechanical Engineers must carry the (A.S.M.E.) stamp.
 6. American Gas Association (A.G.A.).
 7. Provincial and Local Health Department Requirements.
 8. American with Disabilities Act (ADA) as applicable to this project.
- .2 The Contract Documents shall govern whenever they require larger sizes or higher standards than are required by regulations.
- .3 The regulations shall govern whenever the Contract Documents require something which will violate the regulations.
- .4 When seismic regulations are applicable, all equipment shall be fabricated and installed in accordance with those regulations. All seismic requirements shall be shown on all submittals. Submit requested information to the agencies and authorities having jurisdiction.
- .5 No extra charge will be paid for furnishing items required by the regulations, but not specified and/or shown on the drawings.
- .6 Rulings and interpretations of the enforcing agencies shall be considered a part of the regulations.
- .7 The KEC is responsible to maintain the accuracy of equipment drawings and cut books to reflect as built conditions due to equipment deletions, manufacturer and/or model number changes and unanticipated changes to site conditions. It will be the KEC's sole responsibility to notify the Health Department having jurisdiction of all revisions until the project is issued its Certificate of Occupancy.
- .8 Conform to all laws, bylaws, rules, regulations and requirements of all authorities having jurisdiction.
- .9 All electrical equipment must conform to the National Electrical Code, the Electrical Inspection Department Bulletins, the National Electric Code. All equipment must have an approval label. Equipment that is not N.E.M.A. approved will be rejected, removed from the site and substituted for at no additional cost to the Contract.
- .10 Gas equipment shall conform to the A.G.A.

- .11 Any plumbing or drainage systems shall conform to the Local Plumbing Code.
- .12 Each piece of equipment shall be accompanied by a label or certificate of approval.
- .13 All mechanical refrigeration system shall be supplied with safety relief valves, shut-off valves for each piece of equipment and all other items as required by local regulations.
- .14 All welded pressure vessels shall be constructed to ASME Code. The vessels shall bear the stamp and certificates framed under glass and hung adjacent to the vessel.
- .15 Equipment design and fabrication must conform with the National Sanitation Foundation and Provincial as well as Local Municipal Health Department Regulations.

1.11 PERMITS

- .1 The General Contractor shall obtain and pay for all necessary permits, inspections and certificates and licenses required and necessary for the performance of the work and post all notices required by law and comply with all laws, ordinances and regulations bearing on conduct of the work as drawn and specified.

1.12 SHOP DRAWINGS AND MECHANICAL AND ELECTRICAL REQUIREMENTS

- .1 All fabricated items and assemblies of equipment shall be completely illustrated by shop drawings with detailed descriptions, clearly indicated methods of construction, gauges, assembly, fastenings and services, etc.
- .2 All shop drawings for this project shall use Metric Units.
- .3 Drawings prepared by the Consultant depict equipment design intent only. It is the responsibility of the foodservice equipment sub-contractor to prepare shop drawings in conjunction with the Consultants' drawings, specifications, mechanical and electrical data, details and other information. The KEC shall be responsible to coordinate all shop drawings with Architectural and Engineering plans, as built site conditions and the work of all relevant Sections.
- .4 Identify and explain any variation in the shop drawings that do not adhere to the original specifications or details. Advise the Consultant in writing of any conditions that would limit or adversely affect the design intent.
- .5 Ensure that all component parts and assemblies of each piece of equipment will support the loads anticipated without detriment to function, safety or appearance.
- .6 Prepare shop drawings on the same size sheet as plans and elevations, in a scale of not less than 1:1/4 for plans and 1:1/2 for details and sections so as to clearly illustrate the construction and arrangement of equipment.
- .7 Prepare fully dimensioned "roughing-in" and final connection point drawings for mechanical and electrical services. Separate mechanical and electrical, or combined drawings, may be submitted. In either case, drawings must be a minimum of 1:1/4. Include walk-in and fire suppression schematics and any pertinent installation diagrams including dimensioned "sleeving" drawing.

-
- .8 "Rough-in" and "final connection point drawings" must include a list of symbols for each type of connection and must show the location of connections on equipment as well as the location of the rough-in point for all mechanical and electrical services. Both connections to the equipment and the rough-in point must be dimensioned so as to show the relative distances from grid lines or architectural wall reference points as well as the height above the finished floor.
 - .9 Verify the energy requirements for any piece of equipment that is being supplied by the Owner or is existing and being reused. Incorporate this information into the shop drawings, "rough-in" and connection point drawings.
 - .10 Base, curb and depression drawings including low walls, cut-outs and openings must be fully dimensioned and drawn at 1:1/4 scale.
 - .11 Submit equipment data sheets and shop drawings in the following order:
 1. Catalogue cuts and illustrations.
 2. Plan lay out drawing with mechanical and electrical "roughing-ins" and "connection points"
 3. "Sleeving" drawing
 4. Base, curb and depressions
 5. Custom fabricated items
 - .12 Review of shop drawings is general and applies to design only, it is not intended to serve as a final check and shall not relieve the KEC of the responsibility for errors in dimensions, quantity, material or interfacing as required to complete the intent of the design.
 - .13 All shop drawing submissions shall be checked and signed by a senior member of the firm qualified to evaluate the function and construction necessary.
 - .14 The Consultant reserves the rights to reject any submissions that do not comply with the standards noted herein.
 - .15 After the drawings have been reviewed, provide the number of sets required by the Consultant for distribution. Do not proceed with the fabrication until the drawings have been reviewed by the Consultant.
 - .16 Prior to manufacture, the Foodservice Equipment Sub-Contractor shall provide a schedule outlining the proposed manufacture and installation dates for all equipment.
 - .17 The KEC shall be responsible to keep one (1) copy of the reviewed shop drawings on the project job site in good order available to all consultants approved.
 - .18 Examine the drawings and specification of all Sections for any information that may affect this work and co-ordinate the architectural and service requirements with other appropriate contractors.
 - .19 Submit one copies of each shop drawing, quantity of shop drawings to be provided as required by General Contractor.
 - .20 All shop drawings must be prepared using Revit or AutoCAD. Hand drawn shop drawings will be automatically rejected without review and returned to the Foodservice Equipment Sub-contractor.

- .21 The Consultant will only perform one (1) subsequent review of re-submitted shop drawings that have been rejected. If shop drawings are rejected in whole a second time, the Consultant will proceed to prepare the shop drawing and the costs including fees and disbursements will be deducted from the KEC contract amount.
- .22 "Rough-in" and connection point drawings will not be reviewed unless the catalogue cuts and illustrations are submitted first.

1.13 CATALOGUE CUTS AND ILLUSTRATIONS

- .1 All manufactured items being purchased by the Foodservice Equipment Sub-Contractor must be illustrated by catalogue cuts and data sheets.
- .2 Submit two (2) sets of illustration/cuts bound in booklet form for review. Sheets are to be in numerical order, properly labelled with the name of the project and accompanied by a lead sheet with an itemized list of contents. The lead sheet must include the project name, the name of the General Contractor (if applicable), the name of the KEC, the item number, the manufacturers name and model number, all options and accessories included as well as mechanical and electrical service requirements (see typical example provided).

BROCHURE LEAD SHEET (typical information required)	
ITEM NO: _____	QUANTITY: _____
DESCRIPTION: _____	
MANUFACTURER: _____	
MODEL NUMBER: _____	
SERVICES;	
ELECTRIC: _____ VOLTS, _____ PHASE, _____ WATTS, _____ KW _____ AMPS	
NEMA PLUG CONFIGURATION: _____	
PLUMBING: _____ NPT (HW) _____ NPT (CW) _____ I.W., _____ WASTE	
STEAM: _____, (INLET) _____ (CR), _____ PSI	
GAS: _____ BTU, (NATURAL) (LP)	
ACCESSORIES, ATTACHMENTS OR REMARKS:	
1. _____	
2. _____	
3. _____	
4. _____	

- .3 Ensure that the equipment suits the space allocations and the intent of the design.
- .4 After the illustrations have been reviewed, provide the required number of sets for distribution.

1.14 DESIGN DRAWINGS AND SITE DIMENSIONS

- .1 In addition to preparing shop drawings illustrating custom fabricated equipment or assemblies, the Foodservice Equipment Sub-contractor shall be responsible to prepare a set of final plan layouts of the foodservice equipment included. These final plan layouts are to include:
 - 1. 1:50 final plan drawings, on Revit or AutoCad version 2022 or later;
 - 2. Finalized itemized list of food equipment by component and functional area indicating item number, quantity, manufacturer, model number, etc. for all new and relocated existing equipment;

3. Detailed schedule of the mechanical, electrical and structural requirements for new and re-used existing equipment with connection size information; and
4. Depression and curb layout drawings.

PART 2 PRODUCTS

2.1. COMMERCIALY MANUFACTURED EQUIPMENT

- .1 All items of standard equipment shall be the latest model at time of delivery.
- .2 Manufacturer's directions shall be followed in cases where the manufacturers of articles used in this contract furnish directions or prints covering points not shown on the drawings or specifications.
- .3 All doors shall be hinged as shown on plans.
- .4 Refrigerated Items
 1. All reach-in refrigerators and freezers with remote refrigeration systems shall be complete with condensate evaporator when no floor drain is available.
 2. When a condensate evaporator is required, it shall be complete with thermostatic expansion valves at the evaporator.
 3. Refrigerated drawer units are to be provided with stainless steel drawer liners and stainless steel full size pans. KEC to furnish each drawer with two (2) 12" x 20" x 4" deep 18 ga. stainless steel pans.
 4. When a removable plate rail/cutting board is specified for an equipment stand, the KEC is to coordinate cutting board support locations with work top cooking appliances to provide access for operations and service.
 5. The refrigerant for medium and Low Temperature fixtures to be CFC free and conform to the Montreal Protocol Agreement.
 6. All refrigerated fixtures are to be provided with a flush mounted exterior dial thermometer.
 7. All refrigeration Systems to be provided with 5 year compressor warranty and 1 year service agreement.
 8. Doors on refrigerated fixtures are to be provided with cylinder door locks unless specified with an alternate locking devise.
- .5 Free-standing work tables and counters with flanged feet shall be secured to the floor with smooth head stainless steel fasteners or with pins concealed in all legs of the table/counter, when specified or required by code.
- .6 All equipment units that "pass thru" wall openings are to have an "equal" finish on front and rear. The intent is that the equipment unit will project a finished "look" on the rear (kitchen side) as on the front (customer side).
- .7 Provide water treatment units/systems (including surge tanks) for installation by the Plumbing Division suited to the application and anticipated volume for items "in contract" and those units provided "by vendor", "by product supplier" or "by owner" as follows:
 1. Postmix beverages:
 - a. low to medium volume - Everpure High Flow Twin MC p/n 9328-02
 - b. high volume - Everpure High Flow Triple p/n 9328-03
 2. Coffee:
 - a. low to medium volume - Everpure E-10 prefilter with QC4-BH cartridge (can be mounted undercounter)
 - b. high volume - Everpure E-20 prefilter with Twin head/MH cartridges

3. Ice makers:
 - a. less than 500#/day - Everpure Insurice Twin PF p/n 9324-22
 - b. less than 1000#/day - Everpure Insurice Triple PF p/n 9325-23
 - c. greater than 1000#/day - Everpure E-20 prefilter and Insurice 4000 quad
4. Combination:
 - a. less than 3 gallons per minute (gpm) - Everpure High Flow Triple CSR 9328-06
 - b. less than 5 gpm - Everpure High Flow Quad 9437-10
 - c. greater than 5 gpm contact representative 516 250-2200
5. Steam (boiler only):
 - a. countertop and floor steamers less than 1gpm - Everpure E-20 prefilter with Kleensteam 9797-00
 - b. flow rates less than 2 gpm - Everpure High Flow CSR Twin
 - c. flow rates less than 3 gpm - Everpure High Flow CSR Triple 9328-06
6. Provide wall mounted rack per detail C-19-4 when surge tank is wall mounted. Provide properly sized stainless steel pedestal to support surge tank when the surge tank is floor mounted.

2.2. FOODSERVICE EQUIPMENT FLEXIBLE CONNECTORS

- .1 The KEC shall provide all counter top coffee brewing and dispensing equipment (hot and/or cold water), with Dormont Swirl (retractable) hose with quick disconnect 2-way coupling. This includes equipment "in contract" and those items "by vendor", "by product supplier" or "by owner". Service length to be sufficient to attach properly to the food service fixture.
- .2 The KEC Contractor shall furnish the following cooking appliances with appropriately sized (length and diameter) flexible connectors, coiled restraining devices and installation hardware, as indicated below:
- .3 Gas Appliances (Mobile) Dormont Model BPQ-2SR Series flexible connector with two (2) Supr-Swivel couplings and one (1) coiled restraining device with installation mounting hardware.
- .4 Gas Appliances (Stationary) Dormont Model BPQ-2S Series Flexible Connector with two (2) Supr-Swivel couplings.
- .5 Stationary/Mobile Appliances other than Counter-Top Dispensing Units with Water Connections (hot, cold) Dormont Model W-BP2Q Series flexible connector. When mobile, provide unit with coiled restraining device with installation mounting hardware.
- .6 Steam appliances (stationary or mobile) Dormont model BIP-2Q Series flexible connector. When mobile provide unit with coiled restraining devices with installation mounting hardware.
- .7 Length restraining device on mobile units to be sufficient to allow movement of equipment for housekeeping.
- .8 Flexible connectors to be NSF and AGA certified.
- .9 Division 23 00 00 shall connect all quick-disconnect hoses to equipment.

2.3. FIRE SUPPRESSION SYSTEMS – NOT APPLICABLE

2.4. BUY OUT EQUIPMENT

.1 The following is a list of standards for all “buy out” equipment:

1. The intent is that exposed metal surfaces of buy-out equipment units have a
2. Stainless steel finish except where the model number of the unit dictates aluminum. For those items where stainless fronts, tops, rears and sides are “optional” we expect that a stainless finish will be provided in those areas where the finish is exposed.
3. All range units if not provided with a rear riser as a standard component by the manufacturer are to be provided with a stub back (min.).
4. Provide any/all stacking/mounting kits as may be required per the manufacturers recommendations for stacking equipment units together (for example: ice makers positioned on top of soda/ice dispensers), built-in/drop-in units into custom fabricated fixtures, etc.

2.5. PLUMBING WORK

- .1 Provide suitable pipe slots, chases and/or do all drilling, punching and cutting of equipment required to provide access for Division 23 00 00 connections and/or runs. Such work performed at the job site shall be of the same quality as similar work in the shop.
- .2 To insure proper clearance for cleaning, all horizontal piping lines shall be run at the highest possible elevation and not less than 6" above floor, through equipment wherever possible.
- .3 Indirect waste piping (except from sinks and ventilators) shall be installed in accordance with the codes in effect at the job site. Piping shall run as described hereinafter, and shall discharge into floor sinks. Extend piping to a point of at least 2" (50 mm) above rim of floor sink and cut bottom on 45 degree angle. All indirect waste piping shall be installed and routed in a manner to insure proper drainage and shall conform with shelves, spaces, equipment or building conditions. Secure all indirect waste piping as required to achieve same. Indirect waste piping from ice bins, ice pans and similar items shall be insulated to prevent condensation.
- .4 Water inlets shall be located above the positive water level to prevent siphoning of liquids into the water system. Wherever conditions shall require a submerged inlet, a suitable type of check valve and vacuum breaker shall be placed on the fixture to form part of same to prevent siphoning.
- .5 Where exposed, piping and fittings shall be chrome plated.
- .6 All valves shall be American made to insure availability of replacement parts.

2.6. FAUCETS

- .1 Low flow faucets shall be furnished on all sinks, bain maries, water stations and other fixtures as specified and shall be supplied with non- splash aerator, and water saving devices where required by local codes. Unless otherwise specified, faucets shall be provided as follows, for installation by Division 23: (Note: All faucets to be from the same manufacture).

Type 1: Faucet (1/2 Splash)
 Fisher Model 3251 (8" Spout)

Type 2:	T&S Model B—0231 with #60 x (8" Spout) Faucet (3/4 Splash) Fisher Model 5414 (14" Spout)
Type 3:	T&S Model B-0290 (12" Spout) Faucet (1/2 Deck) Fisher Model 3311 (8" Spout)
Type 4:	T&S Model B-1121 (8" Spout) Faucet (3/4 Deck) Fisher Model 5314 (14" Spout)
Type 5:	T&S Model B-0293 (12" Spout) Faucet (1/2 Deck) Fisher Model 1821 (Gooseneck)
Type 5A:	T&S Model B-1142 (Gooseneck) Faucet (1/2 Splash) Fisher Model 1945 (Gooseneck)
Type 5B:	T&S Model B-0331 (Gooseneck) Faucet (1/2 Deck) Fisher Model 3525
Type 6:	Faucet (1/2 Deck) Fisher Model 3010 (INDEX HOT)
Type 7:	T&S Model B-207 (INDEX-HOT) Pre-Rinse Faucet (1/2 Splash) Fisher Model 2210-WB
Type 7A:	T&S Model B-133B W/Wall Bracket Pre-Rinse Faucet (1/2 Deck) Fisher Model 2310-WB
Type 8:	T&S Model B-0113 W/Wall Bracket Fill Faucet (1/2 Wall) Double Jointed Swing Sprout Chicago Model 515 (INDEX COLD)
Type 9:	T&S Model B-592 Dipperwell & Faucet Fisher Model 3041
Type 10:	Component Hardware Model K27-1010 Water Fill Faucet & Drain Pan Fisher Model 1400
Type 11:	Component Hardware Model K27-1000 Pre-Rinse Add On Faucet Fisher Model 2901 add-on faucet.
Type 12:	T&S Model B- 155 ADD-ON-FAUCET Glass Rack Fill Faucet (1/2 deck- hot/cold water) Fisher Model 1117-WB with #82104
Type 13:	Single Deck Dual Control Valve Not Assigned
Type 14:	Faucet (1/2 Deck) Fisher Model 3525 (Gooseneck)
Type 14A:	T&S Model B-1141 (Gooseneck) Faucet (1/2 Splash) Fisher Model 1996 (Gooseneck)
Type 14B:	T&S Model 1146 (Gooseneck) Faucet (1/2 Deck) at Fabricated Hand Sink Located in Worktop Fisher Model 3526 (Gooseneck)
	T&S Model B-1141 with #120x Rigid Gooseneck & #B-0413 Adaptor

- Type 15: Faucet (1/2 Deck) at Fabricated Hand Sink Located Below Worktop
T&S Model -0202
- Type 16: Fill Faucet (1/2 Wall) at Range Spreader
Fisher Model 3710 (INDEX COLD)
T&S Model B-0212 (INDEX COLD)

2.7. DRAINS AND WASTES

- .1 Furnish all necessary drains and wastes with the equipment as follows:
 - Type 1: Drain (1-1/2" & 2") - Rotary handle without overflow, flat strainer. Fisher Model 28932
 - Type 2: Drain (1-1/2" & 2") - Basket Strainer without overflow, basket strainer. Fisher Model 28983.
 - Type 3: Drain (1-1/2") - Drain with standpipe. Fisher Model 6541-2400 waste socket, 6550-2100 lock nut, 6580-5000 tail piece and 6571 standpipe (length as required)
 - Type 4: Drain (1") - Drain with standpipe. Fisher Model 6240-2100 waste socket with 6280-5000 washer, 6250-2100 lock nut and 6271 standpipe (length as required).
 - Type 5: Drain (1-1/2") - Open. Fisher Model 6541-2400 waster socket, 6550-2100 lock nut, 6580-5000 washer and 6544-0000 tail piece.
 - Type 6: Drain (1-1/2" & 2") - Rotary handle with overflow, flat strainer. Fisher Model 28940 (verify length and height of overflow assembly with sink size).
 - Type 7: Drain (1-1/2" & 2") - Rotary handle with overflow and basket strainer. Fisher Model 28959 (verify length and height of overflow assembly with sink size).
- .2 All rotary wastes/lever wastes are to be provided with a # 14 ga. stainless steel valve bracket located a sink bowl front. Refer to Detail C-8-5 for construction.
- .3 KEC to coordinate plumbing interconnections at field joints, completed by Division 23, on equipment assembled at the job site.

2.8. FLOOR TROUGHS

- .1 When specified, floor troughs are to be properly dimensioned on the KEC building works rough-in plan. Careful coordination is required so that trough grate removal is unobstructed by adjacent equipment units. Further, where troughs are specified in front of tilting units (braising pans, kettles), the equipment is to be placed so that the center of the pour path on the tilting unit aligns with the center line of the trough.

2.9. ELECTRICAL WORK

- .1 For all fabricated equipment, furnish and install all outlets, switches, controls, conduit, service fittings and load centers. Load centers shall be complete with individual "visi-trip" circuit breakers for each device built into or forming an integral part of the unit. Furnish to Division 26 a wiring schematic including circuit breaker diagram for load center.
- .2 Ensure that all equipment furnished under this contract shall be so wired, wound or constructed as to conform with the characteristics of electrical and other services at the premises.

- .3 Appliances shall be new, of manufacturer's current production and furnished complete with motors drive mechanism, Starters and controllers, including master switches, timers, cut-outs, reversing mechanism and other electrical equipment if and as applicable. Wiring and connection diagrams shall be furnished with electrically operated machines and for all fabricated equipment.
- .4 Only rigid steel conduit shall be used, zinc coated where unexposed and chrome plated where exposed. All conduit wiring shall be run concealed wherever possible. Conduit shall be continuous from outlet to outlet and from outlet to load center circuit or pull boxes and shall enter and be secured in such a manner that each system shall be electrically continuous throughout. All conduits shall be thoroughly and substantially supported by accepted industry practices.
- .5 Supply on each motor driven appliance or electrical heating unit, a suitable control switch or Starter of proper type wherever such equipment is not provided with same.
- .6 All plug-in equipment shall have plugs and neoprene cords furnished and installed. Coordinate work with Division 26 so that the receptacles provided will match the specific plugs installed as part of the plug-in equipment. Any changes on cords and plugs required in the field due to lack of coordination between Division 26 and KEC shall be the latter's responsibility.
- .7 All surface mounted receptacles indicated for fabricated equipment are to have Component Hardware Group, Inc. model R58-1010 or R58-1029 or equal aluminum box complete with satin finish stainless steel cover and receptacle as indicated below:
 1. 2-pole, 3-wire grounding 20 amp; 125V. Hubbell #5352 or equal (NEMA 5-20R).
 2. 2-pole, 3-wire grounding 20 amp; 250V. Hubbell #5461 or equal (NEMA 6-20R).
 3. 2-pole, 3-wire grounding 30 amp; 250V. Hubbell #9330 or equal (NEMA 6-30R).
- .8 All built-in receptacles indicated for fabricated equipment are to be 2" x 4" x 1-1/2" deep "Handy Box" tack welded to fixture and fitted with receptacle indicated above and satin finish stainless steel cover. Splash mounted receptacles to be horizontal with all others vertical.
 1. 30 AMP, 250 V receptacles require a 2-1/8" deep "Handy Box". If splash mounted, increase splash width to 2-1/2".
- .9 All switches, controls, etc., shall be conspicuously labeled as to use with phenolic plastic name plates screwed to adjacent surfaces, with white recessed lettering on black background. Submit a sample to the Designer for approval.
- .10 All electrically heated, fabricated equipment shall be internally wired to a thermostatic control and an "on/off" red neon light indicator, both to be mounted in a terminal box with a removable access panel and located outside the heated area. Wiring to be nickel-plated copper, properly insulated.
- .11 All cold storage room electrical components shall be provided with conduit, splice boxes, switches, fittings, etc. concealed within the insulated panels at time insulation is foamed in place. Conduit shall extend up within wall panels, through ceiling panels ready for EYS fittings and final connection by Division 26 00 00.
- .12 Provide all incandescent bulbs and fluorescent tubes required for equipment under this section. Fluorescent tubes, for food service display equipment, to be high natural colour fluorescent lamp "Colour-Gard 50" as manufactured by Duro-Test Corporation 1-800-937-0900 ext 7020 (or equal).

- .13 KEC to coordinate electrical interconnections, completed by Division 26, at field joints on equipment assembled at the job site.
- .14 All wiring within custom fabricated counters and tables to be concealed. Wiring To heat lamps and display lighting (Part of food shield assembly) to be concealed.

2.10. FOOD SERVICE EQUIPMENT (COMMERCIAL & FABRICATED)

- .1 Lamps
 - 1. KEC shall furnish all lamps as recommended by the manufacturer, or as specified, required for all food service equipment light fixtures. Lamps will be installed by Division 26.
- .2 Cutting Boards
 - 1. All cutting boards provided for “buy-out” and custom fabricated equipment to be manufactured by Richlite. For custom fabricated application provided the size and thickness as indicated in the documents. For “buy-out” items provide same size and thickness as would otherwise be provided by the manufacturer of the “buy-out” item.

2.11. MOUNTING HEIGHTS FOR FOOD SERVICE EQUIPMENT

- .1 Wall Shelving
 - 1. Wall and table mounted shelves are to be mounted at appropriate height and provide clearance to accommodate table top equipment and provide convenient access to items stored. Coordinate mounting height with Owner’s representative prior to installation.
- .2 Fire Suppression System
 - 1. Fire Suppression System tank/control cabinet to be mounted tight to finished ceiling at location shown on plan.

2.12. VENTILATION WORK – NOT APPLICABLE

2.13. FABRICATED EQUIPMENT

- .1 All specially fabricated equipment must be by one manufacturer acceptable to Designer and the Owner.
- .2 All work must be done in an approved workmanlike manner to the complete satisfaction of Designer and the Owner.
- .3 All stainless steel shall be the U.S. standard gauge, 18-8, type 304, finish as noted in paragraph 2.05N.
- .4 All galvanized steel shall be electro-galvanized.
- .5 All seams and joints shall be shop welded or soldered as the nature of the material may require. Welds to be ground smooth and polished to match original finish.
- .6 Framework of galvanized steel shall be welded construction. Where galvanizing has been burned off, the weld shall be touched up with high grade aluminum paint.

-
- .7 The underside of all metal top tables, counters, drainboards, sinks and dishtables shall be provided with sound deadening material similar to Component Hardware Model Q85-5225 Tacky Tape; 3/4" wide x 3/32" thick strips. Spray or painted material or exposed mastic will not be acceptable.
- .8 Metal Top Construction
1. All seams and joints shall be one-piece welded construction, reinforced on the underside with galvanized steel secured to top with weld studs and stainless steel or chrome plated cap nuts so tops can support heavy weight without deflection. Cross braces to be not more than 48" (1200 cfm) on center.
 2. Tops supporting coffee urns, ice/soda dispensers, Etc...shall have additional bracing to support the heavy loads.
 3. Field joints in stainless steel tops; where required due to limitation of sheet sizes, equipment sizes or installation requirements shall be welded, ground smooth and polished to blend with adjacent surfaces.
 4. If inverted hat sections are used in lieu of channels, close ends.
 5. Stainless steel counter tops and overshelves exposed to heat shall be properly braced to maintain level work surfaces and to prevent warping.
- .9 Fasteners
1. Exposed bolt heads will not be permitted on fixtures.
 2. Butt joints made by riveting straps under seams and then filled with solder will not be accepted.
 3. Rivets of any kind, including pop-rivets, will not be accepted.
 4. Exposed screw heads, when necessary, shall be countersunk flush.
 5. Exposed fasteners shall be one of the same material and finish as the pieces held in place.
 6. Exposed bolt ends not permitted. Chrome plated hexagon type cap nuts to be provided on all exposed bolt ends.
- .10 Rolled edges shall be as detailed with corners bullnosed, welded, ground and polished.
- .11 Corners of dishtables, drainboards, splashbacks and turned up edges shall have 1/2" (15 mm) or larger radius bends in all horizontal and vertical corners, coved at intersections unless specified otherwise.
- .12 Enclosed Cabinet Bases shall be made of 18 gauge stainless steel sheets reinforced by forming the metal. Sides and partitions shall terminate at front in a 2" (50 mm) wide fully enclosed mullion and welded at intersections. Shelves are to be removable where detailed. Exposed ends, partitions and shelves are stainless steel.
- .13 KEC to coordinate size, quantity and location of louvered openings for sufficient ventilation of food service equipment.
- .14 Legs and Cross Rails
1. Equipment legs and cross rails shall be 1-5/8" (40 mm) 16 gauge stainless steel tubing unless otherwise noted. All welds at cross rails shall be continuous and ground smooth. Tack welds are not acceptable. Tops of legs to be fitted with Component Hardware Model # A20-0206 16 gauge stainless steel gusset or approved equal. Gussets are to be secured as hereinafter described to fixtures.
 2. Sinks - weld gussets to triangular 12 ga. stainless steel gusset plates, which are in turn welded to underside of sinks.

3. Tables and Dishtables - to metal top tables and dishtables with gussets which shall be welded to reinforcing channel/hat sections 14 gauge or heavier.

.15 Wood tops:

1. Welded stainless steel hat sections to support top and be held in place with stainless steel metal screws in slotted holes of flanges.
2. Bottom of legs to be fitted with Component Hardware Model # A 10-0851 with locking ring adjustable stainless steel foot or approved equal. Foot plug to be welded, ground and polished. When flanged feet are specified, use Component Hardware Model # A-10-0854 adjustable stainless steel foot or approved equal.
3. Enclosed cabinet bases mounted on 6" (150 mm) high legs are to be equipped with Component Hardware Model # A52-9907 adjustable stainless steel counter legs or approved equal.

.16 Metal Gauge

1. Unless otherwise noted in itemized specification or details, all gauges to be manufactured to the following minimum thickness:

Stainless Steel USS Gauge	Decimal Thickness	Millimeter Thickness
12	.1094	2.78
14	.0781	1.98
16	.0625	1.59
18	.0500	1.27
20	.0375	0.95

.17 Materials

1. All fabricated items to be provided in gauge, metal type and finish per the following table.

Description	Gauge	Metal	Finish No.
Dishtable, Table and Counter tops	14	S.S	4
Hat Sections/Channel:			
Unexposed	14	Galvanized	4
Exposed	14	S.S	4
Counter Body:			
Framework	14	Galvanized	
Aprons, Partitions, Backs and Ends	18	S.S	4
Shelves (Intermediate)	18	S.S	4
Shelves (Base Shelf)	16	S.S	4
Refrigerators			
Interiors	20	S.S	2B
Doors			
Outside Faces	18	S.S	4
Inside Faces	20	S.S	2B
Drawer Pans			
General	18	S.S	2B
Plastic		Uniroyal "Royalite" Series	

	Refrigerated Shelf	18	S.S	2B
	Wall Mounted Fixture Mounted Table	16	S.S	4
	Refrigerator Shelf Bracket (Exposed)	16	S.S	4
	Ventilators & Hoods		S.S Wire	
	Exterior Frame	14	S.S	4
	Interior Plenum	18	S.S	4
	Ducts	16	S.S	4
	Unexposed Exposed	16	Galvanized	Weld
	Dishmachine	16	S.S	4-Weld
	Wall Flashing	18	S.S	4-Weld
	Equipment Legs & Cross Rails	20	S.S	4
		16	S.S Tubing	4
.18	Closure			
	1. Return backsplashes, when exposed to have enclosed finished rear.			
	2. Exposed backs of all equipment, fixtures, back splashes, shelves, etc., shall be closed.			
	3. Exposed backs of counter top equipment in an island configuration will be provided with a full height stainless steel enclosure to conceal utility connections.			
	4. Where the rear of a piece of equipment placed in a wall opening is exposed and unfinished, the KEC will provide a finished rear.			
	5. Provide finished stainless steel on exposed rear of all equipment units.			
.19	Casters shall be Colson Caster Corp. Series 2, or equal, non-marking, ball bearing NSF approved type with greaseproof polyurethane tires, Wheels shall be 5" (130 mm) diameter. Minimum width treads of 1-1/4" (30 mm). Minimum capacity per caster 250 lbs. (115kg). Where a set of four casters is specified, two are to be provided w/ brakes.			
.20	Fabricated sinks shall have corners same as for metal tops. One piece welded construction with bottom pitched to drains and double wall partitions (see standard detail C-8-5 & C-8-8). Multiple compartments shall have continuous and seamless flush front exteriors. Openings between compartments or applied panel will not be accepted. Sink insets shall be 14 gauge stainless steel welded as integral part of top.			
.21	All drawer pans shall have all corners coved. Pan to be mounted on fabricated 14 gauge stainless steel angle cradle frame. Frame to be supported on Component Hardware Model S-52 or approved equal full extension slides with 200 lbs. (91 kg.) capacity per pair. Pan to be easily removable without the use of tools. Drawer fronts shall be double pan type with sound deadening material. Drawer shall be self-closing.			
.22	Doors			
	1. All metal doors to be double pan type reinforced and stiffened to prevent flexing and filled with sound deadening material.			
	2. Sliding doors shall be mounted on large ball bearing quiet rollers in 14 gauge stainless steel overhead tracks and be removable without the use of tools. Sliding doors shall be self-closing.			

-
3. Hinged doors shall be flush type, mounted on heavy duty, stainless steel, lift-off hinges.
 4. Door catches shall be heavy duty, 4 way (mortise or surface application) with adjustable spring loaded ball tension, Model M22-2430 as manufactured by Component Hardware Inc. or equal.
- .23 All hardware shall be of heavy duty construction and identified on shop drawings by manufacturer and model number and shall be subject to final approval by Designer. All hardware shall be identified with manufacturer's name and number so that broken or worn parts may be replaced.
- .24 Breaker Strips - all ice pans, ice bins, refrigerated pans, hot food, Bain Marie pans and cabinets shall be provided with breaker strips where adjoining top or cabinet face materials to prevent condensation. Breaker strips shall be fastened with stainless steel, counter sunk screws. Pop rivets will not be accepted.
- .25 All insulation shall be board form or foamed-in-place polyurethane. Fiberglass insulation shall not be used. Heated areas shall have minimum of 1" thick at sides and 2" thick at bottom. Cold areas shall be thickness indicated on details or drawings. Insulation shall be bonded to all surfaces.
- .26 Refrigerated Items
1. All reach-in refrigerators and freezers with remote refrigeration systems shall be complete with condensate evaporator when no floor drain is available.
 2. When a condensate evaporator is required, it shall be complete with thermostatic expansion valves at the evaporator.
 3. Fabricated compartments, refrigerated shelves, plates, etc., shall be provided with a 20 gauge steel box to house expansion valves when valve is remote from evaporator. Install in base of fixtures or in a concealed position.
 4. All refrigerated compartments shall be fitted with a flush mounted exterior dial thermometer with chrome-plated bezels. Thermometers shall be adjustable and shall be calibrated after installation.
 5. Refrigerator hardware for fabricated refrigerator compartments shall be heavy duty components. Hinges shall be self-closing. Latches to be magnetic edgemount type with cylinder lock unless specified or noted.
 6. Refrigerated drawer units are to be provided with stainless steel drawer liners and stainless steel full size pans. KEC to furnish each drawer with two (2) 12" x 20" x 4" deep 18 ga. stainless steel pans.
 7. When a removable plate rail/ cutting board is specified for an equipment stand, the KEC is to coordinate cutting board support locations with work top cooking appliances to provide access for operations and service.
 8. The refrigerant for medium and LOW TEMPerature fixtures to be CFC free and conform to the Montreal Protocol Agreement.
 9. All refrigeration systems to be provided with 5 year compressor warranty and 1 year service agreement.
- .27 Louvered Shelving - at location of three (3) compartment or pot wash sinks, wall shelving to be louvered to facilitate drainage and air drying. Construction of shelving to be the same as solid shelving as noted under 2.05M. See standard detail.
- .28 Flanged Feet Pinned to Floor - free-standing work tables and counters with flanged feet shall be secured to the floor with smooth head stainless steel fasteners or with pins concealed in all legs of the table/counter when specified.

- .29 Backsplash "Returns" - backsplashes on tables and counters are to be returned at the sides where adjacent wall, columns and other equipment to match the dimension of the adjacent element.
- .30 Wall Flashing to include Component Hardware Model # J64-1450 divider bars and Model # J-63-1451 cap strips as required. No exposed fasteners will be accepted.
- .31 Protection of Tops/Shelves - in order to protect finishes of fabricated items, all exposed horizontal surfaces of counter, tables & shelves are to be covered with cardboard & held in place with duct tape until such time that the work of related trades is complete.
- .32 Adapter Bars - provide a full complement of adapter bars for "buy-out" and "custom fabricated" equipment units where adapter bars are necessary to optimize storage. Provide maximum number of adapter bars based on the smallest pan size to be used.
- .33 Integration of "Buy Out" Item's - custom Fabrication integrated with "buy out" items must satisfy the recommendation of the manufacturer of the buy out item for clearances, tolerances, ventilation, etc. Modifications to custom fabrication to satisfy these manufacturer's recommendations will be at the expense of the custom fabricator.

2.14. MILLWORK/CASEGOODS

- .1 Work is to be performed by skilled mechanics of the trade and is to be of the highest quality throughout, in such a manner as to fulfill the intent of the Contract Documents.
- .2 All fixtures are to be made by one manufacturer and assembled in single and complete units, as the dimensions will permit shipment to and installation at the building. Large pieces requiring sectional construction are to have their parts accurately fitted and aligned with each other, and provided with ample screws, glue and bolt blocks, tongues, grooves and splines, dowels, mortises and tenons, screws, bolts or substantial, rigid and permanently secured in proper position to each related section.
- .3 Sufficient additional material is to be provided to permit accurate scribing to walls, floors and related work, and allowance made wherever possible for shrinkage that may develop after installation. All units are to be provided with adequate cleating, blocking, crating and other forms of protection as necessary to prevent damage during shipping and handling.
- .4 All fixtures are to be assembled without face screws or nails, except where it may be necessary to attach trim items. All face screws or nails that are necessary are to be countersunk and plastic wood or wood plugs used to cover heads, and the plug neatly touched up. The heads of all screws used in any assembly are to be countersunk below the surface.
- .5 Joints – Mortise and tenon, spline, dowel and/or pin block and glue work to avoid use of nails wherever practical. Make butt joints with an approved device for prevention of separation of members. Blind nail and conceal.
- .6 Plastic laminate is to be bonded to all exposed surfaces with contract cement fast bond EC2166 as manufactured by 3-M Products Company, or equal, to minimum 3/4" (19MM) fir faced plywood applied under high pressure. All edges shall be carefully sanded to smooth finish, removing burns, nicks and cut marks. Plastic laminate joints are to be finished without wavy and unsightly joints.
- .7 Where solid core/monolithic tops are specified i.e. Nevamar Fountainhead or equivalent, such materials are to be installed by factory certified installers only.

- .8 Hinged doors are to be fabricated of ¾" (19mm) thick plywood with hardwood full perimeter edging with plastic laminate on face and self-edging on exposed sides. Door hinges, pulls and catches shall be supplied and installed as specified.
- .9 Sliding doors are to be fabricated of solid core plywood with hardwood edges and constructed similar to hinged doors. Doors are to be mounted on E-Z Glides track, and to be removable without the use of tools. Rubber stops are to be provided concealed in end stile or mullion.
- .10 Tambour sliding doors are to be fabricated of individual hardwood slats, 3/8" x 3/4" (10 x 20mm), round on 2 edges and glued to 20 ounce duck canvas or reject elastic vinyl plastic or equal and be provided with hardwood end stile with integral door pull. Track to be lined with laminated plastic or equally smooth surface and guides at top and bottom to be fabricated hardwood. Provide lock-pin for sliding doors.
- .11 Any access panel is to be fabricated of ¾" (19mm) nominal thick hardwood and fabricated as a door. Each access panel to be provided with two (2) magnetic catches at top and two (2) 3/16" (5mm) positioning pins at bottom.
- .12 Drawer sides and backs are to be constructed of 5/8" (16mm) thick solid hardwood such as ash, oak or maple, or 5/8" (16mm) finished birch interior plywood without plugs or defects. Sides to be French dovetailed into fronts, with backs lock-shouldered into sides. Drawer bottoms to be 1/4" (6mm) tempered hardboard, dadoed into sides. Provide pulls as specified. The inside surfaces of all drawers shall receive one coat of Penetrating Primer and one coat of Glass Lacquer.
- .13 Drawer fronts to be 3/4" (19mm) thick, 5-ply veneer core construction, with veneer banded top edge to match face. Ends to be puttied, sanded and glazed to match top edge. All drawers to be provided with full extension glides.
- .14 Painted finishes to have exposed surfaces free from defects and blemished that would show after being finished, regardless of grade specified. All surfaces specified to receive a paint or enamel finish are to receive one cross-coat of lacquer type undercoat. After the undercoat has been thoroughly dried, surfaces are to be sanded smooth and two coats of enamel is to be applied. Back painting is to be provided for all cabinet and woodwork prior to installation.
- .15 Interior shelves are to be laminated and provided with self-edging on all sides.
- .16 Where required by code, all required materials are to be treated with fire retardant chemicals to achieve the required flame spreading performance rating. Retardant chemicals must be a type approved by local authorities.

2.15. SOLID SURFACE

.1 FABRICATION

- 1. Material: Homogeneous filled acrylic; not coated, laminated or of composite construction; meeting ANSI Z124.3 and .6, Type Six, and federally inspected WW-P-541E/GEN.
- 2. Superficial damage to a depth of .1" shall be repairable by sanding and polishing.
- 3. Fabrication to be performed by a Certified Solid Surface fabricator/installer.
- 4. Fabricate components in shop to greatest extent practical to sizes and shapes indicated, in accordance with approved shop drawings and Solid Surface manufacturer requirements.

.2 COUNTER TOPS

1. Kitchen Equipment Sub-Contractor to co-ordinate all necessary re-enforcement, cross bracing and plywood underlays required on s.s. counters and work tables to accept Solid Surface tops.
2. Solid Surface tops to be 19mm thick, adhesively joined with inconspicuous seams; edge details as specified.
3. Edge details as per drawings and specifications.
4. Backsplashes to be 19mm thick with coved edge where backsplash meets counter.

.3 SOLID SURFACE TRAY SLIDES

1. Kitchen Equipment Sub-Contractor to co-ordinate all necessary re-enforcement, cross bracing and plywood underlays required on s.s. counters and work tables to accept Solid Surface tray slides.
2. Solid Surface tray slide to be 19mm thick, adhesively joined with inconspicuous seams; edge details as specified. Tray slide to include 6mm deep grooves to accept tray slide inserts.
3. Solid Surface tray slide inserts to be 13mm x 13mm set into 6mm deep grooves with silicone sealant.
4. Edge details as per drawings and specifications.
5. Solid Surface to be coved wherever tray slide meets counters.
6. Tray slide colours to be determined by Architect.

.4 SOLID SURFACE FOR COLD APPLIANCE APPLICATIONS

1. Kitchen Equipment Sub-Contractor to co-ordinate all necessary re-enforcement, cross bracing and plywood underlays required on s.s. counters and work tables to accept Solid Surface tops.
2. Solid Surface tops to be 19mm thick, adhesively joined with inconspicuous seams; edge details as specified.
3. Make cutouts to templates furnished by cold appliance manufacturer.
4. Reinforce joints and cutouts as recommended by the surfacing manufacturer.
5. Provide insulation between Solid Surface and adjacent cold pans.
6. Thermally isolate hot applications from cold.
7. Counter top colour to be determined by Architect.

.5 SOLID SURFACE FOR HOT APPLIANCE APPLICATIONS

1. Kitchen Equipment Sub-Contractor to co-ordinate all necessary re-enforcement, cross bracing and plywood underlays required on s.s. counters and work tables to accept Solid Surface tops.
2. Solid Surface tops to be 19mm thick, adhesively joined with inconspicuous seams; edge details as specified.
3. Make cutouts to templates furnished by hot appliance manufacturer.
4. Reinforce joints and cutouts as recommended by the surfacing manufacturer.
5. Provide insulation between Solid Surface and adjacent hot appliances.
6. Thermally isolate hot applications from cold.
7. Provide venting of cabinets.
8. Counter top colour to be determined by Architect.

-
- .6 SOLID SURFACE FOR COUNTER TOPS WITH SINKS
1. Kitchen Equipment Sub-Contractor to co-ordinate all necessary re-enforcement, cross bracing and plywood underlays required on s.s. counters and work tables to accept Solid Surface tops.
 2. Solid Surface tops to be 19mm thick, adhesively joined with inconspicuous seams; edge details as specified.
 3. Sinks to be seamed undermount "S" type sink.
 4. Provide counter complete with integral covered backsplash of size as specified.
 5. Single sink bowls to be 445mm wide x 496mm long x 206mm deep complete with drain holes.
 6. Double bowl sinks to be 783mm wide x 471mm long x 210mm deep complete with drain holes.
 7. Counter top and sink colour to be determined by Architect.
- 2.16. PREFABRICATED, INSULATED WALK-IN TYPE REFRIGERATED AND FROZEN ROOM ASSEMBLIES – NOT APPLICABLE**
- 2.17. MECHANICAL REFRIGERATION SYSTEMS – NOT APPLICABLE**
- 2.18. EXHAUST VENTILATORS AND HOODS – NOT APPLICABLE**
- 2.19. CONDENSATE HOODS – NOT APPLICABLE**
- 2.20. FIRE SUPPRESSION SYSTEM – NOT APPLICABLE**
- 2.21. CONVEYOR SYSTEMS – NOT APPLICABLE**
- 2.22. ITEMIZED EQUIPMENT SPECIFICATIONS**
- .1 The following numbers correspond to those on the Foodservice Equipment Drawings.
 - .2 Where a manufacturer's name and model number is indicated, the item shall be supplied with all standard components, features and materials whether specifically identified or not, and shall be considered inherent in this specification.
 - .3 Items identified as custom fabricated shall be constructed of stainless steel unless otherwise specified. Refer to detail drawings at the end of this section for general fabrication methods for all items.
 - .4 Verify mechanical and electrical services on owner supplied equipment.
 - .5 Approved alternative manufactures must supply a product that is equal in performance to the specified item.
 - .6 The following are lists of equipment required in the **Level 4 Servery**.

ITEM NO. 1.000: EXISTING HAND SINK

Quantity: One (1) – to Remain

Components:

- All required cleaning, repairs and commissioning by others.

ITEM NO. 1.001: EXISTING EYEWASH STATION - RELOCATED

Quantity: One (1) – to be Relocated by MECHANICAL DIVISION

ITEM NO. 1.002: NEW S.S. SOILED DISHTABLE WITH PRE-RINSE SINK

Quantity: One (1) – by K.E.C.

Nominal size: 3,048mm long x 762mm wide x Height to suit dishwasher

Type: Custom fabricated stainless steel construction in accordance with the specification for this section.

Components:

- 14 ga. s.s. top with rolled edges as per QF drawing Detail 400.
- Full length 305mm high x 102mm wide integral splash at back as per QF drawing Detail 400, splayed to wall.
- Edge on left-hand side to suit dishwasher.
- One (1) 508mm long x 508mm wide x 203mm deep pre-rinse sink complete with S.S. apron on front and sides. Stainless steel sink to have all covered edges and corners. Provide removable perforated basket and H-shaped rail as per QF drawing Detail 901, with S.S fixed holding hangers secured to front apron.
- One (1) T&S B-2277-01-CR deck-mount pre-rinse faucet, complete with spray hose and hook, add-on faucet, all attachments including wall bracket and B-0425-KIT install kit. Reduced height 12" riser required. Refer to QF drawing Detail 901 for faucet positioning on backsplash.
- Open below table to suit food service equipment.
- Stainless steel fixed base on right-hand side below. Removable panels to be provided as required for access to mechanical and electrical services.
- Table to be sloped from all directions to dishwasher.
- Legs and brace sets as required.
- Secure table to the floor.
- Stainless steel manufacturer to verify dimensions on-site prior to fabrication.
- KEC to review table size in conjunction with elevator, corridors and other critical egress measurements, prior to fabrication, to ensure unobstructed access of the table to final location. Table to be fabricated in sections as required, then welded and polished seamlessly together on site.
- Refer to Elevation on drawing QF-300.

ITEM NO. 1.003: NEW S.S. WALL-MOUNT SORTING SHELF

Quantity: One (1) – by K.E.C.
Nominal size: 1,930mm long x 406mm wide
Type: Custom fabricated stainless steel construction in accordance with the specification for this section.

Components:

- Stainless steel shelf mounted to wall as per QF drawing Detail 912.
- Stainless steel manufacturer to verify dimensions on-site prior to fabrication.
- Refer to Elevation on drawing QF-300.

ITEM NO. 1.004: NEW WASTE BIN WITH DOLLY

Quantity: Two (2) – by K.E.C.
Manufacturer: RUBBERMAID
Model: FG262000GRAY

Components:

- Manufacturer's standard components.
- 20 gallon (76 L) capacity bin, colour to be gray.
- Complete with FG264000BLA dolly.
- Complete with FG261960GRAY gray self-draining lid.

ITEM NO. 1.005: NEW DISHWASHER

Quantity: One (1) – by K.E.C.
Manufacturer: CHAMPION
Model: DH-6000T VHR

Components:

- Manufacturer's standard components.
- Stainless steel high temperature machine.
- Ventless heat recovery system with condensate removal.
- Built-in booster heater to ensure 180°F (82°C) hot water supply.
- Front-mounted controls with HMI digital touchscreen interface for programming and diagnostics.
- Interlock door with 27" high extended clearance.
- Single point electrical connection.
- Automatic delime and notification.
- PRV mounted pressure reducing valve.
- Complete with unmounted drain water tempering kit.
- Complete with ION scale prevention system.
- Complete with splash shields for corner operation.
- Complete with four (4) peg and four (4) flat dish racks.
- Complete with water softener (selection suitability must be confirmed by dishwasher manufacturer prior to ordering).
- Commissioning & training by Champion field engineer.

ITEM NO. 1.006: EXISTING CONDENSATE HOOD

Quantity: One (1) – to Remain

Components:

- All required cleaning, repairs and commissioning by others.

ITEM NO. 1.007: NEW S.S. CLEAN DISHTABLE

Quantity: One (1) – by K.E.C.

Nominal size: 1,397mm long x 762mm wide x Height to suit dishwasher.

Type: Custom fabricated stainless steel construction in accordance with the specification for this section.

Components:

- 14 ga. s.s. top with rolled edges as per QF drawing Detail 400.
- Full length 305mm high x 51mm wide integral splash at back and left-hand side, as per QF drawing Detail 400, splayed to wall.
- Edge on right-hand side to suit dishwasher.
- Stainless steel fixed base on left-hand side below. Removable panels to be provided as required for access to mechanical and electrical services.
- Table to be sloped from all directions to dishwasher.
- Legs and brace sets as required.
- Secure table to the floor.
- Stainless steel manufacturer to verify dimensions on-site prior to fabrication.
- Refer to Elevation on drawing QF-300.

ITEM NO. 1.008: NEW S.S. WALL-MOUNT SHELF

Quantity: One (1) – by K.E.C.

Nominal size: 1,067mm long x 305mm wide x one (1) unit tall

Type: Custom fabricated stainless steel construction in accordance with the specification for this section.

Components:

- Stainless steel shelf mounted to wall as per QF drawing Detail 420.
- Stainless steel manufacturer to verify dimensions on-site prior to fabrication.
- Refer to Elevation on drawing QF-300.

ITEM NO. 1.009: SPARE NUMBER

ITEM NO. 1.010: EXISTING REACH-IN REFRIGERATOR - RELOCATED

Quantity: One (1) – to be Relocated by K.E.C.

Components:

- All required cleaning, repairs and commissioning by others.
- Electrical Division to confirm existing service requirements.
- Refer to Drawing QF-100 for location.

ITEM NO. 1.011: NEW MILLWORK CABINET DOORS & DRAWERS

Quantity: One (1) Lot – by MILLWORK DIVISION

ITEM NO. 1.012: NEW S.S. CABINET WITH PREP SINK

Quantity: One (1) – by K.E.C.

Nominal size: 2,076mm long x 762mm wide x 864mm high

Type: Custom fabricated stainless steel construction in accordance with the specification for this section.

Components:

- Stainless steel reinforced top with boxed edges, no backplash. Refer to QF drawing Detail 400.
- Stainless steel cabinet assembly with enclosed sides, back and base. Support gables to be double-pan construction. Removable panels to be provided in back and base for access to mechanical and electrical services.
- Section on right-hand side to have one (1) 406mm long x 508mm wide x 305mm deep stainless steel undermount welded sink with all covered edges and corners, centre drain with strainer and one (1) T&S UltraRinse B-0221-U12-CR deck-mount mixing faucet with fan spray nozzle. K.E.C. to provide pre-installed heavy-duty soft-close cabinet hinges, suitable for millwork door to be supplied and installed on-site by Millwork Division. Refer to QF drawing Detail 444.
- Section in middle and on left-hand side to have one (1) stainless steel adjustable shelf. K.E.C. to provide pre-installed heavy-duty soft-close cabinet hinges, suitable for millwork doors to be supplied and installed on-site by Millwork Division. Refer to QF drawing Detail 446.
- Stainless steel adjustable legs with recessed and removable kickplate on front and exposed sides.
- Secure cabinet to the floor.
- Stainless steel manufacturer to verify dimensions on-site prior to fabrication.
- KEC to review cabinet size in conjunction with elevator, corridors and other critical egress measurements, prior to fabrication, to ensure unobstructed access of the cabinet to final location. Cabinet to be fabricated in sections as required, then welded and polished seamlessly together on site.
- Refer to Elevation on drawing QF-300.

ITEM NO. 1.013: NEW S.S. CUPBOARDS

Quantity: One (1) – by K.E.C.
Nominal size: 2,076mm long x 457mm wide x 724mm high
Type: Custom fabricated stainless steel construction in accordance with the specification for this section.

Components:

- Stainless steel upper cabinet assembly, enclosed on all sides and back. Support gables to be double-pan construction. Sides and back must be reinforced to support wall-mount fastening.
- Two (2) rows of stainless steel adjustable shelves. K.E.C. to provide pre-installed heavy-duty soft-close cabinet hinges, suitable for millwork doors to be installed on-site by Millwork Division. Refer to QF drawing Detail 449.
- Seal all edges of cupboards water-tight at junctions of finished walls.
- Millwork valance and lighting below cupboards by Millwork Division.
- Stainless steel manufacturer to verify dimensions on-site prior to fabrication.
- Refer to Elevation on drawing QF-300.

ITEM NO. 1.014: SPARE NUMBER

ITEM NO. 1.015: NEW MILLWORK CUPBOARD DOORS

Quantity: One (1) Lot – by MILLWORK DIVISION

ITEM NO. 1.016: NEW S.S. CABINET WITH HAND SINK

Quantity: One (1) – by K.E.C.
Nominal size: 2,669mm long x 762mm wide x 864mm high
Type: Custom fabricated stainless steel construction in accordance with the specification for this section.

Components:

- Stainless steel reinforced top with boxed edges, no backplash. Refer to QF drawing Detail 400.
- Stainless steel cabinet assembly with enclosed sides, back and base. Support gables to be double-pan construction. Removable panels to be provided in back and base for access to mechanical and electrical services.
- Section on right-hand side to have one (1) 305mm long x 406mm wide x 305mm deep stainless steel undermount welded sink with all covered edges and corners, centre drain with strainer and one (1) T&S B-0321-CC-CR deck-mount mixing faucet with gooseneck spout. K.E.C. to provide pre-installed heavy-duty soft-close cabinet hinges, suitable for millwork door to be supplied and installed on-site by Millwork Division. Refer to QF drawing Detail 448.
- Two (2) sections in middle and on right-hand side to each have three (3) banks of stainless steel drawers with full-extension heavy-duty soft-close slides. Millwork fixed front panels to be supplied and installed on-site by Millwork Division. Refer to QF drawing Detail 447.

- Section on left-hand side to have one (1) stainless steel adjustable shelf. K.E.C. to provide pre-installed heavy-duty soft-close cabinet hinges, suitable for millwork doors to be supplied and installed on-site by Millwork Division. Refer to QF drawing Detail 446.
- Stainless steel adjustable legs with recessed and removable kickplate on front and exposed sides.
- Secure cabinet to the floor.
- Cabinet configuration to accommodate structural column at back.
- Stainless steel manufacturer to verify dimensions on-site prior to fabrication.
- KEC to review cabinet size in conjunction with elevator, corridors and other critical egress measurements, prior to fabrication, to ensure unobstructed access of the cabinet to final location. Cabinet to be fabricated in sections as required, then welded and polished seamlessly together on site.
- Refer to Elevation on drawing QF-300.

ITEM NO. 1.017: NEW S.S. CUPBOARDS

Quantity: One (1) – by K.E.C.
Nominal size: 1,524mm long x 356mm wide x 724mm high
Type: Custom fabricated stainless steel construction in accordance with the specification for this section.

Components:

- Stainless steel upper cabinet assembly, enclosed on all sides and back. Support gables to be double-pan construction. Sides and back must be reinforced to support wall-mount fastening.
- Two (2) rows of stainless steel adjustable shelves. K.E.C. to provide pre-installed heavy-duty soft-close cabinet hinges, suitable for millwork doors to be installed on-site by Millwork Division. Refer to QF drawing Detail 450.
- Seal all edges of cupboards water-tight at junctions of finished walls.
- Millwork valance and lighting below cupboards by Millwork Division.
- Stainless steel manufacturer to verify dimensions on-site prior to fabrication.
- Refer to Elevation on drawing QF-300.

ITEM NO. 1.018: EXISTING COUNTERTOP OVEN - RELOCATED

Quantity: One (1) – to be Relocated by K.E.C.

Components:

- All required cleaning, repairs and commissioning by others.
- Electrical Division to confirm existing service requirements.
- Refer to Drawing QF-100 for location.

ITEM NO. 1.019: EXISTING UNDERCOUNTER ICE MACHINE - RELOCATED

Quantity: One (1) – to be Relocated by K.E.C.

Components:

- All required cleaning, repairs and commissioning by others.
- Electrical and Mechanical Divisions to confirm existing service requirements.
- Refer to Drawing QF-100 for location.
- To be connected to water filter. Filter system by K.E.C. and installed by Mechanical Division. K.E.C. to coordinate interconnection to filter station with Mechanical Division.

ITEM NO. 1.019A: NEW WATER FILTER

Quantity: One (1) – by K.E.C.
Manufacturer: EVERPURE or equivalent
Model: Manufacturer recommendation

Components:

- Manufacturer's standard components.

ITEM NO. 1.020: SPARE NUMBER

ITEM NO. 1.021: EXISTING MICROWAVE OVEN - RELOCATED

Quantity: One (1) – to be Relocated by K.E.C.

Components:

- All required cleaning, repairs and commissioning by others.
- Electrical Division to confirm existing service requirements.
- Refer to Drawing QF-100 for location.

ITEM NO. 1.022: NEW S.S. WALL-MOUNT MICROWAVE SHELF

Quantity: One (1) – by K.E.C.
Nominal size: 610mm long x 457mm wide x 305mm high
Type: Custom fabricated stainless steel construction in accordance with the specification for this section.

Components:

- Stainless steel shelf mounted to wall as per QF drawing Detail 451.
- Stainless steel manufacturer to verify dimensions on-site prior to fabrication.
- Refer to Elevation on drawing QF-300.

ITEM NO. 1.023: EXISTING CONVEYOR TOASTER - RELOCATED

Quantity: One (1) – to be Relocated by K.E.C.

Components:

- All required cleaning, repairs and commissioning by others.
- Electrical Division to confirm existing service requirements.
- Refer to Drawing QF-100 for location.

ITEM NO. 1.024: SPARE NUMBER

ITEM NO. 1.025: SPARE NUMBER

ITEM NO. 1.026: NEW MOBILE HEATED PLATE DISPENSER

Quantity: One (1) – by K.E.C.

Manufacturer: HATCH

Model: 2DTH-M-1532*

Components:

- Manufacturer's standard components.
- Stainless steel enclosed base with wrap-around bumper.
- Two (2) heated dispensers with adjustable self-levelling operation, sized to fit maximum 244mm (9 5/8") diameter plates and bowls (china sizes must be confirmed by Architect prior to ordering).
- 6" (152mm) swivel casters, all with brakes.
- NSF certified model required.
- Complete with TC tube covers for each plate dispenser.

ITEM NO. 1.027: SPARE NUMBER

ITEM NO. 1.028: NEW S.S. COUNTERTOP & TRAYRAIL

Quantity: One (1) – by K.E.C.

Nominal size: 4,420mm x 2,184mm long L-shape configuration x 1,219mm wide x 38mm high

Type: Custom fabricated stainless steel construction in accordance with the specification for this section.

Components:

- Stainless steel reinforced top with boxed edges, integral front trayrail with inverted V-ribs and backstop (profile must be approved by Architect prior to fabrication). Refer to QF drawing Details 441, 442 and 443.
- Stainless steel manufacturer to verify dimensions on-site prior to fabrication.
- K.E.C. to review countertop size in conjunction with elevator, corridors and other critical egress measurements, prior to fabrication, to ensure unobstructed access to final location. Countertop to be manufactured in sections as required, then welded and polished seamlessly together on site.
- Refer to Elevations on drawing QF-300.

ITEM NO. 1.029: NEW S.S. CABINET BASE ASSEMBLY

Quantity: One (1) Lot – by K.E.C.
Manufacturer: IFAB MANUFACTURING (no alternate manufacturers accepted)
Model: IFAB-FR1029
Nominal size: 4,381mm x 2,147mm long L-shape configuration x 864mm wide x 826mm high, must be fabricated in sections to allow for unobstructed access to final location.
Type: Custom fabricated stainless steel construction for mounting foodservice equipment and millwork components in accordance with the specification for this section.

Components:

- Frame sections to have all welded and polished components.
- 2"x 2" stainless steel welded tubular posts with levelling feet and adjustable angles for securing to floor structure.
- Stainless steel panels required to enclose vertical gaps between rear posts.
- 2"x 2" stainless steel welded tubular top and cross supports, configured for openings to fit drop-in equipment. Refer to QF drawing Detail 442.
- One (1) section with stainless steel apron at rear service side to include recessed area with cut-outs to fit inset controls for countertop-mount and drop-in equipment. Stainless steel lift-off louvered panel at rear service side with hidden keyhole slots, to align with welded stand-offs on rear posts. Refer to QF drawing Detail 442.
- Two (2) sections to have one (1) each stainless steel adjustable shelf and enclosed base. Refer to QF drawing Detail 441.
- Two (2) sections to have stainless steel gables and be open below for foodservice equipment. Refer to QF drawing Detail 443.
- Stainless steel recessed and removable kickplates on rear service side.
- All electrical conduit, receptacles and junction boxes to be installed, recessed and concealed undercounter and in S.S. apron as required, by K.E.C. All electrical wiring supplied, installed and connected by Electrical Division on site, when cabinets are secured in final position. All junction boxes and receptacles to be clearly labelled with the equipment item numbers they are connected to. All cover plates to be stainless steel.
- Stainless steel manufacturer to verify dimensions on-site prior to fabrication.
- Refer to Drawing QF-402 for frame section configuration details.
- Refer to Elevations on drawing QF-300.

ITEM NO. 1.030: NEW DROP-IN HOT/COLD WELL

Quantity: One (1) – by K.E.C.
Manufacturer: LOW TEMP INDUSTRIES
Model: DI-QSCHP-4 QUICKSWITCH

Components:

- Manufacturer's standard components.
- Stainless steel drop-in assembly with separate insulated quick-change heated and refrigerated wells.
- 1/2" (13mm) turned-down flange top edges with gasket.
- Self-contained refrigeration system on adjustable height drop-in platform below.
- Remote digital controller, to be recessed in S.S. apron.
- Complete with one (1) set full-size 6" (152mm) high S.S. insert pans.
- KEC must coordinate ventilation with millwork fabricator, to ensure drop-in well manufacturer's operating requirements are met.

ITEM NO. 1.031: NEW FULL-SERVE ADJUSTABLE SNEEZE GUARD

Quantity: One (1) – by K.E.C.
Manufacturer: PREMIER METAL & GLASS
Model: FM2N-A

Components:

- Manufacturer's standard components.
- Overall length approximately 1,752mm, configuration as per Drawings QF-100 and QF-300.
- Brushed stainless steel posts and fittings (finish must be confirmed by Architect prior to fabrication).
- 1" diameter round posts.
- Two (2) end posts and one (1) intermediate partial post.
- 3/8" tempered glass top and hinged adjustable front.
- 3/8" tempered glass end panel, outside end only.
- 641/1 above counter surface mount assembly.
- Manufactured in one (1) section.
- End panels as required by local codes.
- Guard must be NSF certified and carry appropriate insignia.
- One (1) end post shared with 1.034 sneeze guard.

ITEM NO.1.031A: NEW HEAT LAMP

Quantity: One (1) – by K.E.C.
Manufacturer: HATCO
Model: GR5AHL-54

Components:

- Manufacturer's standard components
- Infrared strip heater with curved aluminum housing, to be designer colour or gloss finish (finish must be confirmed by Architect prior to fabrication).
- LED dual color lights adjustable from warm white 3200K to cool white 4000K.
- Remote box with electronic infinite control and power on/off switch, to be recessed in S.S. apron.
- Complete with 10' (3,048mm) extended power wire lead.

ITEM NO. 1.032: SPARE NUMBER

ITEM NO. 1.033: NEW UNDERCOUNTER REFRIGERATOR

Quantity: One (1) – by K.E.C.
Manufacturer: TRUE or equivalent by CONTINENTAL
Model: TUC-36-LP-HC~SPEC3

Components:

- Manufacturer's standard components.
- Stainless steel exterior including back, interior and doors with locks.
- 1 1/2" (38mm) low-profile swivel casters, two (2) with brakes.
- Exterior digital temperature display.

ITEM NO. 1.034: NEW FULL-SERVE ADJUSTABLE SNEEZE GUARD

Quantity: One (1) – by K.E.C.
Manufacturer: PREMIER METAL & GLASS
Model: TM2N-A

Components:

- Manufacturer's standard components.
- Overall length approximately 990mm, configuration as per Drawings QF-100 and QF-300.
- Brushed stainless steel posts and fittings (finish must be confirmed by Architect prior to fabrication).
- 1" diameter round posts.
- Two (2) end posts only.
- 3/8" tempered glass top and hinged adjustable front.
- 3/8" tempered glass end panel, outside end only.
- 641/1 above counter surface mount assembly.
- Manufactured in one (1) section.
- End panels as required by local codes.
- Guard must be NSF certified and carry appropriate insignia.
- One (1) end post shared with 1.031 sneeze guard.

ITEM NO. 1.034A: NEW DISPLAY LIGHT

Quantity: One (1) – by K.E.C.
Manufacturer: HATCO
Model: HL5-30

Components:

- Manufacturer's standard components
- Display light with curved aluminum housing, to be designer colour or gloss finish (finish must be confirmed by Architect prior to fabrication).
- LED cool white 4000K lights.
- Power on/off switch.
- Complete with 6' (1,829mm) cord and plug.

ITEM NO. 1.035: SPARE NUMBER

ITEM NO. 1.036: NEW UNDERCOUNTER ICE CREAM FREEZER

Quantity: One (1) – by K.E.C.
Manufacturer: BEVERAGE-AIR
Model: UCF20HC-25-15

Components:

- Manufacturer's standard components.
- Stainless steel exterior and hinged insulated glass door.
- Exterior electronic temperature control and display.
- Complete with key door lock.
- Complete with 3" (76mm) swivel casters, two (2) with brakes.

ITEM NO. 1.037: NEW FULL-SERVE ADJUSTABLE SNEEZE GUARD

Quantity: One (1) – by K.E.C.
Manufacturer: PREMIER METAL & GLASS
Model: TM2N-A

Components:

- Manufacturer's standard components.
- Overall length approximately 1,143mm, configuration as per Drawings QF-100 and QF-300.
- Brushed stainless steel posts and fittings (finish must be confirmed by Architect prior to fabrication).
- 1" diameter round posts.
- Two (2) end posts only.
- 3/8" tempered glass top and hinged adjustable front.
- 3/8" tempered glass end panel, outside end only.
- 641/1 above counter surface mount assembly.
- Manufactured in one (1) section.
- End panels as required by local codes.
- Guard must be NSF certified and carry appropriate insignia.

ITEM NO. 1.037A: NEW DISPLAY LIGHT

Quantity: One (1) – by K.E.C.
Manufacturer: HATCO
Model: HL5-36

Components:

- Manufacturer's standard components
- Display light with curved aluminum housing, to be designer colour or gloss finish (finish must be confirmed by Architect prior to fabrication).
- LED cool white 4000K lights.
- Power on/off switch.
- Complete with 6' (1,829mm) cord and plug.

ITEM NO. 1.038: SPARE NUMBER

ITEM NO. 1.039: EXISTING MOBILE SERVING CART

Quantity: One (1) – by OWNER

Components:

- All required cleaning, repairs and commissioning by others.
- Electrical and Mechanical Divisions to confirm existing service requirements.
- Refer to Drawing QF-100 for location.

ITEM NO. 1.040: NEW MILLWORK CABINET

Quantity: One (1) – by MILLWORK DIVISION

ITEM NO. 1.041: EXISTING LIQUID COFFEE MACHINE - RELOCATED

Quantity: One (1) – to be Relocated by K.E.C.

Components:

- All required cleaning, repairs and commissioning by others.
- Electrical and Mechanical Divisions to confirm existing service requirements.
- Refer to Drawing QF-100 for location.
- To be connected to water filter. Filter system by K.E.C. and installed by Mechanical Division. K.E.C. to coordinate interconnection to filter station with Mechanical Division.

ITEM NO. 1.041A: NEW WATER FILTER

Quantity: One (1) – by K.E.C.
Manufacturer: EVERPURE or equivalent
Model: Manufacturer recommendation

Components:

- Manufacturer's standard components.

ITEM NO. 1.042: EXISTING JUICE DISPENSER - RELOCATED

Quantity: One (1) – to be Relocated by K.E.C.

Components:

- All required cleaning, repairs and commissioning by others.
- Electrical and Mechanical Divisions to confirm existing service requirements.
- Refer to Drawing QF-100 for location.
- To be connected to water filter. Filter system by K.E.C. and installed by Mechanical Division. K.E.C. to coordinate interconnection to filter station with Mechanical Division.

ITEM NO. 1.042A: NEW WATER FILTER

Quantity: One (1) – by K.E.C.
Manufacturer: EVERPURE or equivalent
Model: Manufacturer recommendation

Components:

- Manufacturer's standard components.

ITEM NO. 1.043: NEW ICE AND WATER DISPENSER

Quantity: One (1) – by K.E.C.
Manufacturer: FOLLETT
Model: 15CI100A-IW-CF-ST-00

Components:

- Manufacturer's standard components.
- Built-in internal water filtration system.
- Control panel with touchscreen interface display.
- Agion antimicrobial internal component and touchscreen protection.
- Complete with #01149954 SafeCLEAN Plus cleaner bottles.
- Complete with two (2) #00968107 replacement filter cartridges.

ITEM NO. 1.044: NEW UNDERCOUNTER WASTE BIN

Quantity: Two (2) – by K.E.C.
Manufacturer: RUBBERMAID
Model: FG295600GRAY

Components:

- Manufacturer's standard components.
- 7 gallon (27 L) capacity bin, colour to be gray.

ITEM NO. 1.045: NEW HAND SINK WITH ELECTRONIC FAUCET

Quantity: One (1) – by K.E.C.
Manufacturer: EAGLE or equivalent by ADVANCE TABCO
Model: HSA-10-FA-PE

Components:

- Manufacturer's standard components.
- Stainless steel sink and pedestal with liquid soap dispenser.
- Gooseneck faucet with electronic eye sensor operation.
- P-trap and tailpiece included.
- Complete with MICROGARD antimicrobial protection.
- Complete with 326015 temperature adjustment mixing valve.
- Complete with end splashes as required by local health codes.

ITEM NO. 1.046: NEW S.S. COUNTERTOP

Quantity: One (1) – by K.E.C.
Nominal size: 1,825mm long x 826mm wide
Type: Custom fabricated s/s construction in accordance with the specification for this section.

Components:

- 14 ga. stainless steel top with 38mm high boxed edges on front and right-hand side. Refer to QF drawing Detail 400.
- K.E.C. to verify dimensions on-site prior to fabrication.
- K.E.C. to coordinate stainless steel countertop installation requirements with millwork fabricator, including base cabinet wood subtop and supports provided by millwork contractor.

PART 3 EXECUTION

3.1 SITE INSPECTIONS

- .1 All dimensions shown on the Drawings or listed in this Section of the Specification are to be considered nominal and for guidance only. It is the responsibility of the Foodservice Equipment Sub-contractor to check dimensions on the site and to co-ordinate any adjustments which may be necessary for the proper fabrication and set-in-place of the foodservice equipment.
- .2 If significant variances are apparent to the Construction Manager or Foodservice Equipment Sub-contractor which may require changes affecting the intent of the contract, immediately notify the consultant.
- .3 Fabricate equipment in sections that will allow easy access into the building and to final location within the foodservice area. Any damage to the building or the equipment will be the Foodservice Equipment Sub-contractor's responsibility.
- .4 Verify on the job site all actual dimensions of storerooms and walk-in refrigerators and freezers and adjust if necessary the size of shelving units specified in the item specification.
- .5 Verify all points of access into the job site and ensure that all pieces of equipment or fabricated items installed or relocated are able to pass through doors, hallways etc. in order to arrive at designated location on plans.

3.2 SAMPLES

- .1 If requested by the Consultant, submit samples of components or fabrication methods, materials or finishes, for review and approval before proceeding with that aspect of the work. Where necessary, request a shop inspection of an assembly which cannot be submitted for approval. Include in the base bid price, the cost of samples which may be rejected.
- .2 Samples must be the precise articles proposed to be furnished.
- .3 All samples must be supplied in the required quantity and all except one (1) will be returned.
- .4 Reviewed samples will become the standard of workmanship and material against which installed work will be checked.
- .5 Obtain from the Owner, all necessary samples of china, baskets, trays, etc. to determine proper sizes for openings, angle slides dispensers, conveyors, dishmachines, carts, wrapping machines, etc.
- .6 Prior to ordering dishwashing or traywashing equipment, obtain from the Owner a sample of all service wares, trays and carts etc. and assure their compatibility with warewashing or cartwashing equipment.

3.3 DELIVERY STORAGE OF EQUIPMENT

- .1 The Foodservice Equipment Sub-contractor will coordinate deliveries of equipment in conjunction with construction activity and progress at the site and as dictated by the Construction Manager.

- .2 The Foodservice Equipment Sub-contractor shall obtain and/or hold equipment ready for delivery in accordance with an agreed schedule which will permit completion of the work at the specific date.
- .3 Deliver, unpack and set in place all equipment in the designated position, ready for final connection of services, for units with electrical or mechanical connections.
- .4 Supply to the Construction Manager, in sufficient time, any information or items of service, articles, components or equipment which requires building in or which may overlap or impede the work of others.
- .5 Provide all necessary information within adequate time and in proper sequence regarding the exact location of openings, chases and any attachments or other fittings required for foodservice equipment.
- .6 Supply and deliver to the site in sufficient time all inserts, anchors, bolts, sleeves, ferrules and similar items for attaching to, or building into, masonry, concrete and other work for the proper anchorage and fixing of the equipment. Include necessary templates, instructions, directions and/or assistance in the location and installation of all items by other Sub-contractors.

3.4 INSTALLATION

- .1 Supply to all other trades in sufficient time, any services, articles, or equipment that require "building-in" or overlapping coordination. Also notify exact locations of openings, chases, anchors, floor pan, etc., required for the foodservice equipment covered in this contract.
- .2 Caulk and seal equipment to walls, base pads, curbs, and adjacent equipment where required.
- .3 Leave installed work neat, cleaned and polished, well fitted into position, level, and in proper operating condition.
- .4 Promptly remove all rubbish and debris from the building and site as the work proceeds and on completion.
- .5 Activate, test and adjust all equipment and apparatus installed under this Contract. Refinish and repair any painted and finished surfaces damaged during erection and installation. Hand over the completed installation in first class condition and working order.
- .6 Ensure electrical equipment is accompanied by label or certification of approval by Local Authority.
- .7 Ensure steam pressure equipment is accompanied by a "Certificate of Boiler" to satisfy Federal requirements.
- .8 Finished work must be perfectly true and plumb with no warping, buckling or open seams. All edges, hidden or exposed must be ground smooth and rounded. Rivet heads, weld marks, or other imperfections are not acceptable.
- .9 Cutting and repairs for the proper installation of services are part of the work in this Contract.
- .10 Obtain permits or special inspections. No allowance will be made for costs incurred.

- .11 Identify equipment with metal plates or labels permanently secured which include, where applicable:
 - Manufacturer's name or recognized trademark
 - Complete model identification
 - Model, serial number and U.L. and NSF identifications
 - Electrical characteristics
 - Direction of drive
 - Controls
 - Circuits, lines, etc.
 - Specific operating instructions
- .12 Identify equipment with temporary labels showing location and Item number per Specifications.
- .13 After installation has been completed and all items checked and adjusted where necessary for satisfactory operation, arrange for inspection of equipment. If items are found unsatisfactory, make necessary corrections and adjustments.

3.5 PROTECTION AND CLEANING

- .1 Protect properly and efficiently all work against any damage. Repair without charge to the Owner any damage to equipment and/or building. Cooperate at all times to keep the area clean and free of all rubbish and debris. At the end, clean all equipment to permit immediate use by the Owner without further cleaning.

3.6 MAINTENANCE MANUALS

- .1 Supply four (4) sets of manuals, bound and labeled, incorporating operating and maintenance instructions, including spare parts list and optional accessories for all items specified.
- .2 Identify each item, arrange in proper sequence and ensure that the numbers correspond to the specifications and drawings.
- .3 Provide an itemized lead sheet at the front of the manual with a list of the contents and the name and phone number of the service company.

3.7 DEMONSTRATION

- .1 After completion of installation, cleaning, testing and final inspection, instruct the Owner or their authorized personnel in the correct operation and maintenance of the equipment.
- .2 A demonstration shall be made of each piece of equipment requested by the Consultant, and such demonstration shall be carried out by a competent representative of the manufacturer's equipment.
- .3 It is the responsibility of the Construction Manager and/or Foodservice Equipment Sub-contractor to correct deficiencies and make adjustments to items which are not functioning properly at the time of demonstration.
- .4 The Contractor shall co-ordinate the schedule for equipment demonstrations with the Owner representative, with adequate time allowed for each demonstration.

- .5 Submit to the Foodservice Consultant cleaning, final inspection and testing, a schedule of demonstration by the suppliers of purchased equipment. Indicate clearly the timing for each supplier to Start up and demonstrate the proper use and maintenance of their equipment to the Owner.
- .6 The Consultant will inspect equipment on substantial completion of work and will issue a deficiency report immediately thereafter. A final inspection will also be made to verify corrected deficiencies.
- .7 The Owner reserves the right to inspect equipment at the factory of the Foodservice Equipment Sub-contractor, or at other locations as necessary.
- .8 Rejection of any item of equipment, components or fabrication will be based on degree of conformance to the Specification and Drawings, and is subject to the Conditions of the contract in any matter of dispute.

3.8 GUARANTEE

- .1 All new equipment shall be guaranteed for a **Minimum of Two (2)** years from the date of facility takeover against defects in material, manufacture, assembly, labour and installation. Those items or components which have inherent guarantee periods beyond this minimum shall be sustained to the maximum time provided by the manufacturer.
- .2 This guarantee applies to new purchases and fabricated equipment specified under this Division. Repair and/or replace at no cost to the Owner, parts and labour included, any and all equipment covered in this contract, which proves defective within the guarantee period.
- .3 The **Two (2)** year warranty shall include service, inspection, and maintenance for the fire extinguishing system as requested by the national and/or local authorities and N.F.P.A. - Code 96.
- .4 All mechanical refrigeration system components including compressors, condensing units, Refrigeration System and condensers shall be supplied with a **Two (2)** year replacement guaranteed including parts and labour and an additional **Five (5)** year parts guarantee on compressors.
- .5 If defects become apparent during the guarantee period, they shall be made good by the Foodservice Equipment Sub-contractor/supplier or authorized service representative. The supplier means the manufacturer of the equipment item, but under all circumstances it is the responsibility of the Construction Manager/Foodservice Equipment Sub-contractor to maintain the obligation of guarantee whether or not the supplier provides this service.
- .6 If defects identified at any time during the **Two (2)** year warranty period are not corrected prior to expiration of the warranty period, the warranty period will automatically be extended until the defect is corrected to the "Owners" or "Consultants" satisfaction.
- .7 If deficiencies identified at the point of substantial completion of the food equipment installation or during the **Two (2)** year warranty period are not corrected or resolved prior to the expiration of the **Two (2)** year warranty period, the warranty period will automatically be extended until such time as the outstanding deficiency is corrected to the "Owners" or "Consultants" satisfaction.
- .8 The guarantee shall not apply where it can be clearly shown that a defect or malfunction is due to misuse or neglect by the Owner or their representatives.

- .9 The guarantee period shall commence upon acceptance of the equipment by the Owner, or such date(s) as may be mutually agreed upon after facility takeover of the work. In no event shall the period of guarantee begin later than the date upon which the lien holdback expires.

3.9 INSPECTION, REJECTION AND FACTORY TESTING

- .1 The Owner and Consultant reserve the right to inspect the fabrication of any items at the fabricating plant and they may reject any equipment which does not comply with Plans and/or Specifications. The Contractor will replace without charge all rejected material or equipment within (10) days of rejection.
- .2 Factory test and verify all items such as cold pans, refrigerated display cases, ice cream freezers, custom built refrigerators, etc., to be sure that they are in proper working order before shipment. Inform the Consultant of the date of these tests in advance in writing so that he may observe and inspect these items in the shop if necessary. Advise the Consultant when installation is complete and ready for inspection.

END OF SECTION 11 40 00