



NOTES:
ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE NOTED

REGULATIONS & SPECIFICATIONS:

- CANADIAN AVIATION REGULATIONS CAR 305 & 325
- CANADIAN AVIATION REGULATIONS CAR 621
- ICAO ANNEX 14

OBSTACLE LIMITATION SURFACE DIMENSIONS AND SLOPES FOR NON-INSTRUMENT FATOs FROM CAR 325 TABLE 4-1

HELIPORT CLASSIFICATION: H3

DESIGN HELICOPTER(S): AW139 (MAX OVERALL LENGTH 16.66m (54.66 FT)) & H125/H135/H145 (MAX OVERALL LENGTH 13.64m (44.75 FT))(HELIPORT CLASSIFICATION)

TLOF: COINCIDENTAL WITH FATO

FATO: 24.99m (81.99 ft)

SAFETY AREA: 33.29m (109.21 ft)

DAY/NIGHT CERTIFICATION: 15% DIVERGENCE

PAD \pm ELEVATION (NOT SURVEYED):

- 273.63m (897.75 ft) ASL


HELIPORT \pm GEOGRAPHIC DESIGN COORDINATES NAD83 (NOT SURVEYED):

- N44° 04' 44"
- W79° 23' 38"

CONTRACTOR TO PROVIDE AS-BUILT SURVEY OF GEOGRAPHIC COORDINATES IN NAD83 DATUM REFERENCE IN GEODETIC (DD-MM-SSS) FORMAT AND PAD ELEVATION IN ft ASL AS AFTER CONSTRUCTION COMPLETION

5	ISSUED FOR ADDENDUM B	AW	08 OCT 24
4	ISSUED FOR TENDER	AW	09 SEP 24
3	ISSUED FOR BUILDING PERMIT	AW	31 JUL 24
2	GENERAL REVISIONS	AW	05 JUL 24
1	2ND ISSUE	AW	01 MAY 24
0	1ST ISSUE	AW	16 APR 24
REV.	DESCRIPTION	BY:	DATE:

STATUS:

 RGHservices Consulting Inc.			
Cell 604-626-6834		ron.german@rghservices.com	
This drawing is the exclusive property of RGHservices Consulting Ltd. Reproduction by any means is strictly prohibited.			
CLIENT: YORK REGIONAL POLICE			
ARCHITECT/ENGINEER:			
SITE: EAST GWILLIMBURY, ON			
TITLE: FLIGHT PATH LAYOUT			
SCALE AT ISO A1:	DATE:	DRAWN:	CHECKED:
NONE	23 MAR 24	KW	RQ
PROJECT NO:	DRAWING NO:	REVISION NO:	
RGH224	H01	5	



ELECTRICAL & RELATED WORK CONT'D

2. ELECTRICAL & RELATED WORK

- 2.1. CONTRACTOR TO SUPPLY & INSTALL (1) HELIPORT ARCAL RADIO LIGHTING CONTROLLER WITH 3-STEP BRIGHTNESS CONTROL & ALL NECESSARY CONDUIT FOR 120VAC INPUT ELECTRICAL FEED (SOURCE LOCATION TBD BY ELECTRICAL ENGINEER). NEW LIGHTING CONTROLLER TO LOCATED INSIDE HANGAR ADJACENT TO THE NEAREST MAN DOOR. REFER TO DRAWING H05 & ELECTRICAL ENGINEER'S DOCUMENTS
- 2.2. CONTRACTOR TO SUPPLY & INSTALL (11) 120VAC DIMMING LED HELIPORT INSET GREEN PERIMETER LIGHTS WITH IR DIODE & ALL NECESSARY CONDUIT FOR MULTI-CONDUCTOR ELECTRICAL FEED (NOTE THAT LIGHTS REQUIRE 3-WIRE POWER FEED AND 2 ADDITIONAL DATA WIRES FOR DIMMING; ENSURE CONDUIT SIZE IS APPROPRIATE (SOURCE LOCATION TBD BY ELECTRICAL ENGINEER). REFER TO DRAWING H05 & ELECTRICAL ENGINEER'S DOCUMENTS
- 2.3. CONTRACTOR TO SUPPLY & INSTALL (1) HELIPORT WIND DIRECTION INDICATOR C/W RED LED SINGLE-BULB OBSTRUCTION LIGHT & WHITE INTERNAL SOCK LIGHT. WIND DIRECTION INDICATOR LIGHTING TO BE ENERGIZED 24 HOURS PER DAY; 7 DAYS PER WEEK. THE WIND CONE IS TO BE COMPLIANT WITH CAR 325.31. STRUCTURAL ENGINEER IS TO PROVIDE THE FOUNDATION DESIGN. PROVIDE ALL NECESSARY CONDUIT FOR 120VAC ELECTRICAL FEED (SOURCE LOCATION TBD BY ELECTRICAL ENGINEER). REFER TO DRAWINGS H03, H05 & ELECTRICAL ENGINEER'S DOCUMENTS
- 2.4. INTENTIONALLY LEFT BLANK
- 2.5. CONTRACTOR TO SUPPLY & INSTALL (5) CL810 LOW-INTENSITY STEADY-BURNING DUAL RED LED OBSTRUCTION LIGHTS ENERGIZED FROM A POWER SOURCE SPECIFIED BY THE ELECTRICAL ENGINEER. OBSTRUCTION LIGHTS ARE TO BE ENERGIZED 24 HRS PER DAY/7 DAYS PER WEEK. REFER TO DRAWING H05 & ELECTRICAL ENGINEER'S DOCUMENTS

2.6. CAMPBELL SCIENTIFIC BASE WEATHER STATION BY OWNER. CONTRACTOR TO VERIFY PREFERRED LOCATION 1/5' HANGAR (CURRENTLY SHOWN ADJACENT TO ARCAL) FOR INSTALLATION OF APPROPRIATE ELECTRICAL CONDUIT

2.6.1. WEATHER STATION BASE. STRUCTURAL ENGINEER IS TO PROVIDE THE FOUNDATION DESIGN. PROVIDE ALL NECESSARY CONDUIT FOR APPROPRIATE ELECTRICAL FEED (SOURCE LOCATION TBD BY ELECTRICAL ENGINEER). REFER TO ELECTRICAL, GEOTECHNICAL, STRUCTURAL & CIVIL ENGINEER'S DOCUMENTS. REFER TO DRAWING H05

3. MARKINGS & RELATED WORK

- 3.1. CONTRACTOR TO SUPPLY MATERIALS & PAINT THE WHITE AIMING POINT MARKING PER CAR 325. CONTRACTOR TO ENSURE MARKINGS ALIGN WITH MAGNETIC NORTH. REFER TO DRAWING H04
- 3.2. CONTRACTOR TO SUPPLY MATERIALS & PAINT THE WHITE FATO MARKING ON THE HELIPORT SURFACE. REFER TO DRAWING H04
- 3.3. CONTRACTOR TO SUPPLY MATERIALS & PAINT THE YELLOW PEDESTRIAN CAUTION MARKINGS AS SHOWN. H04
- 3.4. CONTRACTOR TO SUPPLY AND INSTALL (7) NO SMOKING/DANGER SIGNS. FOR LOCATIONS REFER TO DRAWING H03. INSTALL FENCE-MOUNTED SIGNS WITH TAMPER & RUST-RESISTANT SIGN MOUNTING HARDWARE IN 4 LOCATIONS ON EACH SIGN
- 3.5. CONTRACTOR TO SUPPLY AND INSTALL (3) WARNING/ROTOR WASH SIGNS. FOR LOCATIONS REFER TO DRAWING H03. INSTALL FENCE-MOUNTED SIGNS WITH TAMPER & RUST-RESISTANT SIGN MOUNTING HARDWARE IN 4 LOCATIONS ON EACH SIGN
- 3.6. CONTRACTOR TO SUPPLY AND INSTALL (2) FIRE EXTINGUISHER SIGNS ON OUTSIDE OF HANGAR ADJACENT TO THE EXTINGUISHER CABINET. REFER TO DRAWING H03. INSTALL WITH RUST-RESISTANT SIGN MOUNTING HARDWARE IN 4 LOCATIONS ON EACH SIGN
- 3.7. CONTRACTOR TO SUPPLY & PLACE RETRO-REFLECTIVE TAPE EVERY 2m ON TOP OF FENCE LINE AROUND ENTIRE PERIMETER. REFER TO DRAWING H03
- 3.8. CONTRACTOR TO SUPPLY AND INSTALL (2) NO PARKING SIGNS ON OR ADJACENT TO EACH GATE AS SHOWN. REFER TO DRAWING H03. INSTALL FENCE-MOUNTED SIGNS WITH TAMPER & RUST-RESISTANT SIGN MOUNTING HARDWARE IN 4 LOCATIONS ON EACH SIGN
- 3.9. CONTRACTOR TO SUPPLY MATERIALS & PAINT THE WHITE PAVEMENT MARKING AS SHOWN. REFER TO DRAWING H04

GENERAL NOTES
ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE NOTED

CONFIRM EXISTENCE & EXACT LOCATION OF ALL OVERHEAD AND UNDERGROUND SERVICES FROM ENTITIES RESPONSIBLE BEFORE PROCEEDING WITH CONSTRUCTION

CONFIRM ALL EXISTING GRADES, LAYOUT, DIMENSIONS & MATERIALS ON SITE AND REPORT ANY ERRORS OR OMISSIONS TO THE CONTRACT ADMINISTRATOR & PRIME CONSULTANT BEFORE CONSTRUCTION


DEVIATIONS ARE NOT PERMITTED UNLESS AUTHORIZED IN WRITING BY THE CONTRACT ADMINISTRATOR & PRIME CONSULTANT BEFORE CONSTRUCTION



1. CONSTRUCTION WORK

- 1.1. CONTRACTOR TO GRADE AREA OF CONSTRUCTION, SUPPLY & PLACE CORRECT FILL MATERIAL TO ACHIEVE THE DESIGN ELEVATION OF THE NEW SLAB-ON-GRADE HELIPORT & APRON. APPROXIMATE AREA = 1527 SQ m. REFER TO GEOTECHNICAL, STRUCTURAL & CIVIL ENGINEER'S DOCUMENTS
- 1.2. CONTRACTOR TO CONSTRUCT A SLAB-ON-GRADE HELIPORT AND APRON INCLUDING IN-SLAB HYDRONIC HEATING AS ILLUSTRATED. ALL SLABS ARE TO BE SLOPED AS SHOWN. THE SLOPE ON THE SLAB IN ANY DIRECTION SHALL NOT EXCEED 2%. THE CONCRETE HELIPORT SHALL BE CAPABLE OF WITHSTANDING A POINT LOAD WEIGHT OF 17,000 LBS. APPROXIMATE SLAB AREA = 1527 SQ m. PLACE & COMPACT BASE MATERIALS PER GEOTECHNICAL, STRUCTURAL & CIVIL ENGINEER'S DOCUMENTS
- 1.2.1. CONTRACTOR TO CONSTRUCT SLAB-ON-GRADE APRONS AS ILLUSTRATED WITHOUT IN-SLAB HYDRONIC HEATING. APPROXIMATE SLAB AREA = 29.99 SQ m. PLACE & COMPACT BASE MATERIALS PER GEOTECHNICAL, STRUCTURAL & CIVIL ENGINEER'S DOCUMENTS
- 1.2.2. CONTRACTOR TO GRADE AREA OF CONSTRUCTION, SUPPLY & PLACE CORRECT FILL MATERIAL TO ACHIEVE THE DESIGN ELEVATION OF THE ASPHALT APRON (INSIDE FENCE LINE). APPROXIMATE AREA = 107 SQ m. ALL CIVIL WORK OUTSIDE OF THE HELIPORT AREA IS NOT INCLUDED THE SCOPE OF THE HELIPORT DRAWINGS, IN REFER TO GEOTECHNICAL, STRUCTURAL & CIVIL ENGINEER'S DOCUMENTS
- 1.2.3. CONTRACTOR TO APPLY AND COMPACT ASPHALT PAVEMENT IN THE AREA SHOWN AS SPECIFIED BY THE STRUCTURAL/CIVIL ENGINEER. APPROXIMATE AREA = 107 SQ m. PLACE & REFER TO GEOTECHNICAL, STRUCTURAL & CIVIL ENGINEER'S DOCUMENTS
- 1.3. INTENTIONALLY LEFT BLANK
- 1.4. CONTRACTOR TO SUPPLY & INSTALL NEW 10m HIGH CHAIN-LINK FENCE (MAX 1.25m OVER POSTS) WITH (2) DOUBLE LOCKABLE EMERGENCY & MAINTENANCE GATES. ACTUAL FENCE LAYOUT TBD. REFER TO DRAWING H03
- 1.5. CONTRACTOR TO SUPPLY & INSTALL (2) 10A: 120B FIRE EXTINGUISHER INSIDE TAMPER-PROOF CABINETS ON OUTSIDE OF HANGAR
- 1.6. CONTRACTOR TO PREPARE GRADE FOR PLACEMENT OF BACKFILL, TOPSOIL & SOD IN ALL AREAS DISTURBED BY CONSTRUCTION. TOPSOIL & SOD IS NOT TO EXCEED THE HELIPORT PAD ELEVATION AT ANY POINT. REFER TO GEOTECHNICAL, STRUCTURAL & CIVIL ENGINEER'S DOCUMENTS
- 1.7. CONTRACTOR TO PROVIDE AS-BUILT SURVEY OF GEOGRAPHIC COORDINATES IN NAD83 DATUM REFERENCE IN GEODETIC (DD-MM-SSS) FORMAT AND PAD ELEVATION IN ft ASL AS AFTER CONSTRUCTION COMPLETION
- 1.8. FUEL TANK & FOUNDATION BY OTHERS

6	ISSUED FOR ADDENDUM B	AW	08 OCT 24
5	ISSUED FOR TENDER	AW	09 SEP 24
4	REVISED ELECTRICAL	AW	27 AUG 24
3	ISSUED FOR BUILDING PERMIT	AW	31 JUL 24
2	GENERAL REVISIONS	AW	05 JUL 24
1	2ND ISSUE	AW	01 MAY 24
0	1ST ISSUE	AW	16 APR 24
REV.	DESCRIPTION	BY:	DATE:

STATUS:


 RGHservices Consulting Inc.			
Cell 604-626-6834	ron.german@rghservices.com		
This drawing is the exclusive property of RGHservices Consulting Ltd. Reproduction by any means is strictly prohibited.			
CLIENT:	YORK REGIONAL POLICE		
ARCHITECT/ENGINEER:			
SITE:	EAST GWILLIMBURY, ON		
TITLE:	SITE LAYOUT		
SCALE AT ISO A1: NONE	DATE: 23 MAR 24	DRAWN: KDW	CHECKED: RG
PROJECT NO: RGH224	DRAWING NO: H02	REVISION NO: 6	





3.4 NO SMOKING/DANGER SIGN
NO SCALE
QTY REQUIRED SEE DRAWING H02
REFER TO DETAIL 1.4 THIS PAGE
AVAILABLE FROM AIR NAVIGATION PRODUCTS airnav24@shaw.ca



3.5 WARNING/ ROTOR WASH SIGN
NO SCALE
QTY REQUIRED SEE DRAWING H02
REFER TO DETAIL 1.4 THIS PAGE
AVAILABLE FROM AIR NAVIGATION PRODUCTS airnav24@shaw.ca



3.6 FIRE EXTINGUISHER SIGN
NO SCALE
QTY REQUIRED SEE DRAWING H02
AVAILABLE LOCALLY



3.8 NO PARKING SIGN
NO SCALE
QTY REQUIRED SEE DRAWING H02
REFER TO DETAIL 1.4 THIS PAGE
Product Code: 11110194
AVAILABLE FROM ATS TRAFFIC-ONTARIO atstraffic.ca

- NOTES:
- A. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE NOTED
- B. CONFIRM EXISTENCE & EXACT LOCATION OF ALL OVERHEAD AND UNDERGROUND SERVICES FROM ENTITIES RESPONSIBLE BEFORE PROCEEDING WITH CONSTRUCTION
- C. CONFIRM ALL EXISTING GRADES, LAYOUT, DIMENSIONS & MATERIALS ON SITE AND REPORT ANY ERRORS OR OMISSIONS TO THE CONTRACT ADMINISTRATOR & PRIME CONSULTANT BEFORE CONSTRUCTION
- D. DEVIATIONS ARE NOT PERMITTED UNLESS AUTHORIZED IN WRITING BY THE CONTRACT ADMINISTRATOR & PRIME CONSULTANT BEFORE CONSTRUCTION
- E. INSTALL SIGNS WITH TAMPER & RUST-RESISTANT SIGN MOUNTING HARDWARE IN 4 LOCATIONS ON EACH SIGN
- F. ALL SIGN MATERIAL TO BE WHITE BACKGROUND ALUMINUM ASTM 5052-H 38 0.081" (2mm) THICKNESS OR APPROVED EQUIVALENT
- G. CONTRACTOR TO SUPPLY & PLACE RETRO-REFLECTIVE MARKING AS SPACED AS SHOWN ON DETAIL 1.4 FENCE & GATE DETAIL:
- G.A. 3M 50mm DIAMOND GRADE DG REFLECTIVE SHEETING 4.084 OR 973-74 ORANGE 50mm WIDE OR;
- G.B. INCOM 50mm WIDE ORANGE OR;
- G.C. REFLEXITE V98 FLUORESCENT ORANGE OR FLUORESCENT LIME 50mm WIDE
- H. PAINT LEAD-FREE YELLOW ENNIS-FLINT LOW VOC SOLVENT-BASED TRAFFIC PAINT (OR EQUIVALENT HIGH-QUALITY TRAFFIC PAINT). CONTRACTOR MUST FOLLOW MANUFACTURER'S INSTRUCTIONS

5	ISSUED FOR ADDENDUM B	AW	08 OCT 24
4	ISSUED FOR TENDER	AW	09 SEP 24
3	ISSUED FOR BUILDING PERMIT	AW	31 JUL 24
2	GENERAL REVISIONS	AW	05 JUL 24
1	2ND ISSUE	AW	01 MAY 24
0	1ST ISSUE	AW	16 APR 24
REV.	DESCRIPTION	BY:	DATE:
STATUS:			



Cell 604-626-6834 ron.german@rgheliseservices.com





CLIENT: YORK REGIONAL POLICE

ARCHITECT/ENGINEER:

SITE: EAST GWILLIMBURY, ON


TITLE: DETAILS




SCALE AT ISO A1: NOTED	DATE: 23 MAR 24	DRAWN: AW	CHECKED: RG
PROJECT NO: RGH224	DRAWING NO: H03	REVISION NO:	5



- NOTES:**
- A. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE NOTED
 - B. CONFIRM EXISTENCE & EXACT LOCATION OF ALL OVERHEAD AND UNDERGROUND SERVICES FROM ENTITIES RESPONSIBLE BEFORE PROCEEDING WITH CONSTRUCTION
 - C. CONFIRM ALL EXISTING GRADES, LAYOUT, DIMENSIONS & MATERIALS ON SITE AND REPORT ANY ERRORS OR OMISSIONS TO THE CONTRACT ADMINISTRATOR & PRIME CONSULTANT BEFORE CONSTRUCTION
 - D. DEVIATIONS ARE NOT PERMITTED UNLESS AUTHORIZED IN WRITING BY THE CONTRACT ADMINISTRATOR & PRIME CONSULTANT BEFORE CONSTRUCTION
 - E. PAINT LEAD-FREE WHITE ENNIS-FLINT LOW VOC SOLVENT-BASED TRAFFIC PAINT (OR EQUIVALENT HIGH-QUALITY TRAFFIC PAINT). CONTRACTOR MUST FOLLOW MANUFACTURER'S INSTRUCTIONS
 - F. PAINT LEAD-FREE YELLOW ENNIS-FLINT LOW VOC SOLVENT-BASED TRAFFIC PAINT (OR EQUIVALENT HIGH-QUALITY TRAFFIC PAINT). CONTRACTOR MUST FOLLOW MANUFACTURER'S INSTRUCTIONS

6	ISSUED FOR ADDENDUM 8	<i>APR</i>	08 OCT 24
5	ISSUED FOR TENDER	<i>APR</i>	09 SEP 24
4	GENERAL REVISIONS	<i>APR</i>	27 AUG 24
3	ISSUED FOR BUILDING PERMIT	<i>APR</i>	31 JUL 24
2	GENERAL REVISIONS	<i>APR</i>	05 JUL 24
1	2ND ISSUE	<i>APR</i>	01 MAY 24
0	1ST ISSUE	<i>APR</i>	16 APR 24
REV.	DESCRIPTION	BY	DATE

			
RGHeliservices Consulting Inc			
Cell 604-626-6834		ron.german@rgheliservices.com	
This drawing is the exclusive property of RGHeliservices Consulting Ltd. Reproduction by any means is strictly prohibited.			
CLIENT: YORK REGIONAL POLICE			
ARCHITECT/ENGINEER:			
SITE: EAST GWILLIMBURY, ON			
TITLE: DETAILS			
SCALE: AT ISO A1 NOTED	DATE: 23 MAR 24	DRAWN: AKW	CHECKED: RG
PROJECT NO: RGH224	DRAWING NO: H04	REVISION NO: 6	



AVIATION LIGHTING EQUIPMENT SCHEDULE					
WORK NO.	ITEM	MANUFACTURER	PART/SKU NO.	DESCRIPTION	QTY
2.1	HELIPORT LIGHTING CONTROLLER W/ TOUCHSCREEN	POINT LIGHTING CORPORATION	PHC-66002-AC-R C3-A10	VHF RADIO LIGHTING CONTROLLER FOR VARIABLE INTENSITY LED PERIMETER LIGHTS AT 35-60-100% STEPS AS REQUIRED BY TRANSPORT CANADA; 3-5-7 MICROPHONE CLICKS WITH 15 MINUTE ON/OFF TIMER; 120VAC/1 PHASE/60HZ INPUT & OUTPUT; 100 FT ANTENNA CABLE; MOUNT ANTENNA TO HANGAR ROOF	1
2.1a	GROUND TO AIR VHF TRANSCEIVER	ICOM	IC-A16	VHF AIR BAND TRANSCEIVER WITH; BATTERY PACK; RAPID CHARGER; AC ADAPTER; ANTENNA; BELT CLIP; HAND STRAP	1
2.2	POINT ROLLOVER LIGHTS	POINT LIGHTING CORPORATION	PRL-97004-1C-G -VB-PLS-NC	POINT ROLLOVER LIGHTS; HELIPORT INSET LIGHT; 120VAC/1 PHASE/60HZ; NVG COMPATIBLE; GREEN; VARIABLE INTENSITY; SHALLOW BASE & GASKET	11
2.2a	SPARES POINT ROLLOVER LIGHTS	POINT LIGHTING CORPORATION	PRL-97004-1C-G -VB-NC	POINT ROLLOVER LIGHTS; HELIPORT INSET LIGHT; 120VAC/1 PHASE/60HZ; NVG COMPATIBLE; GREEN; VARIABLE INTENSITY; NO BASE	2
2.3	WIND DIRECTION INDICATOR	MILLARD TOWERS	CUSTOM ORDER	COLLAPSIBLE 4.5M WINDSOCK MAST W/1B MOUNT, BASE MOUNT, WINDSOCK ASSY - 100-240VAC 600MM WIND CONE R/W CSA, OBSTRUCTION LIGHT ASSY; INTERNAL SOCK LIGHT ASSY; REFER TO DRAWING H04	1
2.4				INTENTIONALLY LEFT BLANK	
2.5	DUAL OBSTRUCTION LIGHT	POINT LIGHTING CORPORATION	POL-21005-1B-R-10B-D-NC	DUAL OBSTRUCTION LIGHT CL810 NVG COMPATIBLE STEADY-BURNING RED 120VAC 1in BOTTOM MOUNT ETL TC	3

- NOTES:
- A. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE NOTED
- B. CONFIRM EXISTENCE & EXACT LOCATION OF ALL OVERHEAD AND UNDERGROUND SERVICES FROM ENTITIES RESPONSIBLE BEFORE PROCEEDING WITH CONSTRUCTION
- C. CONFIRM ALL EXISTING GRADES, LAYOUT, DIMENSIONS & MATERIALS ON SITE AND REPORT ANY ERRORS OR OMISSIONS TO THE CONTRACT ADMINISTRATOR & PRIME CONSULTANT BEFORE CONSTRUCTION
- D. DEVIATIONS ARE NOT PERMITTED UNLESS AUTHORIZED IN WRITING BY THE CONTRACT ADMINISTRATOR & PRIME CONSULTANT BEFORE CONSTRUCTION
- E. ELECTRICAL ENGINEER TO DETERMINE LOCATION AND DEPTH OF ALL UNDERGROUND CONDUIT REFER TO ELECTRICAL ENGINEER'S DOCUMENTS
- F. ALL UNDERGROUND CONDUIT TO BE SIZED TO PERMIT THE NUMBER OF CONDUCTORS TO ALLOW FOR DIMMING CONTROL OF ALL PERIMETER LIGHTS, TECK CABLE PERMISSIBLE IF APPROVED BY THE ELECTRICAL ENGINEER. CONDUIT SIZE & MATERIAL PER ELECTRICAL ENGINEER'S DOCUMENTS
- G. ALL ITEMS LISTED IN THE AVIATION LIGHTING EQUIPMENT SCHEDULE ARE AVAILABLE FROM AIR NAVIGATION PRODUCTS sales.airnav24@shaw.ca

6	ISSUED FOR ADDENDUM B	AW	08 OCT 24
5	ISSUED FOR TENDER	AW	09 SEP 24
4	REVISED AVIATION LIGHTING EQUIPMENT	AW	21 AUG 24
3	ISSUED FOR BUILDING PERMIT	AW	31 JUL 24
2	GENERAL REVISIONS	AW	05 JUL 24
1	2ND ISSUE	AW	01 MAY 24
0	1ST ISSUE	AW	16 APR 24

REV.	DESCRIPTION	BY.	DATE.
STATUS:			
 RGHservices Consulting Inc. Cell 604-626-6834 ron.german@rghservices.com <small>This drawing is the exclusive property of RGHservices Consulting Ltd. Reproduction by any means is strictly prohibited.</small>			
CLIENT: YORK REGIONAL POLICE			
ARCHITECT/ENGINEER:			
SITE: EAST GWILLIMBURY, ON			
TITLE: ELECTRICAL LAYOUT			
SCALE AT ISO A1:	DATE:	DRAWN:	CHECKED:
NONE	23 MAR 24	KW	RQ
PROJECT NO:	DRAWING NO:	REVISION NO:	
RGH224	H05		6