


CIVIL ADDENDUM C-001  
MILL COURTLAND COMMUNITY CENTER ADDITION

2024-0766-10 March 27, 2025

Civil Questions:

Question 18: Please provide concrete toe wall detail.



**Question 22:** Please provide detail for pup CB203

*Due to the shallow invert, a standard catchbasin may not be able to accommodate a normal frame and grate.*

*If not, we would suggest a "PUP" Catchbasin which has an inset frame and grate.*



Shelley Forwell, P.Eng.  
Site Development Manager  
Partner

sforwell@walterfedy.com  
519.576.2150 Ext.241