



SCARBOROUGH HEALTH NETWORK
GENERAL HOSPITAL
3050 Lawrence Ave E, Scarborough, ON

GROUND FLOOR
Satellite Imaging Renovation

Project Number: 140023034



DRAWING LIST:	
ARCHITECTURAL:	
A000	PROJECT TITLE PAGE
A001	NOTES, SYMBOLS AND LEGENDS
A002	LOCATION PLAN
A100	LIFE SAFETY PLAN AND CODE MATRIX
A301	DEMOLITION PLAN
A401	PARTIAL FLOOR PLAN
A402	EQUIPMENT PLAN
A403	FF&E RESPONSIBILITIES
A404	EXISTING PARTIAL BASEMENT FLOOR PLAN
A501	PARTIAL GROUND FLOOR CEILING DEMOLITION PLAN
A502	PARTIAL GROUND FLOOR REFLECTED CEILING PLAN
A503	PARTIAL BASEMENT REFLECTED CEILING PLAN
A801	DOOR SCHEDULE
A802	FINISH SCHEDULE, WALL PROTECTION, PHASING
A901	CASEWORK / MILLWORK SECTIONS, ELEVATIONS, HHS & WASHROOM ELEVATIONS
A902	WINDOW INFILL/REPLACEMENT DETAILS
STRUCTURAL	
S100	SPECIFICATIONS AND GENERAL NOTES
S200	PART EXISTING GROUND FLOOR FRAMING PLAN
S201	PART EXISTING FIRST FLOOR FRAMING PLAN
S300	SECTIONS
SD201	PART EXISTING FIRST FLOOR DEMOLITION PLAN
MECHANICAL	
M000	MECHANICAL LEGENDS & DRAWING LIST
M111	GROUND LEVEL - VENTILATION DEMO
M121	GROUND LEVEL - PLUMBING DEMO
M122	BASEMENT LEVEL - PLUMBING DRAINAGE DEMO
M131	GROUND LEVEL - FIRE PROTECTION DEMO
M141	GROUND LEVEL - HVAC PIPING DEMO
M151	GROUND LEVEL - MEDICAL GAS DEMO
M211	GROUND LEVEL - VENTILATION
M221	BASEMENT LEVEL - PLUMBING DRAINAGE
M222	GROUND LEVEL - PLUMBING DRAINAGE
M223	GROUND LEVEL - PLUMBING WATER
M231	GROUND LEVEL - FIRE PROTECTION
M241	BASEMENT LEVEL - HVAC PIPING
M242	GROUND LEVEL - HVAC PIPING
M251	GROUND LEVEL - MEDICAL GAS
M401	MECHANICAL DETAILS
M402	MECHANICAL DETAILS
M403	MECHANICAL DETAILS
M500	MECHANICAL SCHEDULES
ELECTRICAL	
E001	ELECTRICAL LEGEND AND DRAWING LIST
E002	KEY PLAN
E100	POWER & SYSTEMS PLAN - DEMOLITION
E101	LIGHTING PLAN - DEMOLITION
E200	POWER & SYSTEMS PLAN - FITOUT
E201	LIGHTING PLAN - FITOUT
E202	ENLARGED ELECTRICAL ROOM
E301	SINGLE LINE DIAGRAM
E302	LUMINARE SCHEDULE
E303	PANEL SCHEDULES
E304	CT WIRING DETAILS
E305	CT WIRING DETAIL
E306	X-RAY WIRING DETAILS



ARCHITECTS



Stantec Architecture Ltd.
200 - 835 Paramount Drive
Stoney Creek, ON, L8J 0B4
Tel. 905-385-3234
www.stantec.com

CONSULTANTS

MECHANICAL

STANTEC CONSULTING LTD.
100-401 WELLINGTON STREET WEST
TORONTO ON M5V 1E7
Tel. 416-596-6666
www.stantec.com


ELECTRICAL

STANTEC CONSULTING LTD.
100-401 WELLINGTON STREET WEST
TORONTO ON M5V 1E7
Tel. 416-596-6666
www.stantec.com

ISSUED FOR:

ISSUED FOR
CONSTRUCTION

2025-06-11



1	ISSUED FOR ADDENDUM 1	NA	BDM	25.05.02
Revision		By	Appd.	YY.MM.DD
3	ISSUED FOR CONSTRUCTION	BDM	BDM	25.06.11
2	ISSUED FOR TENDER & PERMIT	BDM	BDM	25.04.07
1	ISSUED FOR COSTING	BDM	BDM	25.01.06
Issued		By	Appd.	YY.MM.DD
File Name:		Dwn.	Chkd.	Dsgn.
				YY.MM.DD




FLOOR PLAN SYMBOLS LEGEND

ROOM NAME	ROOM NAME AND ROOM NUMBER
1 A100	DETAIL BUBBLE
1 A100	INTERIOR ELEVATION REFERENCE
3375	DIMENSION
E1	EXISTING GRID LINE AND GRID BUBBLE
P1	EXISTING WALL
F1	PARTITION AND PARTITION TYPE
1	FURRING AND FURRING TYPE
1	WALL PROTECTION
1	EXISTING SCREEN
S100	NEW SCREEN AND SCREEN NUMBER
1	EXISTING DOOR AND FRAME
D100	NEW DOOR AND FRAME AND DOOR NUMBER
PP	PUSH PLATE/PROXIMITY READER
CR	CARD READER

5 FLOOR PLAN SYMBOLS LEGEND

A001 SCALE: N.T.S.



1 LOCATION PLAN

A001 SCALE: N.T.S.

DEMOLITION PLAN SYMBOLS LEGEND

EXISTING WALL
EXISTING ITEMS TO BE REMOVED
EXISTING WALL/PARTITION OR FURRING
REMOVE EXISTING FINISH MATERIAL ON ONE SIDE ONLY OR AS OTHERWISE NOTED.
EXISTING PARTITION OR FURRING AND/OR FITMENTS TO BE REMOVED. SCOPE OF WORK INCLUDES REMOVAL OF SPEED TILE, CONCRETE BLOCK, GYPSUM WALL BOARD, GLASS BLOCK, ETC.
EXISTING WINDOW OR SCREEN
EXISTING WINDOW OR SCREEN TO BE REMOVED
EXISTING DOOR AND FRAME
EXISTING DOOR AND FRAME TO BE REMOVED
EXISTING PLUMBING FIXTURES TO REMAIN (INCLUDES SINKS, TOILETS, SHOWERS, TUBS, ETC.) REFER TO MECHANICAL DRAWINGS
EXISTING PLUMBING FIXTURES TO BE REMOVED (INCLUDES SINKS, TOILETS, SHOWERS, TUBS, ETC.) REFER TO MECHANICAL DRAWINGS
EXISTING MILLWORK/CASEWORK
EXISTING MILLWORK/CASEWORK TO BE REMOVED (INCLUDES ANY/ALL PLUMBING ACCESSORIES LOCATED WITHIN MILLWORK/CASEWORK).

6 DEMOLITION PLAN SYMBOLS LEGEND

A001 SCALE: N.T.S.

FLOOR PLAN NOTES:

- ALL PATCHING AND REPAIRING OF SURFACES ARE NOT NECESSARILY SHOWN. PATCH AND REPAIR ALL EXISTING SURFACES SCHEDULED TO RECEIVE NEW FINISHES SO THAT ALL SURFACES WHEN COMPLETE RESEMBLE A NEW INSTALLATION.
- ALL DIMENSIONS DENOTED AS "x" ARE TO BE SITE MEASURED AND VERIFIED BY THE CONTRACTOR PRIOR TO ANY CONSTRUCTION. CONTRACTOR TO ADVISE THE CONSULTANT (IN ADVANCE) IN WRITING OF DEVIATIONS (SITE CONDITIONS) FROM EXISTING BASE BUILDING DRAWINGS INFORMATION. ADVISE CONSULTANT FOR COORDINATION OF WORK.
- UPPERTAIN ALL FIRE RATINGS IN EXISTING BUILDING AFFECTED BY THE REMOVAL, RELOCATION, OR INSTALLATION OF NEW WORK.
- SITE VERIFY AND REVIEW ALL EXISTING CONDITIONS PRIOR TO THE COMMENCEMENT OF ANY FABRICATION OR CONSTRUCTION RELATED TO THE PROJECT.

P1	3 3/4" METAL STUDS 1'-4" O/C TO UNDERSIDE OF STRUCTURE ABOVE	P3	6" METAL STUDS 406mm O/C TO UNDERSIDE OF STRUCTURE ABOVE	F2	2 1/2" METAL STUDS 1'-4" O/C TO UNDERSIDE OF STRUCTURE ABOVE
P2 (1 HR)	92mm METAL STUDS 1'-4" O/C TO UNDERSIDE OF STRUCTURE ABOVE	F0	3/4" GYPSUM BOARD TO UNDERSIDE OF STRUCTURE ABOVE	F3	3 3/4" METAL STUDS 1'-4" O/C TO UNDERSIDE OF STRUCTURE ABOVE
	1/2" FIRE RATED GYPSUM BOARD TO UNDERSIDE OF STRUCTURE ABOVE		1/2" GYPSUM BOARD TO 6" ABOVE HIGHEST ADJACENT FINISHED CEILING		3/4" GYPSUM BOARD TO 6" ABOVE HIGHEST ADJACENT FINISHED CEILING
	ULC DESIGN NO. W407 WITH STUD SPACING MODIFIED	F1	3/4" METAL FURRING 1'-4" O/C TO UNDERSIDE OF STRUCTURE ABOVE	F4	6" METAL STUDS 1'-4" O/C TO UNDERSIDE OF STRUCTURE ABOVE
			3/4" GYPSUM BOARD TO 6" ABOVE HIGHEST ADJACENT FINISHED CEILING		3/4" GYPSUM BOARD TO 6" ABOVE HIGHEST ADJACENT FINISHED CEILING

PARTITION AND FURRING TYPE NOTES:

- ALL PARTITIONS/FURRING TO EXTEND TO U/S OF DECK/STRUCTURE ABOVE UNLESS INDICATED OTHERWISE.
- SUBSTITUTE GYPSUM BOARD WITH CEMENTITIOUS BOARD (CBM/BO) WHERE TILE WALL FINISHES ARE INDICATED ON THE DRAWINGS OR ROOM FINISH SCHEDULE. PROVIDE HEAVIER GLUZE METAL STUDS AS SPECIFIED IN METAL SUPPORT ASSEMBLIES AT ALL PARTITIONS WITH CEMENTITIOUS BOARD.
- ALL PARTITIONS/FURRING ARE TO BE REINFORCED TO ACCOMMODATE GUARDS, HANDRAILS, BUMPERS, WALL HUNG COUNTERS, GRAB BARS WHERE INDICATED. PROVIDE THE NECESSARY BRACING/BLOCKING AS REQUIRED.
- UNLESS OTHERWISE NOTED, WHERE FURRING TYPE IS SHOWN AT A COLUMN, FURRING TYPE APPLIES TO ALL SIDES OF COLUMN NOT FORMING PART OF ADJACENT WALL(S).
- ALL VERTICAL PIPING (EXCEPT WHERE SHOWN EXPOSED IN SERVICE ROOMS OR LOCATED IN A RATED SHAFT) TO BE ENCLOSED WITH GYPSUM WALL BOARD AND STEEL STUDS FRAMING TO ABOVE CEILING AND KEPT TO MINIMUM HORIZONTAL DIMENSION.
- ALL GYPSUM WALLBOARD TO BE PAPERLESS.
- "S" SUFFIX DENOTES MINERAL FIBRE SOUND INSULATION FOR THE FULL HEIGHT OF THE PARTITION.
- "L" SUFFIX DENOTES LEAD SHEET RADIATION PROTECTION TO BE INSTALLED TO A MINIMUM OF 2.13 M ABOVE FINISHED FLOOR. PROVIDE HEAVIER GLUZE METAL STUDS AS SPECIFIED IN METAL SUPPORT ASSEMBLIES AT ALL PARTITIONS WITH LEAD SHEET RADIATION PROTECTION.
- "P" SUFFIX DENOTES 3/4" PLYWOOD ON NOTED SIDE.

2 FLOOR PLAN NOTES

A001 SCALE: N.T.S.

REFLECTED CEILING PLAN SYMBOLS LEGEND

GYPSUM BOARD CEILING / BULKHEAD
CEILING GRID
OCCUPANCY SENSOR
SPRINKLER HEAD
CEILING MOUNTED EXIT SIGN
FIRE ALARM DEVICE
WALL MOUNTED EXIT SIGN
SMOKE DETECTOR- REFER TO ELECTRICAL
CEILING MOUNTED FIRE ALARM COMBINATION SMOKE / STROBE
POT LIGHT
RETURN AIR DIFFUSER
LIGHT FIXTURE
DOME LIGHT
SUPPLY AIR GRILLE
PAGING SPEAKER
ACCESS DOOR/HATCH
EXISTING DIFFUSER TO REMAIN
EXISTING LIGHT FIXTURE TO REMAIN
EXISTING RETURN AIR GRILLE TO REMAIN
WIRELESS ACCESS POINT
FIRE ALARM CONE SPEAKER
LV TRACK

7 REFLECTED CEILING PLAN LEGEND

A001 SCALE: N.T.S.

REFLECTED CEILING PLAN NOTES:

- WHERE NEW CEILING MATERIALS ARE INDICATED ON REFLECTED CEILING PLAN OR ROOM FINISH SCHEDULE, REMOVE EXISTING CEILING SYSTEMS AND BULKHEADS COMPLETELY INCLUDING SUSPENSION SYSTEM AND HANGERS, THEN INSTALL A COMPLETE NEW CEILING SYSTEM.
- REMOVE AND REINSTALL EXISTING CEILING TILES AND SERVICES AS REQUIRED TO EFFECT MECHANICAL AND ELECTRICAL WORK. REFER TO MECHANICAL AND ELECTRICAL DOCUMENTS. REPLACE ALL CEILING TILES, GRID AND SERVICE DAMAGES AS A RESULT OF REMOVAL AND/OR REINSTALLATION WITH NEW TO MATCH EXISTING IN SIZE, COLOUR, TEXTURE AND FUNCTION.
- ALL PATCHING AND REPAIRING OF CEILINGS AND CEILING SURFACES ARE NOT NECESSARILY SHOWN. PATCH, REPAIR AND REFINISH ALL EXISTING SURFACES AFFECTED BY CONSTRUCTION ACTIVITIES (INCLUDING DEMOLITION AND INSTALLATION OF NEW BUILDING SERVICES) SO THAT ALL SURFACES WHEN COMPLETE RESEMBLE A NEW INSTALLATION.
- REFER TO MECHANICAL AND ELECTRICAL DOCUMENTS FOR QUANTITIES OF CEILING DEVICES.
- EXISTING CEILINGS TO REMAIN ARE SHOWN LIGHTER THAN NEW WORK.
- OR HEIGHTS OF CEILINGS AND BULKHEADS, REFER TO ROOM FINISH SCHEDULE.

DEMOLITION NOTES:


- REFER TO MECHANICAL AND ELECTRICAL DRAWINGS FOR ASSOCIATED DEMOLITION. COORDINATE WITH MECHANICAL AND ELECTRICAL DRAWINGS FOR THE EXTENT OF CHANGE TO EXISTING LIGHTING, POWER, FIRE ALARM AND DOOR SECURITY SYSTEMS WITHIN EXISTING TO REMAIN.
- WHERE EXISTING SURFACES ARE DISTURBED DUE TO DEMOLITION OR ALTERATIONS, AND NOT REQUIRED TO BE COVERED WITH NEW FINISHES, SUCH SURFACES SHALL BE MADE GOOD TO MATCH EXISTING MATERIALS AND FINISHES.
- MAKE GOOD ALL MATERIALS, AND FINISHES WHERE DISTURBED AND WHERE ALTERATIONS OCCUR. REFER TO ALL DRAWINGS FOR FULL EXTENT OF WORK REQUIRED; NOTE THAT MAKING GOOD INCLUDES WORK ASSOCIATED WITH THE REMOVAL OF EXISTING AND INSTALLATION OF NEW SERVICES, ETC. (EXAMPLES: FIRE ALARM MODIFICATIONS, REMOVAL OF SPEAKERS, SMOKE DETECTORS ETC.)
- WHERE EXISTING WALLS, PARTITIONS OR FURRINGS AND BUILDING FITMENTS ARE BEING REMOVED, MAKE GOOD SUBSTRATES TO RECEIVE NEW SPECIFIED MATERIALS AND FINISHES.
- WHERE EXISTING SERVICES ARE BEING REMOVED AND EXISTING STRUCTURAL SLAB PENETRATIONS ARE EXPOSED, INFILL EXISTING SLAB PENETRATIONS WITH CONCRETE WITH FIRE RATING TO MATCH EXISTING ADJACENT FLOOR SLAB, AND MAKE GOOD FLOOR SLAB TO BE SMOOTH AND LEVEL. FLOOR SLAB TO BE VOID OF WAVES, BUMPS IN MATERIALS /FINISHES, OR DEPRESSIONS.
- WHERE NEW FLOORING MATERIALS ARE INDICATED ON FLOOR PLAN OR ROOM FINISH SCHEDULE, COMPLETELY REMOVE EXISTING FLOORING TO EXPOSE STRUCTURAL FLOOR SLAB. PATCH, FILL HOLES IN SLAB, REPAIR AND MAKE GOOD EXISTING FLOOR SLAB TO BE SMOOTH AND LEVEL. FLOOR SLAB TO BE VOID OF WAVES, BUMPS IN MATERIALS/FINISHES OR DEPRESSIONS. EXISTING FLOOR SLAB TO ACCEPT NEW SPECIFICATIONS AND FLOORING MANUFACTURER REQUIREMENTS.

REFLECTED CEILING PLAN KEYNOTES:

- REMOVE ACT CEILING TILES AND ASSOCIATED CEILING FIXTURES AS REQUIRED TO ACCOMMODATE DEMOLISHING EXISTING MECHANICAL SYSTEMS AND ADDING NEW STRUCTURAL AND MECHANICAL INSTALLATIONS. PLACE BACK ALL ACT CEILING TILES AND ASSOCIATED CEILING FIXTURES. REFER TO MECHANICAL AND STRUCTURAL DOCUMENTS FOR FULL EXTENT OF WORK.
- CUT BACK A PORTION OF GWB CEILING AS REQUIRED TO ACCOMMODATE DEMOLISHING EXISTING MECHANICAL SYSTEMS AND ADDING NEW STRUCTURAL AND MECHANICAL INSTALLATIONS. PATCH, REPAIR AND PAINT GWB CEILING TO MATCH THE EXISTING CEILING. REFER TO MECHANICAL AND STRUCTURAL DOCUMENTS FOR FULL EXTENT OF WORK.
- REMOVE GWB CEILING SYSTEM AND ASSOCIATED CEILING FIXTURES.
- REMOVE ACT CEILING SYSTEM AND ASSOCIATED CEILING FIXTURES.
- REMOVE GWB CEILING SYSTEM AND ASSOCIATED CEILING FIXTURES. GO TO INVESTIGATE THE EXISTING BULKHEAD TO IDENTIFY ANY CONCEALED UTILITIES/STRUCTURAL ELEMENTS PRIOR TO DEMOLITION.


3 REFLECTED CEILING PLAN & DEMOLITION NOTES

A001 SCALE: N.T.S.



4 TYPICAL WALL PROTECTION DETAILS

A001



The Contractor shall verify and be responsible for all dimensions. DO NOT scale the drawing - any errors or omissions shall be reported to Stantec without delay.
The Copyrights to all designs and drawings are the property of Stantec. Reproduction or use for any purpose other than that authorized by Stantec is forbidden.

Keyplan 

1	ISSUED FOR ADDENDUM 1	NA	BDM	25.05.02
Revision		By	Appd.	YY.MM.DD
3	ISSUED FOR CONSTRUCTION	BDM	BDM	25.06.11
2	ISSUED FOR TENDER & PERMIT	BDM	BDM	25.04.07
1	ISSUED FOR COSTING	BDM	BDM	25.01.06
Issued		By	Appd.	YY.MM.DD
File Name:				
		Own.	Chkd.	Dsgn.
				YY.MM.DD

ONTARIO ASSOCIATION
 OF
 ARCHITECTS
Brian D. Moeller
 BRIAN D. MOELLER
 LICENCE
 4336

Client/Project

SCARBOROUGH HEALTH NETWORK
GENERAL HOSPITAL

SATELLITE IMAGING RENOVATION


3050 Lawrence Ave East, Scarborough, Ontario

Title
PARTIAL GROUND FLOOR PLAN
LIFE SAFETY PLAN


Project No.	Scale
140023034	

Drawing No.	Sheet	Revision
-------------	-------	----------

A100 of **0**

[illegible]

Ontario Building Code Data Matrix, Part 11
© Ontario Association of Architects




1	ISSUED FOR ADDENDUM 1	NA	BDM	25.05.02
Revision		By	Appd.	YY.MM.DD
3	ISSUED FOR CONSTRUCTION	BDM	BDM	25.06.11
2	ISSUED FOR TENDER & PERMIT	BDM	BDM	25.04.07
1	ISSUED FOR COSTING	BDM	BDM	25.01.06
Issued		By	Appd.	YY.MM.DD
File Name:		Dwn.	Chkd.	Dsgn.
				YY.MM.DD



SCARBOROUGH HEALTH NETWORK
GENERAL HOSPITAL
SATELLITE IMAGING RENOVATION

3050 Lawrence Ave East, Scarborough, Ontario

DEMOLITION FLOOR PLAN




DEMOLITION PLAN KEYNOTES

- 1 REMOVE EXISTING WALL MOUNTED EXAM LIGHTS.
- 2 REMOVE EXISTING WALL TILE.
- 3 REMOVE EXISTING WALL PROTECTION.
- 4 REMOVE AND DISPOSE ALL EXISTING XRAY/CT EQUIPMENT AND ASSOCIATED INCLUDING, ELECTRICAL COMPONENTS AND WALL BUCKIES, ETC. STRUCTURAL STEEL SUPPORT ASSEMBLY FOR CEILING MOUNTED EQUIPMENT.
- 5 REMOVE EXISTING PATIENT LIFT INCLUDING THE ABOVE CEILING SUPPORT ASSEMBLY.
- 6 EXISTING CURTAIN TRACK TO BE REMOVED
- 7 EXISTING LEAD LINED PARTITION TO REMAIN
- 8 REMOVE EXISTING WINDOW ASSEMBLY, WINDOW STOOL AND CONVECTOR AND GWB ENCLOSURE
- 9 REMOVE EXISTING WINDOW ASSEMBLY AND CONVECTOR. WINDOW STOOL TO REMAIN

DEMOLITION NOTES:

1. ALL PERIMETER X-RAY ROOM AND CT ROOM PARTITIONS AND CONTROL SCREENS IN THE EXISTING CT AND XRAY ROOMS CONTAIN LEAD LINING TO BE REMOVED
2. EXAM LIGHTS AND PATIENT LIFTS TO BE TURNED OVER TO OWNER.
3. REMOVE ALL FITMENTS AND EQUIPMENT FASTENED TO WALLS AND PARTITIONS THROUGHOUT THE AREA OF WORK.



1	ISSUED FOR ADDENDUM 1	NA	BDM	25.05.02
Revision		By	Appd.	YY.MM.DD
3	ISSUED FOR CONSTRUCTION	BDM	BDM	25.06.11
2	ISSUED FOR TENDER & PERMIT	BDM	BDM	25.04.07
1	ISSUED FOR COSTING	BDM	BDM	25.01.06
Issued		By	Appd.	YY.MM.DD
File Name:		Dwn.	Chkd.	Dsgn.
				YY.MM.DD




Client/Project
**SCARBOROUGH HEALTH NETWORK
GENERAL HOSPITAL
SATELLITE IMAGING RENOVATION**

3050 Lawrence Ave East, Scarborough, Ontario

Title
PARTIAL GROUND FLOOR PLAN


Project No.	Scale
140023034	1/4"=1'-0"
Drawing No.	Sheet
	Revision

A401 of 0



FLOOR PLAN KEYNOTES

- 1 INFILL EXISTING WINDOW OPENINGS - SEE DETAIL 3&4/A902 LEAD LINING AS INDICATED ON PLAN
- 2 PROVIDE ALUMINUM WINDOWS WITH LOW E THERMAL PANES - SEE DETAIL 1&2/A902
- 3 PROVIDE EXHAUST FOR SHOE CABINET. REFER TO MECH FOR ASSOCIATED DUCTWORK.
- 4 PROVIDE CHANGE CUBICLE PARTITION AND DOOR INFILL EXISTING DOORWAY OPENING WITH METAL STUDS AND GWB FLUSH WITH BOTH FACES OF EXIST PARTITION. PATCH RUBBER BASE
- 5 NOT USED
- 6 NOT USED
- 7 EXISTING LEAD LINED PARTITION TO REMAIN
- 8 NOT USED
- 9 NOT USED
- 10 IMAGING EQUIPMENT ISO CENTRE
- 11 SILENTIA PRIVACY SCREENS
- 12 REPACE DOOR AND FRAME. PATCH AND PAINT TO MATCH EXISTING



1	ISSUED FOR ADDENDUM 1	NA	BDM	25.05.02
Revision		By	Appd.	YY.MM.DD
3	ISSUED FOR CONSTRUCTION	BDM	BDM	25.06.11
2	ISSUED FOR TENDER & PERMIT	BDM	BDM	25.04.07
1	ISSUED FOR COSTING	BDM	BDM	25.01.06
Issued		By	Appd.	YY.MM.DD
File Name:				
		Dwn.	Chkd.	Dsgn.
				YY.MM.DD



SCARBOROUGH HEALTH NETWORK
GENERAL HOSPITAL
SATELLITE IMAGING RENOVATION

3050 Lawrence Ave East, Scarborough, Ontario

EQUIPMENT PLAN

Project No.
140023034

Scale
1/4"=1'-0"

Drawing No.


Sheet

Revision

A402

of

0



GENERAL NOTES

1. REFER TO FF&E RESPONSIBILITIES LIST

FLOOR PLAN KEYNOTES

- 1 NOT USED
- 2 PROVIDE A COOLING SYSTEM FLOW HEATER CABINET SUPPORT- SEE DETAIL 7/A902
- 3 PROVIDE INDOOR COOLING SYSTEM SUPPORT- SEE DETAIL 8/A902
- 4 PROVIDE SILENTIA PRIVACY SCREENS
- 5 WALL MOUNT THAT IS WIDTH AND HEIGHT ADJUSTABLE TO FIT THE MOUNTING HOLES ON A 32" TO 42" DIAGONAL FLAT PANEL MONITORS UP TO 170 LBS. AS RECOMMENDED BY THE TV MANUFACTURER. THE TV MOUNT SHALL FEATURE A 0-15 DEGREE FORWARD TILT ADJUSTMENT, WITH HEAVY-DUTY ARM WHICH ALLOWS THE MONITOR TO BE PULLED OUT FROM THE WALL UP TO 16 1/2". MOUNT SHALL BE ULC LISTED. SOLID BLOCKING FOR ATTACHMENT TO BE PROVIDED IN LOCATION AS DIRECTED BY THE CONSULTANT.

ABBREVIATIONS:

BLIND ROLLER BLIND
CLK CLOCK
GD GLOVE DISPENSER, TRIPLE
HD HAND SANITIZER DISPENSER
HHS HAND HYGIENE SINK
MIR MIRROR
PPE PERSONAL PROTECTIVE EQUIPMENT
PTB PATIENT TRANSFER BOARD
PTD PAPER TOWEL DISPENSER
RHB ROBE HOOK
SD SOAP DISPENSER
SHP SHARPS CONTAINER
TP TOILET PAPER DISPENSER
WB WHITEBOARD

\\s0224-prfs01\shared_projects\140023034\140023034\01_architecture\01_con\01_sheets\GEN- Ground Floor Plan_2025-02-19.dwg
2025/06/06 10:19 AM By: Moeller, Brian

ORIGINAL SHEET - Arch D

Rm No.	Rm Name	Supply	Install	Item	
G4520	Waiting area ER	Owner	Owner	Chairs	✓
		Owner	Owner	End table	✓
		Vendor	Vendor	Television	✓
		Owner	Owner	Waste receptacle(s)	✓
		Owner	Contractor	Hand sanitizer	✓
		Owner	Contractor	Security camera	✓
G4519	Washroom (beside ER wait)	Owner	Contractor	Paper towel dispenser	✓
		Owner	Contractor	Toilet paper dispenser	✓
		Owner	Contractor	Soap dispenser	✓
		Owner	Owner	Waste receptacle	✓
		Contractor	Contractor	Nurse call	✓
		Contractor	Contractor	Mirror	✓
		Contractor	Contractor	Coat hooks	✓
		Contractor	Contractor	Grab bar	✓
		Owner	Contractor	Paper towel dispenser	✓
		Owner	Contractor	Toilet paper dispenser	✓
G4501	Washroom - ultrasound	Owner	Contractor	Soap dispenser	✓
		Owner	Contractor	Waste receptacle	✓
		Contractor	Contractor	Sanitary Napkin Dispenser	✓
		Contractor	Contractor	Nurse call	✓
		Contractor	Contractor	Mirror	✓
		Contractor	Contractor	Coat hooks	✓
		Contractor	Contractor	Grab bar	✓
		Owner	Owner	Ultrasound scanner	✓
		Owner	Owner	Transducer rack, wall mount	✓
		Owner	Owner	Stretcher	✓
G4502	Ultrasound	Contractor	Contractor	Code blue/staff assist	✓
		Owner	Owner	Chair, sonographer	✓
		Owner	Owner	Chair, guest, sled base	✓
		Owner	Owner	Computer & monitor	✓
		Owner	Owner	Linen storage cart	✓
		Owner	Owner	Hamper, linen, soiled w lid	✓
		Owner	Owner	Procedure cart, small	✓
		Owner	Owner	Telephone, desk mount	✓
		Owner	Owner	Regulator oxygen	x
		Owner	Owner	Regulator suction	x
		Owner	Contractor	Paper towel dispenser	✓
		Owner	Owner	Soap dispenser	✓
		Owner	Owner	Waste receptacle	x
		Owner	Contractor	Hand sanitizer dispenser, wall mount	✓
		Owner	Contractor	Glove dispenser, triple	✓
		Owner	Contractor	Sharps container	x
		Owner	Owner	Document Scanner	✓
		Owner	Contractor	Hand sanitizer dispenser, wall mount	✓
		Owner	Contractor	CCTV display	✓
		Contractor	Contractor	Clock	✓
		Owner	Owner	laser printer	✓
		Contractor	Contractor	Desk or built-in millwork	✓
G4503	Stretcher hold-U/S	Owner	Owner	Transducer storage cabinet	✓
		Owner	Owner	Regulator oxygen	x
		Owner	Owner	Regulator suction	x
		Contractor	Contractor	Nurse call	✓
		Owner	Owner	Waste receptacle	x
		Owner	Contractor	PPE dispenser, wall mount	✓
		Owner	Contractor	Hand sanitizer dispenser, wall mount	✓
		Owner	Owner	supply cart	✓
		Owner	Contractor	Paper towel dispenser	✓
		Owner	Contractor	Soap dispenser	✓
G504	Soiled	Owner	Owner	Waste receptacle	✓
		Owner	Contractor	Hand sanitizer dispenser, wall mount	✓
		Owner	Owner	SS cart for MDRD transport	✓
		Owner	Owner	Rack, wire storage	✓
		Owner	Owner	Table	✓
		Owner	Owner	Chairs, stackable, Qty TBD/fit	✓
		Owner	Owner	Microwave oven	✓
		Owner	Owner	Refrigerator, full-size, no freezer	✓
		Contractor	Contractor	Water cooler, H&C, plumbed, no bottles	✓
		Owner	Contractor	Telephone, wall mount	✓
G4505	Team room	Owner	Owner	Television	✓
		Contractor	Contractor	Television wall mount bracket	✓
		Contractor	Contractor	Lockers, purse, 2 banks of 6	✓
		Contractor	Contractor	Coat rack	✓
		Contractor	Contractor	Shoe/boot rack	✓
		Owner	Contractor	Paper towel dispenser	✓
		Owner	Contractor	Soap dispenser	✓
		Owner	Owner	Waste receptacle	✓
		Owner	Contractor	White board	✓
		Owner	Owner	kettle	x
		Owner	Contractor	Hand sanitizer dispenser, wall mount	✓
		Owner	Owner	Table	✓
		Owner	Owner	Chairs, stackable, Qty TBD/fit	✓
		Owner	Owner	Microwave oven	✓
		Owner	Owner	Refrigerator, full-size, no freezer	✓

Rm No.	Rm Name	Supply	Install	Item	
G4506	Stretcher hold	Owner	Contractor	Paper towel dispenser	✓
		Owner	Contractor	Soap dispenser	✓
		Owner	Owner	Waste receptacle	✓
		Owner	Contractor	Hand sanitizer dispenser, wall mount	x
		Owner	Owner	Code blue cart w defib	✓
		Owner	Owner	Chair, sled base Qty TBD	✓
		Owner	Owner	Cart, storage, supply Qty TBD	✓
		Contractor	Contractor	Screen, privacy, mobile Size/Qty TBD	✓
		Owner	Owner	Regulator oxygen	x
		Owner	Owner	Regulator suction	x
		Owner	Owner	Hamper, linen, soiled w lid	✓
		Contractor	Contractor	Code blue/staff assist	✓
		Contractor	Contractor	Window blinds	✓
		Vendor	Vendor	CT control console	✓
		Vendor	Vendor	Injector console	✓
G4507	CT Control	Owner	Owner	Chair, high stool w foot ring x 2	✓
		Owner	Owner	Chair, task	✓
		Contractor	Contractor	Desk	✓
		Contractor	Contractor	Pedestal	✓
		Contractor	Contractor	Printer stand	✓
		Owner	Owner	Telephone, desk top x 2	✓
		Owner	Owner	Computer w monitor x 2	✓
		Owner	Owner	Document scanner	✓
		Owner	Owner	Multifunction printer	✓
		Owner	Contractor	Whiteboard	✓
		Owner	Contractor	Hand sanitizer dispenser, wall mount	✓
		Owner	Owner	Waste receptacle	x
		Owner	Contractor	PPE dispenser, wall mount	✓
		Owner	Contractor	Telephone, interpretation	✓
		Owner	Owner	Label Printer	✓
G4508	CT Gantry	Owner	Owner	Shred bin for confidential waste	✓
		Contractor	Contractor	Code blue/staff assist	✓
		Contractor	Contractor	Clock	✓
		Owner	Contractor	CCTV display	✓
		Contractor	Contractor	Window blinds	✓
		Vendor	Vendor	CT scanner w table	✓
		Owner	Vendor	Injector, mobile pedestal	✓
		Vendor	Vendor	Ceiling lift	✓
		Owner	Owner	Cart, storage, supply	✓
		Owner	Owner	Cart, procedure	✓
		Owner	Contractor	Patient transfer board, wall mount	✓
		Owner	Contractor	Apron rack, wall mount	✓
		Owner	Owner	Apron, lead	x
		Owner	Contractor	Paper towel dispenser	✓
		Owner	Owner	Soap dispenser	✓
G4509	CT Equipment	Owner	Contractor	Hand sanitizer dispenser, wall mount	x
		Owner	Contractor	Sharps disposal	✓
		Owner	Owner	Regulator oxygen	x
		Owner	Owner	Regulator suction	x
		Owner	Owner	Contrast media warmer	✓
		Owner	Owner	Dump sink w millwork w shelf for warmer	✓
		Owner	Owner	Monitor, patient, mobile	✓
		Owner	Owner	Table, ss instrument	✓
		Owner	Owner	Telephone, wall mount	✓
		Contractor	Contractor	Code blue/staff assist	✓
		Contractor	Contractor	IV track, ceiling	✓
		Owner	Owner	Foot stool w handle	✓
		Owner	Owner	Hamper, linen, soiled w lid	✓
		Owner	Contractor	Glove dispenser, triple	✓
		Owner	Owner	IV pole	✓
G4510	Linen alcove	Owner	Owner	Instrument table	✓
		Contractor	Contractor	Clock	✓
		Contractor	Contractor	Eyewash station	✓
		Vendor	Vendor	Will depend on scanner equipment	✓
		Owner	Owner	Cart, wire, linen 24"Dx60"Wx?H	✓


Rm No.	Rm Name	Supply	Install	Item	
G4511	X-ray-south	Vendor	Vendor	X-ray system w table & upright bucky	✓
		Vendor	Vendor	Ceiling lift	✓
		Owner	Owner	Cart, storage, supply	✓
		Owner	Owner	Cart, procedure	✓
		Owner	Contractor	Patient transfer board, wall mount	✓
		Owner	Contractor	Apron rack, wall mount	✓
		Owner	Owner	Apron, lead	x
		Owner	Owner	Apron, lead half-size, mobile	✓
		Owner	Contractor	Paper towel dispenser	✓
		Owner	Contractor	Soap dispenser	✓
		Owner	Vendor	Waste receptacle	x
		Owner	Contractor	Hand sanitizer dispenser, wall mount	✓
		Owner	Contractor	Sharps disposal	✓
		Owner	Owner	Regulator oxygen	x
		Owner	Owner	Regulator suction	x
		Owner	Owner	Table, ss instrument	✓
		Contractor	Contractor	Code blue/staff assist	✓
		Owner	Owner	Foot stool w handle	✓
		Owner	Owner	Hamper, linen, soiled w lid	✓
		Owner	Contractor	Glove dispenser, triple	✓
		Owner	Owner	Stool, no arms, no wheels	✓
		Owner	Contractor	Telephone, wall mount	✓
		Owner	Owner	IV pole	✓
		Contractor	Contractor	Upper cupboard lock	✓
		Contractor	Contractor	Clock	✓
G4512	X-ray Control	Vendor	Vendor	X-ray control x 2	✓
		Owner	Owner	Chair, high stool w foot ring x 2	✓
		Contractor	Contractor	Desk	✓
		Owner	Owner	Pedestal	✓
		Owner	Owner	Chair, task x 1	✓
		Owner	Owner	Laser printer	✓
		Owner	Contractor	Printer stand	✓
		Contractor	Contractor	Telephone, desk top x 2	✓
		Owner	Owner	Computer w monitor x 2	✓
		Owner	Owner	Document scanner x 2	✓
		Owner	Contractor	Whiteboard	✓
		Owner	Contractor	Hand sanitizer dispenser, wall mount	✓
		Owner	Owner	Waste receptacle x 2	x
		Owner	Contractor	PPE dispenser, wall mount	✓
		Owner	Owner	Cart, storage, supply	✓
		Owner	Contractor	Telephone, interpretation	✓
		Owner	Contractor	CCTV display	✓
		Contractor	Contractor	Clock	✓
G4513	X-ray-north	Vendor	Vendor	X-ray system w table & upright bucky	✓
		Vendor	Vendor	Ceiling lift	✓
		Owner	Owner	Cart, storage, supply	✓
		Owner	Owner	Cart, procedure	✓
		Owner	Contractor	Patient transfer board, wall mount	✓
		Owner	Contractor	Apron rack, wall mount	✓
		Owner	Owner	Apron, lead	✓
		Owner	Owner	Apron, lead half-size, mobile	✓
		Owner	Contractor	Paper towel dispenser	✓
		Owner	Contractor	Soap dispenser	✓
		Owner	Owner	Waste receptacle	✓
		Owner	Contractor	Hand sanitizer dispenser, wall mount	✓
		Owner	Contractor	Sharps disposal	✓
		Owner	Owner	Regulator oxygen	x
		Owner	Owner	Regulator suction	x
		Owner	Owner	Table, ss instrument	✓
		Contractor	Contractor	Code blue/staff assist	✓
		Owner	Owner	Foot stool w handle	✓
		Owner	Owner	Hamper, linen, soiled w lid	✓
		Owner	Contractor	Glove dispenser, triple	✓
		Owner	Owner	Stool, no arms, no wheels	✓
		Owner	Contractor	Telephone, wall mount	✓
		Owner	Owner	IV pole	✓
		Contractor	Contractor	Upper cupboard lock	✓
		Contractor	Contractor	Clock	✓
G4514	Change room	Owner	Owner	3' standing patient "screen"	✓
		Contractor	Contractor	Remove curtain, add door	✓
		Owner	Owner	Hamper, linen soiled w lid	✓
		Contractor	Contractor	Gown storage	✓
		Owner	Owner	Chair, bariatric or regular	✓
G4515	Housekeeping room	N/A	N/A		
G4516	Washroom-X-ray/CT	N/A	N/A	Add card swipe for staff only	
G4517	Waiting area Fracture Clinic	Owner	Owner	Chairs, Qty TBD after layout finalized	✓
		Owner	Owner	End tables, TBD after layout finalized	✓
		Owner	Contractor	Hand sanitizer dispenser, wall mount	✓
TBD	Fracture CI Waiting W/R	Owner	Contractor	Paper towel dispenser	✓
		Owner	Contractor	Toilet paper dispenser	✓
		Owner	Contractor	Soap dispenser	✓
G4510	Linen alcove	Owner	Owner	Waste receptacle	x
		Contractor	Contractor	Nurse call	✓
		Contractor	Contractor	Mirror	✓
G4510	Linen alcove	Contractor	Contractor	Coat hooks	✓
		Contractor	Contractor	Grab bar	✓
		Contractor	Contractor		✓



Stantec Architecture Ltd.
200 - 835 Paramount Drive
Stoney Creek, ON, L8J 0B4
Tel. 905-385-3234
www.stantec.com

Copyright Reserved

The Contractor shall verify and be responsible for all



1	ISSUED FOR ADDENDUM 1	NA	BDM	25.05.02
Revision		By	Appd.	YY.MM.DD
3	ISSUED FOR CONSTRUCTION	BDM	BDM	25.06.11
2	ISSUED FOR TENDER & PERMIT	BDM	BDM	25.04.07
1	ISSUED FOR COSTING	BDM	BDM	25.01.06
Issued		By	Appd.	YY.MM.DD
File Name:		Dwn.	Chkd.	Dsgn.
				YY.MM.DD




Client/Project
**SCARBOROUGH HEALTH NETWORK
GENERAL HOSPITAL
SATELLITE IMAGING RENOVATION**

3050 Lawrence Ave East, Scarborough, Ontario

Title
**EXISTING PARTIAL
BASEMENT FLOOR PLAN**

Project No. 140023034	Scale 1/4"=1'-0"	Revision
Drawing No.	Sheet	Revision


A404 of **0**



PARTIAL FLOOR PLAN LEGEND AND KEYNOTES:

PROPOSED AREA OF WORK

1 REMOVE AND RELOCATE EXISTING LOCKERS WITHIN HIGHLIGHTED AREA OF WORK FOR FACILITATED ACCESS. TEMPORARY LOCATION TO BE DETERMINED LATER BY SHN. EXISTING LOCKERS LAYOUT SHOWN ARE A GRAPHIC REPRESENTATION OF THE ASSUMED EXISTING CONDITIONS AND SHALL BE VERIFIED BY GC ON-SITE.



1	ISSUED FOR ADDENDUM 1	NA	BDM	25.05.02
Revision		By	Appd.	YY.MM.DD
3	ISSUED FOR CONSTRUCTION	BDM	BDM	25.06.11
2	ISSUED FOR TENDER & PERMIT	BDM	BDM	25.04.07
1	ISSUED FOR COSTING	BDM	BDM	25.01.06
Issued		By	Appd.	YY.MM.DD
File Name:		Dwn.	Chkd.	Dsgn.
				YY.MM.DD




Client/Project
**SCARBOROUGH HEALTH NETWORK
GENERAL HOSPITAL
SATELLITE IMAGING RENOVATION**

3050 Lawrence Ave East, Scarborough, Ontario

Title
**REFLECTED CEILING PLAN
DEMOLITION**

Project No. 140023034	Scale 1/4"=1'-0"
Drawing No.	Sheet
	Revision

A501 of **0**




REFLECTED CEILING PLAN GENERAL NOTES:

- EXISTING CEILING LAYOUTS AND MATERIALS SHOWN ARE A GRAPHIC REPRESENTATION OF THE ASSUMED EXISTING CONDITIONS. SITE VERIFY LAYOUTS, MATERIALS AND DEVICE QUANTITIES AND LOCATIONS.
- REPLACE TILES THAT ARE DAMAGED DURING THE COURSE OF THE WORK WITH NEW TILES TO MATCH EXISTING.

REFLECTED CEILING PLAN KEYNOTES:

- NOT USED
- NOT USED
- REMOVE GWB CEILING SYSTEM AND ASSOCIATED CEILING FIXTURES.
- REMOVE ACT CEILING SYSTEM AND ASSOCIATED CEILING FIXTURES.
- REMOVE GWB CEILING SYSTEM AND ASSOCIATED CEILING FIXTURES. GC TO INVESTIGATE THE EXISTING BULKHEAD TO IDENTIFY ANY CONCEALED UTILITIES/STRUCTURAL ELEMENTS PRIOR TO DEMOLITION.



1	ISSUED FOR ADDENDUM 1	NA	BDM	25.05.02
Revision		By	Appd.	YY.MM.DD
3	ISSUED FOR CONSTRUCTION	BDM	BDM	25.06.11
2	ISSUED FOR TENDER & PERMIT	BDM	BDM	25.04.07
1	ISSUED FOR COSTING	BDM	BDM	25.01.06
Issued		By	Appd.	YY.MM.DD
File Name:		Dwn.	Chkd.	Dsgn.
				YY.MM.DD




Client/Project
**SCARBOROUGH HEALTH NETWORK
GENERAL HOSPITAL
SATELLITE IMAGING RENOVATION**

3050 Lawrence Ave East, Scarborough, Ontario

Title
REFLECTED CEILING PLAN


Project No.	Scale
140023034	1/4"=1'-0"
Drawing No.	Sheet
A502	
Revision	



FLOOR PLAN KEYNOTES

- SIEMENS 3D CAMERA. PROVIDE UNISTRUT SUPPORT, PROVIDE CLEARANCE TO PATIENT LIFT SEE DETAIL 5/A902
- SIEMENS MONITOR SUPPORT. PROVIDE STEEL SUPPORT. SEE DETAIL 6/902
- REFER TO CARE STREAM DRAWINGS FOR ADDITIONAL INFORMATION
- REFER TO ARCHITECTURAL SPECIFICATIONS, SECTION 05 16 00 FOR DETAILS REGARDING THE STRUCTURAL CEILING GRID (UNISTRUT).

1.58mm (1/16\") THICK LEAD LINING TO A MINIMUM OF 2.13m A.F.F.



1	ISSUED FOR ADDENDUM 1	NA	BDM	25.05.02
Revision		By	Appd.	YY.MM.DD
3	ISSUED FOR CONSTRUCTION	BDM	BDM	25.06.11
2	ISSUED FOR TENDER & PERMIT	BDM	BDM	25.04.07
1	ISSUED FOR COSTING	BDM	BDM	25.01.06
Issued		By	Appd.	YY.MM.DD
File Name:		Dwn.	Chkd.	Dsgn.
				YY.MM.DD



SCARBOROUGH HEALTH NETWORK
GENERAL HOSPITAL
SATELLITE IMAGING RENOVATION

3050 Lawrence Ave East, Scarborough, Ontario

PATRIAL BASEMENT
REFLECTED CEILING PLAN

Project No.	Scale
140023034	1/4"=1'-0"
Drawing No.	Sheet
A503	Revision

REFLECTED CEILING PLAN GENERAL NOTES:

- EXISTING CEILING LAYOUTS AND MATERIALS SHOWN ARE A GRAPHIC REPRESENTATION OF THE ASSUMED EXISTING CONDITIONS. SITE VERIFY LAYOUTS, MATERIALS AND DEVICE QUANTITIES AND LOCATIONS.
- REPLACE TILES THAT ARE DAMAGED DURING THE COURSE OF THE WORK WITH NEW TILES TO MATCH EXISTING.

REFLECTED CEILING PLAN KEYNOTES:

- REMOVE ACT CEILING TILES AND ASSOCIATED CEILING FIXTURES AS REQUIRED TO ACCOMMODATE DEMOLISHING EXISTING MECHANICAL SYSTEMS AND ADDING NEW STRUCTURAL AND MECHANICAL INSTALLATIONS. PLACE BACK ALL ACT CEILING TILES AND ASSOCIATED CEILING FIXTURES. REFER TO MECHANICAL AND STRUCTURAL DOCUMENTS FOR FULL EXTENT OF WORK.
- CUT BACK A PORTION OF GWB CEILING AS REQUIRED TO ACCOMMODATE DEMOLISHING EXISTING MECHANICAL SYSTEMS AND ADDING NEW STRUCTURAL AND MECHANICAL INSTALLATIONS. REMOVE AND REINSTALL ASSOCIATED CEILING FIXTURES. PATCH, REPAIR AND PAINT GWB CEILING TO MATCH THE EXISTING CEILING. REFER TO MECHANICAL AND STRUCTURAL DOCUMENTS FOR FULL EXTENT OF WORK.

\\s0224-prfs01\shared_projects\140023034\4_working_files\04_architecture\01_cad\01_labels\GEN- Ground Floor Plate_2025-02-19.dwg
2025/06/06 10:30 AM By: Meisler, Brian

DOOR/ SCREEN NUMBER	FRAME TYPE	MATL. COLOUR	FINISH COLOUR	PROFILE	DETAIL	GLASS	DOOR SIZE	TYPE	MATL. COLOUR	FINISH COLOUR	GLASS	GRILLE U/C	FIRE RATING	REMARKS
G4502	F1	HM	PT	P1	DT1	-	3'-6" & 1'-8" x 7'-0" x 1 3/4"	A, A	WD	PLAM	-	-	-	HO
G4503	F1	HM	PT	P5	DT2	-	3'-2" x 7'-0" x 1 3/4"	A	WD	PLAM	-	-	-	DOUBLE ACTING DOOR
G4504	F1	HM	PT	P1	DT1	TEMP/GL	3'-6" & 2'-0" x 7'-0" x 1 3/4"	B	WD	PLAM	TEMP/GL	-	NON-RATED	DIM1=5'-6" CARD READER, MAGNETIC HOLD OPEN
G4505	F1	HM	PT	P1	DT1	-	3'-2" x 7'-0" x 1 3/4"	A	WD	PLAM	-	-	-	CARD READER
G4506A	F1	HM	PT	P1	DT1	-	3'-6" x 7'-0" x 1 3/4"	A	WD	PLAM	-	-	-	CARD READER
G4507	F1	HM	PT	P1	DT1	-	3'-2" x 7'-0" x 1 3/4"	A	WD	PLAM	-	-	-	CARD READER
G4507A	F1	HM	PT	P1	DT4	-	3'-2" x 7'-0" x 1 3/4"	E	WD	PLAM	LEAD	-	-	HD FRAME LEAD LINED, WINDOW BLIND
G4507B	F2	HM	PT	P1	DT5	LEAD	-	-	-	-	-	-	-	DIM1=7'-2". DIMX=3'-0". DIMY=4'-0" WINDOW BLIND
G4508	F1	HM	PT	P1	DT4	-	4'-0" & 2'-0" x 7'-0" x 1 3/4"	A, A	WD	PLAM	-	-	-	LEAD LINED HO X-RAY IN USE SIGN
G4509	F3	ALUM	-	-	DT7	-	15'-4"	C,C	ALUM	-	TEMP/GL	-	-	DOOR WIDTH DENOTES UNIT PACKAGE WIDTH. PRIVACY FILM
G4511	F1	HM	PT	P1	DT4	-	3'-6" & 1'-6" x 7'-0" x 1 3/4"	A, A	WD	PLAM	-	-	-	HD FRAME, HO LEAD LINED X-RAY IN USE SIGN
G4512	F1	HM	PT	P1	DT1	-	3'-2" x 7'-0" x 1 3/4"	A	WD	PLAM	-	-	-	CARD READER HD FRAME
G4512A	F2	HM	PT	P2	DT5	LEAD	-	-	-	-	-	-	-	DIM1=5'-1". DIMX=3'-0". DIMY=4'-0"
G4512B	F2	HM	PT	P2	DT5	LEAD	-	-	-	-	-	-	-	DIM1=2'-8". DIMX=3'-0". DIMY=4'-0"
G4512C	F2	HM	PT	P2	DT5	LEAD	-	-	-	-	-	-	-	DIM1=5'-1". DIMX=3'-0". DIMY=4'-0"
G4512D	F2	HM	PT	P2	DT5	LEAD	-	-	-	-	-	-	-	DIM1=2'-8". DIMX=3'-0". DIMY=4'-0"
G4513	F1	HM	PT	P1	DT4	-	3'-6" & 1'-6" x 7'-0" x 1 3/4"	A, A	WD	PLAM	-	-	-	HD FRAME, HO LEAD LINED X-RAY IN USE SIGN
G4516	F1	HM	PT	P1	DT2	-	3'-2" x 7'-0" x 1 3/4"	A	WD	PLAM	-	-	-	STAFF WR - CARD READER
G4518	F1	HM	PT	P5	DT2	-	3'-2" x 7'-0" x 1 3/4"	A	WD	PLAM	-	-	-	ADOIP, DOUBLE ACTING DOOR


ABBREVIATIONS:

HM HOLLOW METAL
WD SOLID CORE WOOD DOOR
ALUM ALUMINUM
PT PAINT
GWB GYPSUM BOARD
PLAM PLASTIC LAMINATE
TEMP TEMPERED GLASS
FRG FIRE RATED GLAZING
GL# GLAZING TYPE. REFER TO SPECIFICATIONS
DPP DOOR FRAME PROTECTION
DP DOOR PROTECTION
ADO AUTOMATIC DOOR OPERATOR
MHO MAGNETIC HOLD OPEN DEVICE
HO HOLD OPEN
CR CARD READER
KPD KEY PAD
ES ELECTRIC STRIKE
ML MAG LOCK
FL FIRELITE
NRFS NON-RATED FIRE SEPARATION


DOOR SCHEDULE GENERAL NOTES

- DOOR FRAME SIZES ARE FRAME REBATE SIZES.
- FILL FRAME JAMBS SOLID WITH MORTAR WHERE THEY OCCUR IN POURED CONCRETE OR MASONRY WALLS, EXCEPT AT THERMALLY BROKEN FRAMES WHERE THEY ARE TO BE FILLED SOLID WITH INSULATION.
- FIRE RATINGS NOTED IN THE DOOR AND SCREEN SCHEDULE INCLUDES DOORS, FRAMES, SCREENS, GLAZED LIGHTS AND HARDWARE. CONFIRM MAXIMUM GLASS SIZE PERMITTED FOR RATINGS INDICATED PER OBC.
- SUB-CAULK ALL DOOR THRESHOLDS.
- ALL EXTERIOR DOORS TO HAVE THRESHOLDS AND THERMALLY BROKEN FRAMES.
- ALL DOORS, FRAMES AND SCREENS SCHEDULED TO RECEIVE HARDWARE MUST BE FABRICATED, REINFORCED AND PREDRILLED TO SUITE HARDWARE.
- COORDINATE WITH DOOR AND SCREEN SCHEDULE FOR DETAILS OF LABELLED DOORS, FRAMES AND SCREENS.
- PROVIDE ADDITIONAL STEEL FRAMING AND SWAY BRACING AT O/H GRILLES, SLIDING DOORS AND SCREENS TO STABILIZE DOOR AND TRACK ASSEMBLY.
- REFER TO MECHANICAL DOCUMENTS AND COORDINATE DOOR UNDERCUTS:
-25mm IN NONRATED DOORS
-19mm IN HOLLOW METAL DOORS
-10mm IN RATED WOOD DOORS.
- DOORS, FRAMES AND SCREENS MUST BE FABRICATED, REINFORCED AND PREDRILLED FOR THE INSTALLATION OF SECURITY DEVICES.
- CONTRACTOR IS RESPONSIBLE TO SITE MEASURE AND VERIFY DOOR OPENING SIZES PRIOR TO ANY FABRICATION.
- SOUND ATTENUATE DOORS AND FRAMES INTO NOISY ROOMS FOR SOUND AND VIBRATION. THIS INCLUDES A THRESHOLD COMPLETE WITH NEOPRENE SOUND SEAL AND RUBBER DOOR SWEEP (HARDWARE ALLOWANCE). DOORS TO HAVE A TEMPERATURE RATE OF RISE DOOR RATING OF 250.
- REFER TO SECTION 09900 OF THE SPECIFICATIONS FOR HOLLOW METAL AND WOOD DOOR FINISHES.
- EXISTING STRUCTURAL STEEL OVERHEAD. SITE VERIFY HEIGHT AVAILABLE FOR DOOR AND FRAME.
- NOT USED
- SEE DOOR SCHEDULE AND FLOOR PLANS FOR ADDITIONAL GLASS TYPES
- ALL LEAD LINING TO BE 3/8" THICK MINIMUM OR EQUIVALENT FOR GLASS.


5 DOOR SCHEDULE
A801




4 FRAME TYPE
A801 SCALE: 1/4"=1'-0"



3 DOOR TYPE
A801 SCALE: 1/4"=1'-0"



2 FRAME PROFILES
A801 SCALE: NTS



1 DETAILS
A801 SCALE: 1/4"=1'-0"


Copyright Reserved

The Contractor shall verify and be responsible for all dimensions. DO NOT scale the drawing - any errors or omissions shall be reported to Stantec without delay. The Copyrights to all designs and drawings are the property of Stantec. Reproduction or use for any purpose other than that authorized by Stantec is forbidden.

Consultants

Keyplan

North Arrow



1	ISSUED FOR ADDENDUM 1	NA	BDM	25.05.02
Revision		By	Appd.	YY.MM.DD
3	ISSUED FOR CONSTRUCTION	BDM	BDM	25.06.11
2	ISSUED FOR TENDER & PERMIT	BDM	BDM	25.04.07
1	ISSUED FOR COSTING	BDM	BDM	25.01.06
Issued		By	Appd.	YY.MM.DD
File Name:				
	Dwn.	Chkd.	Dsgn.	YY.MM.DD

Permit-Seal



Client/Project

SCARBOROUGH HEALTH NETWORK
GENERAL HOSPITAL
SATELLITE IMAGING RENOVATION

3050 Lawrence Ave East, Scarborough, Ontario

Title

DOOR SCHEDULE

Project No.
140023034

Scale

Drawing No.

Sheet


Revision

A801

of

0

\\s0224-prfs01\shared_projects\140023034\working_files\04_architecture\01_con\01_sheets\GEN- Ground Floor Plate_2025-02-19.dwg
2025/06/06 10:21 AM By: Moeller, Brian



4
A802 PHASING DRAWING
SCALE: 1 1/2"=1'-0"

ROOM NUMBER	ROOM NAME	FLOOR	BASE	WALL1	NORTH	WALL2	EAST	WALL3	SOUTH	WALL4	WEST	CEILING		REMARKS
		MATL.	MATL.	FINISH	COLOUR	FINISH	COLOUR	FINISH	COLOUR	FINISH	COLOUR	MATL.	FINISH	
G4-18	EXISTING CORRIDOR	EXST	EXIST	PT		-		PT		-		EXIST	-	PAINT FULL EXTENT OF CORRIDOR
G4-19	EXISTING CORRIDOR	EXST	EXIST/RSF	-		-		-		PT		EXIST	-	
G6-17	EXISTING CORRIDOR	RSF	RSF	PT		PT		PT		PT		ACT	-	
G4501	ALCOVE	RSF	RSF	WP		WP		WP		WP		ACT	-	
G4502	ULTRASOUND	RSF	RSF	PT		PT		PT		PT		ACT	-	
G4503	WR	RSF	RSF	PT		PT		PT		PT		GWB	PT	
G4504	STRETCHER	RSF	RSF	PT		PT		PT		PT		ACT	-	
G4505	TEAM ROOM	RSF	RSF	PT		PT		PT		PT		ACT	-	
G4506	STRETCHER HOLDING	RSF	RSF	PT		PT		PT		PT		ACT	-	
G4507	CONTROL	RSF	RSF	PT		PT		PT		PT		ACT	-	
G4508	CT	RSF	RSF	PT		PT		PT		PT		ACT	-	
G4509	CT EQUIPMENT	RSF	RSF	PT		PT		PT		PT		ACT	-	
G4510	LINEN ALCOVE	RSF	RSF	PT		PT		PT		PT		ACT	-	
G4511	X-RAY	RSF	RSF	PT		PT		PT		PT		ACT	-	
G4512	CONTROL	RSF	RSF	PT		PT		PT		PT		ACT	-	
G4513	X-RAY	RSF	RSF	PT		PT		PT		PT		ACT	-	
G4517	WAITING AREA	RSF	RSF	PT		PT		PT		PT		ACT	-	
G4518	WR	RSF	RSF	PT		PT		PT		PT		GWB	PT	

3
A802 ROOM FINISH SCHEDULE
NTS

PHASING DRAWING GENERAL NOTES AND KEYNOTES

- CONSTRUCTION HOARDING IS SUBJECT TO CHANGE BASED ON COORDINATION WITH SHN IPAC TEAM AND INCORPORATION OF THEIR REQUIREMENTS.
- THE DOWNTIME BETWEEN THE TURNOVER OF PHASE 1 AND THE COMMENCING OF PHASE 2 IS A WEEK.


1 A MINIMUM OF 4' CLEARANCE NEEDS TO BE MAINTAINED FOR THE DURATION OF CONSTRUCTION.

ROOM FINISH SCHEDULE GENERAL NOTES


- SCHEDULES TO BE READ IN CONJUNCTION WITH ALL DRAWINGS AND SPECIFICATIONS.
- PROVIDE GYPSUM BOARD BULKHEADS ON METAL FURRING WHERE SHOWN ON DRAWINGS AND AT ALL CHANGES IN CEILING HEIGHT.
- ALL BASES IN CABINET WORK TO BE FINISHED IN BASE MATERIAL USED FOR SURROUNDING FLOOR.
- FREE-STANDING COLUMNS FINISHED SAME AS REMAINDER OF ROOM.
- PAINT ALL EXPOSED MISCELLANEOUS METALS AND SERVICES (E.G. DUCTS, CONDUITS, PIPING ETC.) WHERE CEILINGS AND WALLS ARE SCHEDULED TO BE PAINTED.
- GYPSUM BOARD APPLIED TO CLAY TILE OR CONCRETE MASONRY UNITS SHALL BE INSTALLED ON METAL FURRING.
- EXISTING WALLS SHALL BE CHASED AND OPENINGS CREATED AS REQUIRED TO EXECUTE THE WORK.
- MAKE GOOD ALL MATERIALS AND FINISHES WHERE DISTURBED AND WHERE ALTERATIONS OCCUR. REFER TO MECHANICAL AND ELECTRICAL DRAWINGS FOR FULL EXTENT OF WORK REQUIRED. NOTE THAT MAKING GOOD INCLUDES WORK ASSOCIATED WITH THE INSTALLATION OF SERVICES SHOWN ON DRAWINGS.
- REFER TO SECTION 09 65 00 RESILIENT FLOORING. PREPARE SMOOTH SURFACE VOID OF ANY IRREGULARITIES PRIOR TO THE INSTALLATION OF RESILIENT FLOORING.
- WHERE GWB WALLS RECEIVE EPT FINISH, PROVIDE ABUSE RESISTANT GWB (IN LIEU OF REGULAR GWB)
- ALL BASES TO BE 150mm HIGH.
- HYGENIC WALL PANEL SYSTEM (HWPS) - SEE ROOM ELEVATIONS AND PLANS FOR LOCATIONS
- WHERE FLOORING AND BASE SHOW THE SAME MATERIAL PROVIDE AN 150mm INTEGRAL COVERED BASE.

ABBREVIATIONS:

RUB	RUBBER BASE
RSF	RESILIENT SHEET FLOORING
FAF	FLUID APPLIED FLOORING
GWB	GYPSUM WALL BOARD
HWPS	HYGENIC WALL PANEL SYSTEM
PT	PAINT
EPT	EPOXY PAINT
ACT	ACOUSTIC TILE CEILING
BRK	BRICK



1
A802 TYPICAL BASE DETAIL
SCALE: 3"=1'-0"



2
A802 WALL PROTECTION SYSTEMS
SCALE: 1 1/2"=1'-0"



Stantec Architecture Ltd.
200 - 835 Paramount Drive
Stoney Creek, ON, L8J 0B4
Tel. 905-385-3234
www.stantec.com


Copyright Reserved

The Contractor shall verify and be responsible for all dimensions. DO NOT scale the drawing - any errors or omissions shall be reported to Stantec without delay.
The Copyrights to all designs and drawings are the property of Stantec. Reproduction or use for any purpose other than that authorized by Stantec is forbidden.

Consultants

Keyplan

North Arrow



2	ISSUED FOR ADDENDUM 2	NA	BDM	25.05.09
1	ISSUED FOR ADDENDUM 1	NA	BDM	25.05.02
Revision		By	Appd.	YY.MM.DD
3	ISSUED FOR CONSTRUCTION	BDM	BDM	25.06.11
2	ISSUED FOR TENDER & PERMIT	BDM	BDM	25.04.07
1	ISSUED FOR COSTING	BDM	BDM	25.01.06
Issued		By	Appd.	YY.MM.DD
File Name:		Dwn.	Chkd.	Dsgn.
Permit-Seal				YY.MM.DD



Client/Project


SCARBOROUGH HEALTH NETWORK
GENERAL HOSPITAL
SATELLITE IMAGING RENOVATION

3050 Lawrence Ave East, Scarborough, Ontario

Title

FINISH SCHEDULE
WALL PROTECTION
PHASING

Project No.	Scale
140023034	
Drawing No.	Sheet
A802	of
	Revision
	9



1	ISSUED FOR ADDENDUM 1	NA	BDM	25.05.02
Revision		By	Appd.	YY.MM.DD
3	ISSUED FOR CONSTRUCTION	BDM	BDM	25.06.11
2	ISSUED FOR TENDER & PERMIT	BDM	BDM	25.04.07
1	ISSUED FOR COSTING	BDM	BDM	25.01.06
Issued		By	Appd.	YY.MM.DD
File Name:				
		Dwn.	Chkd.	Dsgn.
				YY.MM.DD




SCARBOROUGH HEALTH NETWORK
GENERAL HOSPITAL
SATELLITE IMAGING RENOVATION


3050 Lawrence Ave East, Scarborough, Ontario

CASEWORK / MILLWORK SECTIONS,
ELEVATIONS, HHS AND WASHROOM
ELEVATIONS


Project No.	Scale	
140023034		
<hr/>		
Drawing No.	Sheet	Revision




12 GOWN STORAGE
A901 SCALE: 1/2"=1'-0"




11 SERVICE STRIP MODULES
A901 SCALE: NTS




10 TYPICAL HAND HYGENE STATION (HHS) AND SPLASH GUARD
A901 SCALE: 1/2"=1'-0"




9 BARRIER FREE WASHROOM
A901 SCALE: 1/2"=1'-0"




8 TYPICAL ACCESSORY MOUNTING HEIGHTS
A901 SCALE: 1/4"=1'-0"





7 G4502 - ULTRASOUND
A901 SCALE: 1/4"=1'-0"




6 G4507 - CONTROL
A901 SCALE: 1/4"=1'-0"




5 G4508 - CT
A901 SCALE: 1/4"=1'-0"




4 G4505 - TEAM ROOM
A901 SCALE: 1/4"=1'-0"





3 G4512 - CONTROL
A901 SCALE: 1/4"=1'-0"




2 G4513 - X-RAY
A901 SCALE: 1/4"=1'-0"




1 CASEWORK/MILLWORK SECTIONS
A901 SCALE: 1/2"=1'-0"




4 WALL SECTION - WINDOW INFILL
A902 SCALE: 1 1/2"=1'-0"



3 PLAN DETAIL - WINDOW INFILL
A902 SCALE: 1"=1'-0"




2 WALL SECTION - WINDOW REPLACEMENT
A902 SCALE: 1 1/2"=1'-0"



1 PLAN DETAIL - WINDOW REPLACEMENT
A902 SCALE: 1"=1'-0"

COOLING SYSTEM INDOOR UNIT CABINET (water/air-split)




NOTE: No service space required on sides of cabinet

NOTE: Base frame cut-outs for when cables are routed on the floor into the cabinet (all four sides possible).

Siemens recommends the optional base frame for raising the equipment cabinet (as shown in detail above). See **BASE FRAME (INDOOR UNIT)** detail.

BASE FRAME (INDOOR UNIT) PROPOSAL ONLY - OPTIONAL



Fastening points under SIEMENS equipment cabinet (4 x 15mm Ø).


Cable opening under SIEMENS cabinet (dashed line as shown).

Opening complete with cover and screws (all 4 sides of base).

SECTION A-A (NTS)

- Frame to be designed by Structural Engineer in order to be a solid and vibration-free mounting for Siemens equipment Cabinet.
- Mounting Frame and Floor Fasteners to be supplied by others/customer.


COOLING SYSTEM FLOW HEATER CABINET (water/air-split)



NOTE: Base frame cut-outs for when cables are routed on the floor into the cabinet (only front side possible).

Siemens recommends the optional base frame for raising the equipment cabinet (as shown in detail above). See **BASE FRAME (FLOW HEATER)** detail.

COOLING SYSTEM FLOW HEATER BASE FRAME



Fastening points under SIEMENS equipment cabinet (2 x 10mm Ø).


Cable opening under SIEMENS cabinet (dashed line as shown).

Frame to be bolted to floor, by others.

SECTION A-A (NTS)

- Frame to be designed by Structural Engineer in order to be a solid and vibration-free mounting for Siemens equipment Cabinet.
- Mounting Frame and Floor Fasteners to be supplied by others/customer.

CAREVISION CT CEILING SUPPORT




NOTE: Bolt pattern to be confirmed by Siemens

A) Four Ø 16 holes in steel plate (HASEKE).

B) Three Ø 18 holes in steel plate (ONDAL).

C) Three M16 holes in steel plate (ONDAL).

3D CAMERA CEILING SUPPORT



NOTE: Total weight of the 3D camera system = 14 kg (mounting plate, flange with flange pipe, canopy, and the 3D camera).

8 INDOOR COOLING SYSTEM SUPPORT
A902 SCALE: NTS

7 COOLING SYSTEM FLOW HEATER CABINET SUPPORT
A902 SCALE: NTS

6 CEILING MOUNTED MONITOR SUPPORT
A902 SCALE: NTS

5 3D CAMERA MOUNT - CT
A902 SCALE: NTS

1	ISSUED FOR ADDENDUM 1	NA	BDM	25.05.02
Revision		By	Appd.	YY.MM.DD
3	ISSUED FOR CONSTRUCTION	BDM	BDM	25.06.11
2	ISSUED FOR TENDER & PERMIT	BDM	BDM	25.04.07
1	ISSUED FOR COSTING	BDM	BDM	25.01.06
Issued		By	Appd.	YY.MM.DD
File Name:		Dwn.	Chkd.	Dsgn.
Permit-Seal				



Client/Project
**SCARBOROUGH HEALTH NETWORK
GENERAL HOSPITAL
SATELLITE IMAGING RENOVATION**

3050 Lawrence Ave East, Scarborough, Ontario

Title
**WINDOW INFILL/REPLACMENT
DETAILS**

Project No.	Scale
140023034	
Drawing No.	Sheet
A902	of
Revision	0