

- GENERAL NOTE

  - RESEAL AND RE-INSULATE ALL DUCTWORK ON FLOOR TO REMAIN
  - GRILLES, DIFFUSERS AND RADIANT CEILING PANELS TO HAVE SECURE TYPE INSTALLATION WITH TAMPER PROOF FASTENERS.
  - FIRE DAMPER TO BE PROVIDED FOR EVERY DUCT CROSSING A FIRE RATED WALL.
- DRAWING NOTES

  - EXISTING TERMINAL BOX. VERIFY OPERATION AND REBALANCE AS INDICATED
  - LAUNDRY DRYER EXHAUST DUCT TO BE C/W EXTERNAL SECONDARY UNIT TRAP IN AN ACCESSIBLE LOCATION FOR FREQUENT CLEANING. PROVIDE LOUVER FOR LAUNDRY DRYER EXHAUST.
  - CONDENSATE FROM FAN COIL UNITS TO BE ROUTED TO THE NEAREST AVAILABLE FLOOR DRAIN OR W/P SINK. AVAILABLE W/P SINK IN HOUSEKEEPING ROOM 3011. INDIRECT CONNECTION. REFER TO DETAIL 12 ON DRAWING M2
  - PROVIDE FANS AS SHOWN WITH FLEXIBLE CONNECTIONS AND VIBRATION ISOLATION. REFER TO DETAIL 5 ON DRAWING M2.

1 LEVEL 03 FLOOR PLAN HVAC DUCTWORK NEW WORK  
M9 1:96

TOANCHE  
LEVEL 03  
RENOVATIONS -  
STAGE 4

CANNONDESIGN  
50 Fountain Plaza Suite 200  
Buffalo, NY 14202  
P: 716.773.6900  
F: 716.773.6900  
www.cannondesign.com

MULVEY & BANANI  
90 Sheppard Avenue East, Suite 500, Toronto, ON M2N 3A1  
416.751.2525

MULVEY & BANANI  
Electrical Engineer  
90 Sheppard Ave. E. Suite 500  
North York, ON M2N 3A1, Canada  
416.751.2520


HHAngus  
HH Angus & Associates Ltd  
Mechanical Engineer  
1127 Leslie St.  
North York, ON M5C 2J6, Canada  
416.443.8200

stephenson  
ASALASOBRIEN COMPANY  
Stephenson Engineering Ltd  
Structural Engineer  
2550 Victoria Park Ave. #602  
North York, ON M2J 5A9, Canada  
416.635.9970

ISSUED FOR TENDER  
18 DEC 2023  
Ministry of Health Project Number# 205004



04	Issued for Tender	2023-12-18
03	Issued for Construction	2023-11-17
02	Issued for Stage 4 Submission	2023-11-23
01	Issued for 95% CD-QA/QC	2022-11-01
Rev.	Description	Date



LEVEL 03 FLOOR PLAN  
HVAC DUCTWORK NEW  
WORK

Project No.: 020708.50 Checked by: ES

M9