


Rev.	Description	Date
4	STAGE 4 SUBMISSION	11/23/2022
3	QA/QC 95% CDs	11/01/2022
2	LEVEL 03 RENOVATIONS - STAGE 3 SUBMISSION	06/30/2021
1	ISSUED FOR REVIEW	06/15/2021




Drawing Title:

LEVEL 03 FLOOR PLAN
LIGHTING

Project No.: 210029 Checked by: JM

E02



LEVEL 03 PLAN
SCALE: 1:100

- NOTES:
- ALL WALL SCONCES TYPE LT-04A LOCATED IN THE CORRIDOR TO BE CONTROLLED BY ONE CENTRAL SWITCH LOCATED AT THE CARE DESK 3013 (TYPICAL FOR ALL).
 - FIXTURES TYPE LT-02 LOCATED IN THE CORE TO BE CONTROLLED BY ONE CENTRAL SWITCH LOCATED AT THE CARE DESK 3013 (TYPICAL).
 - FIXTURES TYPE LT-01D LOCATED IN THE CORRIDOR TO BE CONTROLLED BY ONE CENTRAL SWITCH LOCATED AT THE CARE DESK 3013 (TYPICAL FOR ALL).
 - RE-CIRCUIT EXISTING LIGHT FIXTURES AS SHOWN (TYPICAL FOR ALL).
 - RE-CIRCUIT EXISTING EXIT SIGNS AS SHOWN (TYPICAL FOR ALL).
 - ALL CIRCUIT NUMBERS INDICATED IN THIS DEMARCATION SHALL BE PREFIX WITH "LP-" UNLESS OTHERWISE NOTED. CIRCUITS INDICATED IS FOR GROUPING PURPOSES ONLY. EXACT CIRCUIT NUMBER TO BE CONFIRMED ON SITE AFTER DEMOLITION.
 - REFER TO ARCHITECTURAL DOCUMENTS FOR CONSTRUCTION PHASING REQUIREMENTS.