



**Addendum #7**

**Bid Opportunity: CPS-RFT-25-03 - North Paris Fire Station**  
**Closing Date: Thursday, August 28, 2025 2:00 PM**

---

**CLARIFICATION: NO FURTHER ADDENDA WILL BE ISSUED. PLEASE BID AS PER THE APECS, DRAWINGS AND ADDENDA ISSUED TO DATE.**

**Question 1:** I have been in communication with Vic West regarding the proposed wall construction for W-EX1, W-EX2 and W-P2a as well as the roof assembly for the North Paris New Fire Station. I have been informed that the proposed assemblies are not recommended uses of the L-800R liner and System 2000. Below is the correspondence with Vic West for more information, please advise how we should proceed with pricing. Also be advised I am waiting for a reply from Agway regarding a similar issue of their AL-315 panel.

**Answer: See sections:**

**07 46 19 PREFORMED METAL CLADDING**

**07 61 13 STANDING SEAM SHEET METAL ROOFING**

**13 34 19 PRE-ENGINEERED METAL BUILDING RFQ**

**VicWest products are not specified as products to be incorporated into the work for this project.**

**VicWest cladding products are included under the products as the *basis-of-design* for profile and gauge.**

**The cladding, roofing, and liner, is to be provided by the pre-eng. supplier,(per 13 34 19), to the specs listed under those respective sections.**

**See Section 13 34 19, which outlines the scope of work for the pre-engineered supplier.**