

October 3, 2025

Posted via Ariba  
(2 Pages + Attachment)

**ADDENDUM No. 11**  
**REQUEST FOR TENDER No. Doc5314342288**

**SUBMISSION DEADLINE: 12:00 NOON (LOCAL TIME), October 7, 2025**

**FOR: Accessibility Upgrades Located at 50 Richmond St., Toronto**

Please refer to the above Request for Tender document in your possession and be advised of the following:

**I. CLARIFICATIONS**

C1 – Please see below changes as per the attachment to this addendum.

E0001 – Updated symbol for exit sign

E1100 – Clarified demolition scope for existing service entrance disconnect

E2000 – Updated single line to clarify elevator feed and new service entrance disconnect

E2704 – Added panel schedule for XRP-5

C2 – Specification section 26 32 16

Line 2.2.2.5 – Where the generator mentions Kohler as the manufacturer. The following other manufacturers shall be added:

Generac

Cummins

**II. QUESTIONS**

Q1 – Where can I find Exits signs, Lighting control specs? Refer to Clarification C1.

A1 – The exit signs are shown in the lighting plans, the symbol is the circle with an x through it and typically have arrows for the direction of the exit as well.

Q2 – Disconnect for the Elevator Power says fed from Basement Distribution Panel PPA, which is not existing. Assuming it is referring from DP1, this feeder is not shown in the single line diagram. Please clarify from which Panel we are feeding the elevator Disconnect

A2 – It is meant to be fed from panel DP1. See riser drawing feeder for intent.

Q3 – Panel Schedule for 'XRP-5' is missing, please provide.

A3 – Provided as part of addendum. See attachment.

Q4 – Drawing E2100 (Basement Power) says to replace existing 800A Service Entrance Disconnect Switch, however the SLD shows it as existing (not to replace) and by Toronto Hydro, please advise.

A4 – Disconnect is intended to be replaced.

Should you have any questions regarding this addendum send via the event message board or contact Max Parker by email at [Max.Parker@toronto.ca](mailto:Max.Parker@toronto.ca).

Suppliers must acknowledge receipt of all addenda in the space provided on Part 4 – Submission Form as per Part 1 Tender Process, Section 1 RFT Specific Process and Submission Instructions, Item 1.7 – Addenda, of the Tender document. All other aspects of the Tender remain the same.

Yours truly,

Theodoros Maicantis, Supervisor  
Purchasing & Materials Management Division