

November 27, 2025

Client: G.M. Diemert Architect Inc.
957 4th Ave. E.,
Owen Sound, ON N4K 2N9

RE: Town of South Bruce Peninsula Town Hall
Wiarton, ON

Job #: 24099

Attn: Grant Diemert, OAA/Bryce Jaekel

ADDENDUM 05

MECHANICAL

Item 1

1.0 Bidder Questions

.1 Question:

Drawing M401 – Water Room Entrance Detail – Please clarify the pipe sizing in this detail. The water enters at 50mm and the increases to 80mm at the double check backflow preventor and the reduces to 50mm again. There is also an 80mm hose connection and vacuum breaker shown, what is this for? There is also a RP backflow assembly shown next to a vacuum breaker and drain. What is it for?

Answer:

Water entrance detail has been updated. Please reference attached reissued drawing M401.

.2 Question:

Drawing M401 - Please confirm the cold water sizing shown on Washroom 15a/b Part plan. The washrooms have a 20mm feed but the drop and header in the washroom is 25mm.

Answer:

Please reference attached reissued drawing M401 for water sizing.

.3 Question:

HVAC Controls, please clarify if Carrier controls is an acceptable?

Answer:

Carrier is an acceptable controls alternative. To be submitted as separate number under the control cash allowance. Submission to conform to the controls specification sections.

ELECTRICAL

Item 1

1.0 No electrical content.



Hamza Bagui, M.Eng.
Mechanical Designer

24099 Addendum 05 (M-Bidder Questions)(reissued dwg M401) Nov 27 25
hb/sad



