

December 03, 2025

Tender Period Addendum 06

Town of South Bruce Peninsula – New Town Hall Offices

370 William Street, Wiarton, Ontario, N0H 2T0

Issued To: All Bidders

Re: Architectural Revisions

Part 1 ATTACHMENTS:

1.1 G.M. DIEMERT ARCHITECT INC. DRAWINGS:

- .1 Electronic Document Identification: PDF file attached “20251203gmda-ARCH-TSBP-Add06-DWG”, 3 pages ARCH “E” size (121.92 cm x 91.4 cm), issued; “06, Add-06, ADDENDUM 06, 2025.12.03”, identified as follows:
 - .1 A-110, titled “Ground Floor Plan”,
 - .2 A-111, titled “Ground Floor Enlarged Plan”,
 - .3 A-112, titled “Ground Floor Enlarged Plan”.

Part 2 Summary of Amendments to Bid Documents:

2.1 CLARIFICATION:

- .1 Concrete curbs and curb-faced walks are to be cast-in-place concrete as specified and indicated on Architectural Drawing A-002 “Site Plan, OBC Matrices & Details” within Details 15 and 22. Permacon precast concrete curbs specified within Specifications section 32 14 13 – Pre-Cast Concrete Unit Paving are not required for this Project.

2.2 ARCHITECTURAL DRAWINGS ARE REVISED:

- .1 Wall types W1A and W1B within Wall Type Legend on Drawings A-110, A-111 and A-112 are revised as follows:
 - .1 **DELETE** 38x140mm SPF No. 1 / 2 wood studs.
 - .2 **ADD** 38x184mm SPF No. 1 / 2 wood studs as indicated in structural addendum 01. This change is also identified in wall sections on drawings A-310 and A-311 issued in Addendum 04.

End of Tender Addendum.