



NOTES:

- OVERALL INTENT OF THIS DRAWING IS TO INDICATE ELECTRICAL SCOPE FOR THE STAGE OF WORK NEEDING TO BE DONE PRIOR TO THE FIFA WORLD CUP.
- ALL PROPOSED NEW ELECTRICAL EQUIPMENT IS TO BE FED FROM EXISTING PANEL LP-1. PANEL LP-1 IS AT MAXIMUM BREAKER CAPACITY. SELECTIVE DEMOLITION IS TO BE DONE FROM NON CRITICAL LOADS TO FREE UP BREAKER SPACE TO ACCOMMODATE NEW LOADS INDICATED.
- EXISTING LIGHTING, EMERGENCY LIGHTING, EXIT SIGNAGE, HVAC LOADS ARE TO REMAIN OPERATIONAL FOR THIS PHASE OF CONSTRUCTION. ALL EXISTING POWER DISTRIBUTION IS TO REMAIN FOR THIS PHASE.
- PROVIDE CONNECTION FOR NEW COMPRESSOR FROM EXISTING PANEL DP-2 EXISTING COMPRESSOR BREAKER. PROVIDE NEW BREAKER IN EXISTING PANEL TO SUIT NEW COMPRESSOR PER SINGLE LINE DIAGRAM.
- AFTER POST FIFA MOBILIZATION, CONTRACTOR IS TO RE-CIRCUIT LOADS FED TO LP-1 TO NEW PANEL INDICATED ON PROPOSED PLAN.
- CIRCUITS SHOWN ARE FOR GROUPING PURPOSES ONLY TO MATCH THE FINAL STATE CIRCUIT GROUPINGS.
- PROVIDE POWER CONNECTIONS FOR THE NEW TAILPIPE EXHAUST SYSTEM EXHAUST FANS EF10, EF11 ON ROOF AS PART OF PRE-FIFA SCOPE. REFER TO PROPOSED 2ND FLOOR PLAN E202 FOR SIZING, LOCATION AND CIRCUIT GROUPING.

CLIENT
CITY OF TORONTO

Corporate Real Estate Management
Project Management Office
Metro Hall Toronto, ON
M5V 3C6

COPYRIGHT
This drawing has been prepared solely for the intended use. Thus any reproduction or distribution for any purpose other than authorized by Arcadis is forbidden. Written dimensions shall have precedence over scaled dimensions. Contractors shall verify and be responsible for all dimensions and conditions on the job, and Arcadis shall be informed of any variations from the dimensions and conditions shown on the drawing. Shop drawings shall be submitted by Arcadis for general conformance before proceeding with fabrication.

Arcadis Professional Services (Canada) Inc.

ISSUES		
No.	DESCRIPTION	DATE
C	ISSUED FOR 95% DESIGN	2025-12-01
D	ISSUED FOR 100% DESIGN	2025-12-10
E	ISSUED FOR PERMIT	2025-12-10
F	ISSUED FOR TENDER	2025-12-10
G	ISSUED FOR TENDER REV. 01	2025-12-23
H	ADDENDUM 3	2026-01-12

CONSULTANTS

SEAL

PRIME CONSULTANT



100 - 175 Galaxy Blvd,
Toronto, ON M9W 0C9, Canada
tel 416 679 1930
www.arcadis.com

PROJECT TITLE

TORONTO PARAMEDIC SERVICES
FLEET MAINTENANCE STATION -
UPGRADE WORKS

PROJECT ADDRESS

KING STREET YARD -
BUILDING NO. 8 & 9
1116 KING STREET WEST

PROJECT NO:

30276606

DRAWN BY:

M.B

CHECKED BY:

L. S.

PROJECT MGR:

N. L.

APPROVED BY:

F.R

SHEET TITLE

FIRST FLOOR ELECTRICAL
STAGE 1 (PRE-FIFA)

SHEET NUMBER

E801

ISSUE

H

