




GBGH Minor Works - Pharmacy - Issued for Permit/Tender - 2025-12-17



1 KEY PLAN
1 : 2000



DRAWING LIST

SHEET NUMBER SHEET NAME

Architectural

A000	COVER SHEET
A002	SYMBOLS AND ABBREVIATIONS
A003	ASSEMBLIES SCHEDULE
A010	CODE SUMMARY
A011	LIFE SAFETY PLANS
A015	SITE SURVEY
A020	OVERALL SITE PLAN
A021	LEVEL 1 - OVERALL KEY PLAN
A030	SCHEDULES
A100	LEVEL 1 - DEMOLITION PLAN
A102	LEVEL 1 - DEMOLITION PLAN (PHASE 1)
A103	LEVEL 1 - DEMOLITION PLAN (PHASE 3)
A110	LEVEL 1 - DEMOLITION RCP
A111	LEVEL 1 CLEAN CARTS - DEMOLITION RCP (PHASE 0)
A112	LEVEL 1 - DEMOLITION RCP (PHASE 1)
A113	LEVEL 1 - DEMOLITION RCP (PHASE 3)
A114	DEMOLITION DETAILS
A200	LEVEL 1 - OVERALL FLOOR PLAN
A201	LEVEL 1 - OVERALL FLOOR PLAN (PHASE 0)
A202	LEVEL 1 - OVERALL FLOOR PLAN (PHASE 1)
A203	LEVEL 1 - OVERALL FLOOR PLAN (PHASE 2)
A204	LEVEL 1 - OVERALL FLOOR PLAN (PHASE 3)
A210	LEVEL 1 - OVERALL FINISH PLAN
A220	WALL GRAPHIC ELEVATIONS
A300	LEVEL 1 - REFLECTED CEILING PLAN
A301	LEVEL 1 - REFLECTED CEILING PLAN (PHASE 1)
A302	LEVEL 1 - REFLECTED CEILING PLAN (PHASE 3)
A500	BUILDING SECTIONS
A550	WALL SECTIONS
A600	DETAILS
A610	TYPICAL DETAILS
A800	INTERIOR ELEVATIONS
A801	INTERIOR ELEVATIONS
A802	INTERIOR ELEVATIONS
A803	INTERIOR ELEVATIONS
A804	INTERIOR ELEVATIONS
A830	MILLWORK DETAILS
A831	METAL CASEWORK DETAILS
A1000	MOUNTING HEIGHTS

DRAWING LIST

SHEET NUMBER SHEET NAME

Mechanical

M-000	COVER PAGE
M-001	MECHANICAL LEGEND & DRAWING LIST
M-002	MECHANICAL SCHEDULES I
M-201	PLUMBING DEMOLITION - LEVEL 1
M-250	PLUMBING NEW WORK - FOUNDATION
M-251	PLUMBING NEW WORK - LEVEL 1
M-301	VENTILATION DEMOLITION - LEVEL 1
M-351	VENTILATION NEW WORK - LEVEL 1
M-353	VENTILATION NEW WORK - LEVEL 2
M-391	HVAC PRESSURIZATION - LEVEL 1
M-501	FIRE PROTECTION DEMOLITION - LEVEL 1
M-551	FIRE PROTECTION NEW WORK - LEVEL 1
M-700	MECHANICAL CONTROL SEQUENCES I
M-800	MECHANICAL TYPICAL DETAILS I


Electrical

E-001	ELECTRICAL LEGEND AND DRAWING LIST
E-002	ELECTRICAL SPECIFICATION I
E-003	ELECTRICAL SPECIFICATION II
E-100	ELECTRICAL PARTIAL LEVEL 1 KEY PLAN
E-200	LEVEL 1 - ELECTRICAL LIGHTING LAYOUT - DEMOLITION (PHASE 0)
E-201	LEVEL 1 - ELECTRICAL LIGHTING LAYOUT - DEMOLITION (PHASE 1 AND 3)
E-202	LEVEL 1 - ELECTRICAL POWER LAYOUT - DEMOLITION (PHASE 1 AND 3)
E-203	LEVEL 1 - COMMUNICATION, FIRE ALARM AND DOOR ACCESS CONTROL SYSTEMS LAYOUT - DEMOLITION (PHASE 1 AND 3)
E-300	LEVEL 1 - ELECTRICAL LIGHTING LAYOUT - NEW WORK (PHASE 0, 1, AND 3)
E-301	LEVEL 1 - ELECTRICAL POWER LAYOUT - NEW WORK (PHASE 0 AND 2)
E-302	LEVEL 1 - ELECTRICAL POWER LAYOUT - NEW WORK (PHASE 1 AND 3)
E-303	LEVEL 1 COMMUNICATION, FIRE ALARM AND DOOR ACCESS CONTROL SYSTEMS LAYOUT - NEW WORK (PHASE 0 AND 2)

ARCHITECT:

MECHANICAL, ELECTRICAL ENGINEER:

CLIENT:



Cumulus Architects Inc.
Suite 300 - 160 Pears Avenue
Toronto, ON M5R 3P8
(416) 539-0763
cumulusarch.com



Quasar Consulting Group
250 Rowntree Dairy Road
Woodbridge ON, L4L 9J7
905-507-0800




GBGH
1112 St Andrews Dr.
Midland, ON
L4R 4P4

ABBREVIATIONS

ACM	ACCESSIBLE	HM	HOLLOW METAL	RO	ROUGH OPENING
ADM	ASBESTOS CONTAINING MATERIAL	HORIZ	HORIZONTAL	ROW	RIGHT OF WAY
ADJ	ADJACENT	HOSP	HOSPITAL	RSN	RESILIENT STAIR NOSING
AFF	ABOVE FINISHED FLOOR	HP	HIGH POINT	RST	RESILIENT STAIR TREAD
AGF	ARCHITECTURAL GLASS FLOORING	HPC	HIGH PERFORMANCE COATING	RT	RESILIENT TILE
AHU	AIR HANDLING UNIT	HPL	HIGH PRESSURE DECORATIVE LAMINATE	RTU	ROOF TOP UNIT
ALT	ALTERNATE	HR	HANDRAIL	RV	RIGID VINYL
ALUM	ALUMINUM	HSS	HOLLOW STRUCTURAL SECTION		
APC	ACOUSTICAL PANEL CEILING	HT	HEIGHT	S	SEALED
APPROX	APPROXIMATE	HVAC	HEATING-VENT-AIR CONDITIONING	SDF	STATIC DISSIPATIVE FLOORING
ARCH	ARCHITECTURAL)	HWB	HEAT WELDING BEAD	SECT	SECTION
ASN	ABRASIVE STAIR NOSING			SGT	STRUCTURAL GLAZED TILE
ATC	ACOUSTICAL TILE CEILING	ID	INSIDE DIAMETER	SHR	SHOWER
AUTO	AUTOMATIC	INCL	INCLUDED	SHT	SHEET
AWP	ACOUSTICAL WALL PANEL	INSUL	INSULATION(ED)	SIM	SIMILAR
		INT	INTERIOR	SM	SPECIALIZED METAL
BLDG	BUILDING			SOG	SLAB-ON-GRADE
BLKG	BLOCKING	JAN	JANITOR	SOP	STARTING OUT POINT
BOS	BOTTOM OF STEEL	JT	JOINT	SP	SAFETY PAD
BRG	BEARING			SPEC	SPECIFY(ICATION) PROJECT MANUAL
BSMT	BASEMENT	KIT	KITCHEN	SQ	SQUARE
				SS	SOLID SURFACE(ING)
C	COURSE	LAB	LABORATORY	SSB	STEEL SHEET BACKING
CF	CONDUCTIVE FLOORING	LAM	LAMINATE(D)	SST	STAINLESS STEEL
CFCI	CONTR-FURN/CONTR-INST	LAV	LAVATORY	ST	STONE
CG	CORNER GUARD	LGT	LENGTH	STC	SOUND TRANSMISSION CLASS
CHG	CHANGE ROOM	LH	LEFT HAND	STD	STANDARD
CIP	CAST-IN-PLACE	LIN	LINOLEUM	STL	STEEL
CJ	CONTROL JOINT	LP	LOWPOINT	STRUCT	STRUCTURE(AL)
CL	CENTERLINE	LT	LIGHT	SUSP	SUSPENDED
CLG	CEILING	LWT	LIGHTWEIGHT	SV	SHEET VINYL
CLO	CLOSET	LVT	LUXURY VINYL TILE	SWC	SPECIAL WALL COATING
CLR	CLEAR(ANCE)				
CLRM	CLASSROOM	MACH	MACHINE	T	TREAD
CMT	CERAMIC MOSAIC TILE	MARB	MARBLE	T&G	TONGUE & GROOVE
CMTB	CERAMIC MOSAIC TILE BASE	MAS	MASONRY	T/O	TOP OF
CMU	CONCRETE MASONRY UNIT	MATL	MATERIAL	TB	TACK BOARD
CO	CLEAN OUT	MAX	MAXIMUM	TBD	TO BE DETERMINED
COL	COLUMN	MB	MARKER BOARD	TEMP	TEMPORARY
COMM	COMMUNICATION	MCP	METAL CEILING PANEL	TER	TERRAZZO
CONC	CONCRETE	MECH	MECHANICAL	TERB	TERRAZZO BASE
CONF	CONFERENCE	MES	METAL EDGE STRIP	TEXT	TEXTURE
CONT	CONTINUOUS	MEZZ	MEZZANINE	THK	THICK(NESS)
CORR	CORRIDOR	MFR	MANUFACTURER(D)	TLT	TOILET
CPT	CARPET(ING)	MHO	MAGNETIC HOLD OPEN	TOFF	TOP OF FINISHED FLOOR
CR	CRASH RAIL	MIN	MINIMUM	TOS	TOP OF STEEL
CT	CERAMIC TILE	MISC	MISCELLANEOUS	TOW	TOP OF WALL
CTB	CERAMIC TILE BASE	MO	MASONRY OPENING	TP	TANGENT POINT
CUH	CABINET UNIT HEATER	MPC	METAL PANEL CEILING	TPO	THERMOPLASTIC POLYOLEFIN ROOFING
CW	CASEWORK	MSS	METAL SUSPENSION SYSTEM		MEMBRANE
		MTL	METAL	TRSLT	TRANSLUCENT
DEMO	DEMOLISH(ITION)	MW	MILLWORK	TS	TACKABLE SURFACE
DEPT	DEPARTMENT			TYP	TYPICAL
DIA	DIAMETER	NIC	NOT IN CONTRACT		
DIAG	DIAGONAL	NO	NUMBER	U/S	UNDERSIDE OF
DIM	DIMENSION	NOM	NOMINAL	UC	UNDERCOUNTER
DN	DOWN	NTS	NOT TO SCALE	UNO	UNLESS NOTED OTHERWISE
DS	DOWNSPOUT			UPH	UPHOLSTERY
		OC	ON CENTER		
EA	EACH	OD	OUTSIDE DIAMETER	VAC	VACUUM
EIFS	EXTERIOR INSULATION FINISH SYSTEM	OFCl	OWNER FURN CONTR INST	VCT	VINYL COMPOSITION TILE
EJ	EXPANSION JOINT	OFCl	OWNER FURN OWNER INST	VEST	VESTIBULE
EL	ELEVATION	OH	OVERHEAD	VET	VINYL ENHANCED TILE
ELEC	ELECTRIC(AL)	OPNG	OPENING	VIF	VERIFY IN FIELD
ELEC	ELECTRICAL	OPP	OPPOSITE	VNL	VINYL
ELEV	ELEVATOR	ORD	OVERFLOW ROOF DRAIN	VP	VOLLEYBALL / BADMINTON POST
EM	ENTRANCE MATS			VTR	VENT THROUGH ROOF
EMB	ELECTRONIC MARKER BOARD	PB	PUSH BUTTON	WWC	VINYL WALL COVERING
EMER	EMERGENCY	PBD	PARTICLE BOARD		
EOS	EDGE OF SLAB	PCC	PRECAST CONCRETE	WAF	WOOD ATHLETIC FLOORING
EP	ELECTRICAL PANEL	PCF	POUNDS PER CUBIC FOOT	WB	WOOD BLOCKING
EQ	EQUAL	P'CONC	POLISHED CONCRETE	WC	WATER CLOSET
EQUIP	EQUIPMENT	PERF	PERFORATE(D)	WCV	WALL COVERING
ER	EPOXY RESIN	PL	PLATE	WD	WOOD
EST	ESTIMATE(D)	PLP	PLASTIC PANEL	WDV	WOOD VENEER
EWC	ELECTRIC WATER COOLER	PLSHD	POLISHED	WDMTR	WINDOW TREATMENT
EXH	EXHAUST	PLYWD	PLYWOOD	WM	WATER METER
EXIST	EXISTING	PMF	PREFINISHED METAL FLASHING	WP	WORK POINT
EXP	EXPANSION	PMS	PREFINISHED METAL SIDING	WPC	WOOD PANEL CEILING
EXPD	EXPOSED	PMT	PORCELAIN MOSAIC TILE	WT	WEIGHT
EXT	EXTERIOR	PNT	PAINT(ED)	WW	WATER SHUT-OFF VALVE
		POT	PORCELAIN TILE		
F/O	FACE OF	PREFAB	PREFABRICATED		
FD	FLOOR DRAIN	PREFIN	PREFINISHED		
FDTN	FOUNDATION	PRT	POLY RESIN TILE		
FE	FIRE EXTINGUISHER	PSF	POUNDS PER SQUARE FOOT		
FEC	FIRE EXTINGUISHER CABINET	PSI	POUNDS PER SQUARE INCH		
FG	FOOT GRILLE	PTB	PORCELAIN TILE BASE		
FHC	FIRE HOSE CABINET				
FHCR	FIRE HOSE CABINET RECESSED	QT	QUARRY TILE		
FIN	FINISH(ED)	QTB	QUARRY TILE BASE		
FLR	FLOOR	QTY	QUANTITY		
FOG	FACE OF GLASS				
FOS	FACE OF STEEL	R	RISER		
FRR	FIRE RESISTANCE RATING	RA	ROOF ANCHOR		
FT	FOOT/FEET	RAD	RADIUS		
FTG	FOOTING	RAF	RESILIENT ATHLETIC FLOORING		
FWP	FABRIC WRAPPED PANE	RBf	RUBBER FLOORING		
		RBRT	RUBBER TILE		
GA	GAUGE / GAGE	RCp	REFLECTED CLG PLAN		
GALV	GALVANIZED	RD	ROOF DRAIN		
GFRc	GLASS FIBER REINF CONCRETE	REF	REFERENCE(CE) TO		
GFRG	GLASS FIBER REINF GYPSUM	REFG	REFRIGERATOR		
GL	GLASS	REINF	REINFORCED(ING)		
GLMT	GLASS MOSAIC TILE	REQD	REQUIRED		
GLMU	GLASS MASONRY UNIT	RES	RESILIENT		
GLT	GLASS TILE	RESB	RESILIENT BASE		
GST	GLASS STAIR TREAD	REV	REVISE (SION)		
GWB	GYPSUM WALL BOARD	RF	RESINOUS FLOORING		
GYP	GYPSUM	RFg	ROOFING		
		RH	RIGHT HAND		
HB	HOSE BIBB	RM	ROOM		
HDW	HARDWARE				

SYMBOLS LEGEND



GENERAL NOTES

THESE NOTES ARE TO BE READ IN CONJUNCTION WITH THE DRAWINGS AND SPECIFICATION.

DO NOT SCALE DRAWINGS. WRITTEN DIMENSIONS GOVERN. NOTIFY CONSULTANT OF DISCREPANCIES OR CONFLICTS IN THE DOCUMENTS PRIOR TO EXECUTION OF WORK.

VERIFY DIMENSIONS NOTED AS "CLEAR", "HOLD", "MIN", "CRITICAL", OR "I.F.:" DURING LAYOUT OF WORK.

STRUCTURAL, MECHANICAL & ELECTRICAL ITEMS SHOWN ON THE ARCHITECTURAL DRAWINGS ARE FOR COORDINATION PURPOSES. REFER TO RESPECTIVE DISCIPLINES DRAWINGS AND SPECIFICATIONS FOR COMPLETE LAYOUTS.

PROTECT AREA OF WORK AND ADJACENT AREAS FROM DAMAGE.


DO NOT LOAD ANY PART OF THE WORK WITH WEIGHT THAT WILL DAMAGE OR ENDANGER THE SAFETY OF THE STRUCTURE OR ANY PART THEREOF.

CONFIRM THE LOCATION OF ALL SERVICES INTERIOR AND EXTERIOR PRIOR TO COMMENCING CONSTRUCTION.


NOTIFY CONSULTANT AND OWNER IF HAZARDOUS MATERIALS ARE DISCOVERED ON SITE DURING CONSTRUCTION.

REVIEW THE LOCATION OF ACCESS HATCHES OR PANELS WITH CONSULTANT PRIOR TO INSTALLATION AND ADJUST POSITION AS REQUIRED BASED ON REVIEW.

SCAN STRUCTURAL SLAB AT ALL LOCATIONS OF CORE DRILLING AND PROVIDE SUBMITTALS FOR REVIEW IN ACCORDANCE WITH THE SPECIFICATIONS AND WITH THE OWNER'S REQUIREMENTS. COORDINATE LAYOUT OF ALL CORE LOCATIONS AND REVIEW WITH CONSULTANT PRIOR TO EXECUTION OF WORK.



MATERIAL LEGEND



CLIENT:



CONSULTANT



SEAL:



This drawing, as an instrument of service, is the property of Cumulus Architects Inc., the copyright in the same being reserved to them. No reproduction is allowed without the permission of Cumulus Architects Inc. and when made must bear its name.

This drawing is not to be scaled. The contractor is to verify dimensions and data noted herein for conformity with the conditions on site and is responsible for reporting in writing any discrepancy to Cumulus Architects Inc. for adjustment.

Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.

3	Issued for Permit/Tender	2025-12-17
2	Issued for 100% Design Development	2025-10-14
1	Issued for Schematic Design	2025-05-26
NO	DESCRIPTION	DATE

SHEET REVISION

PROJECT:
GBGH Minor Works - Pharmacy
1112 St Andrews Dr, Midland, ON L4R 4P4

TITLE:

SYMBOLS AND
ABBREVIATIONS

PROJECT NO:
24013B

CHECKED:
TP

DRAWING NO:

A002

CEILING ASSEMBLIES

ACT1




CLEANABLE ACOUSTIC TILE CEILING




GYP SUM BOARD CEILING


INTERIOR WALL ASSEMBLIES




X1 PARTITION - FULL HEIGHT, 1 LAYER TYPE-X GYP EACH SIDE						
MARK	DESCRIPTION	FRAME		Max. Wall Ht., mm	Sound Blanket	STC Rating
		Stud Size, mm	Stud Spacing, mm			
X1A	1 HR FRFR PARTITION ULC DES. U419	92	@406 O.C.	4.6M	YES	45
X1B	1 HR FRFR PARTITION ULC DES. U419	152	@406 O.C.	6.4M	YES	45



P1 PARTITION - FULL HEIGHT, 1 LAYER GYP EACH SIDE						
MARK	DESCRIPTION	FRAME		Max. Wall Ht., mm	Sound Blanket	STC Rating
		Stud Size, mm	Stud Spacing, mm			
P1A		152	@406 O.C.	6.4M	YES	50
P1B		152	@406 O.C.	6.4M	NO	45
P1C		92	@406 O.C.	4.6M	YES	50
P1D		92	@406 O.C.	4.6M	NO	45



F1 - FURRING						
MARK	DESCRIPTION	FRAME		Max. Wall Ht., mm	Sound Blanket	STC Rating
		Stud Size, mm	Stud Spacing, mm			
F1A		22	@406 O.C.		NO	



F2 - FURRING, TO 150mm ABOVE CEILING, SINGLE LAYER GYP.						
MARK	DESCRIPTION	FRAME		Max. Wall Ht., mm	Sound Blanket	STC Rating
		Stud Size, mm	Stud Spacing, mm			
F2A		64	@406 O.C.		NO	
F2B		92	@406 O.C.		NO	

PROTECTION OF EXISTING CONSTRUCTION - GENERAL

- UPON MOBILIZATION, PERFORM A PRE-CONSTRUCTION SURVEY OF THE EXISTING CONDITIONS COMPLYING WITH THE REQUIREMENTS OF THE CONTRACT.
- PROTECT AREA OF WORK AND ADJACENT AREAS FROM DAMAGE.
- PROTECT ADJACENT EXISTING CONSTRUCTION AND SURFACES-- INCLUDING BUT NOT LIMITED TO WALLS, WINDOWS, DOORS, FLOORS, CEILINGS, FURNITURE, FIXTURES, ETC.
- DO NOT LOAD ANY PART OF THE WORK WITH WEIGHT THAT WILL DAMAGE OR ENDANGER THE SAFETY OF THE STRUCTURE OR ANY PART THEREOF.
- PROTECTION MUST WITHSTAND IMPACT AND DAMAGE UNDERTAKEN DURING REMOVAL AND REPLACEMENT OPERATIONS.
- PROTECTION OF CEILINGS, WALLS AND FLOORS SHALL BE SELF-SUPPORTING WITH NO FASTENING OF ANY KIND INTO THESE MATERIALS.
- DAMAGE TO ADJACENT MATERIALS AND FINISHES DUE TO THE WORK OF THIS CONTRACT SHALL BE REPAIRED BY THE GENERAL CONTRACTOR INCLUDING THE REPLACEMENT OF DAMAGED ELEMENTS TO MATCH EXISTING ARRANGEMENTS, SIZE AND MATERIAL.

REPAIR OF EXISTING AND MISSING FIRESTOPPING

- MAINTAIN FIRE RESISTANCE RATING OF EXISTING ASSEMBLIES. REPAIR/RESTORE ALL EXISTING FIRESTOPPING, SMOKE SEALS AND APPLIED FIRE PROTECTION WITHIN THE CONSTRUCTION AREA WHICH ARE FOUND TO BE DEFICIENT.
- REPAIR/RESTORE ALL EXISTING FIRESTOPPING, SMOKE SEALS AND APPLIED FIRE PROTECTION COATINGS THAT ARE AFFECTED OR DAMAGED AS A RESULT OF WORK.
- PROVIDE FIRESTOPPING AND SMOKE SEALS AT ALL SERVICE PENETRATIONS OF NEW WALL AND/OR FLOOR FIRE SEPARATIONS. FIRESTOPPING RATING TO MATCH FIRE RESISTANCE RATING (FRR) OF THE FIRE SEPARATION AFFECTED BY THIS WORK.
- WHERE FIRESTOPPING IS MISSING AT EXISTING SERVICE PENETRATIONS AND GAPS BETWEEN EQUIPMENT COVERS, HVAC GRILLES THROUGH ALL PARTITIONS, ALL FLOORS, STRUCTURAL SLABS AND DROPPED PLASTER CEILINGS, INSTALL NEW FIRESTOPPING.
- COSTS OF REPAIRING MISSING FIRESTOPPING TO BE MADE THROUGH A CASH ALLOWANCE UNDER THE CONTRACT.

FLOOR PLANS:

- ARCHITECTURAL CONSTRUCTION PLANS INDICATE PARTITION LAYOUT, TYPES AND BUILT-IN FEATURES. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO ENSURE PROPER COORDINATION WITH DOORS, DEVICES, MILLWORK, FIXTURES, FINISHES, EQUIPMENT AND FURNITURE.
- ALIGNMENTS ARE DIMENSIONED FROM FINISH FACE TO FINISH FACE, UNLESS OTHERWISE NOTED. ALLOW FOR THICKNESS OF FINISHES.
- VERIFY DIMENSIONS NOTED AS "CLEAR", "HOLD", "MIN", "CRITICAL", OR "V.I.F." DURING LAYOUT OF WORK. NOTIFY ARCHITECT OF DISCREPANCIES OR CONFLICTS PRIOR TO EXECUTION OF WORK.
- LAYOUT ALL PARTITION LOCATIONS ON THE STRUCTURAL SLAB FOR CONSULTANT REVIEW PRIOR TO CONSTRUCTION. ADVISE CONSULTANTS OF DISCREPANCIES WITH THE DIMENSIONED PLANS OR CONFLICTS WITH OTHER PARTS OF THE WORK. ADJUST LOCATIONS AS REQUIRED BASED ON REVIEW.
- PARTITIONS ARE TO BE SECURED TO THE U/S OF STRUCTURE UNLESS OTHERWISE NOTED.
- PATCH AND REPAIR EXISTING WALLS, FLOORS, COLUMNS AND SURFACES TO REMAIN AS REQUIRED TO LEAVE THEM SMOOTH, EVEN AND/OR LEVEL TO RECEIVE NEW FINISHES. STARTING OF WORK INDICATES INSTALLERS ACCEPTANCE OF SUBSTRATE.
- PROVIDE SOLID WOOD BLOCKING AS REQUIRED IN PARTITION WALLS TO SUPPORT SHELVING, HANGING RODS, MILLWORK, GRAB BARS, ACCESSORIES AND OTHER ITEMS THAT ARE PART OF THIS CONTRACT. REFER TO CONSULTANT PLANS AND SPECIFICATIONS TO COORDINATE LOCATION OF BLOCKING TO SUPPORT ALL WALL MOUNTED FURNISHINGS PROVIDED BY OTHERS.

REFLECTED CEILING PLANS:

- THE REFLECTED CEILING PLAN AND ASSOCIATED ENLARGED CEILING PLANS SHOW LOCATION FOR CRITICAL CEILING COMPONENTS AND DEVICES. REFER TO ELECTRICAL, MECHANICAL DRAWINGS FOR FULL SCOPE OF WORK AND QUANTITIES.
- MAINTAIN LAYOUT AS INDICATED IN THE REFLECTED CEILING PLANS. ADVISE CONSULTANTS OF DISCREPANCIES WITH THE DIMENSIONED PLANS OR CONFLICTS WITH OTHER PARTS OF THE WORK. ADJUST LOCATIONS AS REQUIRED BASED ON REVIEW.
- LOCATE UN-DIMENSIONED SPRINKLER HEADS, SPEAKERS, LIGHT FIXTURES AND OTHER ITEMS IN THE CENTRE OF SUSPENDED ACOUSTIC CEILING TILES UNLESS OTHERWISE NOTED.
- FINISH AND COLOUR OF ACCESS PANELS, HVAC DIFFUSERS/REGISTERS, LIGHT FIXTURES, CEILING TRIM, DRAPERY POCKETS, SPEAKER GRILLES AND OTHER CEILING MOUNTED DEVICES TO MATCH CEILING COLOUR UNLESS OTHERWISE NOTED.
- REVIEW THE LOCATION OF ACCESS HATCHES OR PANELS WITH CONSULTANTS PRIOR TO INSTALLATION AND ADJUST POSITION AS REQUIRED BASED ON REVIEW.

CLEARANCE AT EXISTING STRUCTURE

- PROVIDE MINIMUM OF 38 MM CLEARANCE ABOVE MAIN CARRYING T-BARS AND UNDERSIDE OF NEW MECHANICAL EQUIPMENT AND DISTRIBUTION TO PERMIT CEILING TILE INSTALLATION.
- PROVIDE MINIMUM OF 13MM CLEAR BELOW UNDERSIDE OF EXISTING STRUCTURAL BEAM AND TOP OF NEW MECHANICAL EQUIPMENT AND DISTRIBUTION.

REINSTATEMENT OF EXISTING CEILING-MOUNTED FIXTURES

- REINSTATE EXISTING CEILING-MOUNTED FIXTURES, FIRE ALARM DEVICES, AIR TERMINALS AND SECURITY DEVICES IN EXISTING LOCATIONS.
- REFER TO ELECTRICAL AND MECHANICAL DRAWINGS AND SPECIFICATIONS. COORDINATE WORK WITH OWNER AND BUILDING OPERATIONS. REPLACE TO MATCH EXISTING ANY FIXTURES, COMPONENTS OR DEVICES DAMAGED DURING CONSTRUCTION.

DEMOLITION NOTES

- ARCHITECTURAL DEMOLITION SCOPE INDICATED ON DRAWINGS IS TO BE READ IN CONJUNCTION OF OTHER ARCHITECTURAL DRAWINGS AND SPECIFICATIONS, AND DRAWINGS AND SPECIFICATIONS PROVIDED BY MECHANICAL & ELECTRICAL CONSULTANTS.
- DEMOLITION DRAWINGS:
 - DEMOLITION DRAWINGS ARE GENERAL IN NATURE. THE CONTRACT DOCUMENTS REQUIRE ALL THE DEMOLITION NECESSARY TO ACCOMPLISH THE FINAL RESULT OF THE WORK AS SHOWN IN THE CONTRACT DOCUMENTS WHETHER OR NOT SUCH DEMOLITION IS SPECIFICALLY NOTED ON THE DEMOLITION OR OTHER CONTRACT DRAWINGS. THE GENERAL CONTRACTOR IS RESPONSIBLE FOR COORDINATING THE DEMOLITION PERFORMED BY ALL TRADES AND SUBCONTRACTORS.
 - DASHED LINES INDICATE, IN A GENERAL MANNER, ALL WORK TO BE DEMOLISHED, WHERE DEMOLITION OCCURS, ALL DISTURBED SURFACES MUST BE PATCHED TO MATCH SURROUNDING WALLS, FLOORS, CEILINGS, AND/OR TRIM. ETC
- VERIFY ALL EXISTING CONDITIONS PRIOR TO COMMENCING THE WORK. NOTIFY THE ARCHITECT AND CONSULTANTS OF ANY DISCREPANCIES WITH THE DRAWINGS PRIOR TO DEMOLITION.
- COORDINATE WITH OWNER FOR HOURS OF OPERATION, MATERIAL AND WASTE HANDLING REQUIREMENTS.
- COORDINATE WITH OWNER AND OBTAIN APPROVAL FOR SPECIAL DEMOLITION ACTIVITIES CAUSING DISTURBANCE TO OTHER OCCUPANTS AND SPACES OUTSIDE DEMOLITION AREA.

- PATCH AND REPAIR EXISTING WALLS, FLOORS, COLUMNS AND SURFACES TO REMAIN AS REQUIRED TO LEAVE THEM SMOOTH, EVEN AND/OR LEVEL TO RECEIVE NEW FINISHES. STARTING OF WORK INDICATES INSTALLERS ACCEPTANCE OF SUBSTRATE.
- CONTRACTOR SHALL SCAN/XRAY STRUCTURAL SLABS AT ALL LOCATIONS OF PROPOSED CORE DRILLING AND SUBMIT RESULTS TO CONSULTANTS' FOR REVIEW IN ACCORDANCE WITH THE SPECIFICATIONS AND WITH THE OWNER'S REQUIREMENTS. COORDINATE LAYOUT OF ALL CORE LOCATIONS AND REVIEW WITH CONSULTANT PRIOR TO EXECUTION OF WORK.

LOCAL PATCH AND REPAIR

- LOCALLY PATCH AND REPAIR TO MATCH EXISTING CONDITIONS AND ANY EXISTING CONSTRUCTION ADJACENT TO AND AFFECTED BY DEMOLITION WORK, TEMPORARY WORK OR NEW CONSTRUCTION.
- EXAMINE EXISTING CONDITIONS PRIOR TO COMMENCING WORK, INCLUDING ELEMENTS SUBJECT TO DAMAGE OR MOVEMENT DURING CUTTING OR PATCHING.
- PROVIDE TEMPORARY SUPPORT TO ENSURE STRUCTURAL INTEGRITY OF THE WORK.
- REFINISH SURFACES TO MATCH ADJACENT FINISH. FOR CONTINUOUS SURFACES, REFINISH TO NEAREST INTERSECTION OR NATURAL BREAK.

EXISTING FURNITURE:

- MOVING FURNITURE TO ACCOMMODATE CEILING WORK SHALL BE PROVIDED BY GENERAL CONTRACTOR. IDENTIFY THE MINIMUM NUMBER OF FURNITURE PIECES TO BE TEMPORARILY MOVED AND LOCATIONS WHERE THEY ARE TO BE MOVED TO FACILITATE CEILING WORK AND COORDINATE WITH THE GENERAL CONTRACTOR.
- PROVIDE PROTECTION OF EXISTING MILLWORK AND FURNITURE THAT IS TO REMAIN FROM DAMAGE DURING CONSTRUCTION.

BOUNDARY OF HOARDING

- APPROXIMATE BOUNDARY OF REQUIRED HOARDING CORRESPONDS TO BOUNDARY OF EXPECTED LIMIT OF WORK INDICATED BY DASHED LINE.
- WHERE EXISTING WALLS FULFILL HOARDING REQUIREMENTS, CONSTRUCTION OF NEW HOARDING IS NOT NECESSARY.
- IN AREAS WITH NO CEILING OR WHERE CEILING IS TEMPORARILY REMOVED TO ACCOMMODATE DEMOLITION OR NEW WORK, HOARDING TO EXTEND TO U/S SLAB, AS PER LIFE SAFETY REQUIREMENTS.
- REFER TO A001 - GENERAL NOTES, 'FIRE PROTECTION & LIFE SAFETY PROVISIONS DURING CONSTRUCTION'.

TEMPORARY REMOVAL OF EXISTING CEILING-MOUNTED FIXTURES

- WHERE INDICATED, TEMPORARILY REMOVE EXISTING CEILING-MOUNTED LIGHTING AND MECHANICAL FIXTURES, FIRE ALARM AND SECURITY DEVICES AS INDICATED BY DASHED LINE AS REQUIRED TO ACCOMMODATE MECHANICAL AND ELECTRICAL WORK. SALVAGE AND PROTECT EXISTING FOR REINSTATEMENT.
 - SALVAGE AND PROTECT EXISTING FOR REINSTATEMENT. REFER TO MECHANICAL AND ELECTRICAL DRAWINGS FOR TYPES, QUANTITIES AND LOCATIONS.
 - REPLACE EXISTING FIXTURES DAMAGED DURING TEMPORARY REMOVAL OR DURING STORAGE.
- FIRE PROTECTION AND LIFESAFTY PROVISIONS DURING CONSTRUCTION**
- ADHERE TO THE FOLLOWING PROTECTION METHODS FOR 810 UNIVERSITY AVE. WHEN WORK UNDER THE CONTRACT REQUIRES TEMPORARY DISRUPTION OF FIRE/LIFE SAFETY SYSTEMS DURING AND BETWEEN CONSTRUCTION SHIFTS.
 - AS A MINIMUM PERFORMANCE STANDARD FOR PROTECTION, AND FAILING ALL OTHER MEASURES DESCRIBED BELOW, GENERAL CONTRACTOR IS RESPONSIBLE FOR PROVIDING A FIRE WATCH PROTOCOL DURING AND BETWEEN EACH CONSTRUCTION SHIFT IN ALL CONSTRUCTION AREAS. OBTAIN PERMISSION FROM THE FACILITY MANAGER.
 - IN THE CONSTRUCTION AREAS AND WHERE THE FIRE PROTECTION SYSTEM IS OPERATIONAL DURING A CONSTRUCTION SHIFT, THE CONTRACTOR SHALL:
 - TEMPORARILY PROTECT EXISTING FIRE ALARM DEVICES AND SPRINKLER HEADS FROM INCIDENTAL CONTACT, DUST AND DEBRIS DURING CONSTRUCTION SHIFT.
 - TEMPORARY PROTECTION TO BE REMOVED AT THE END OF EACH CONSTRUCTION SHIFT TO MAINTAIN EXISTING FIRE ALARM AND SPRINKLER PROTECTION DURING THE DAY BETWEEN CONSTRUCTION SHIFTS.
 - IN THE CONSTRUCTION AREAS AND WHERE THE FIRE PROTECTION SYSTEM CANNOT REMAIN OPERATIONAL, PROVIDE TEMPORARY SMOKE/HEAT DETECTION SYSTEM THAT COMPLIES WITH THE FOLLOWING REQUIREMENTS:
 - SHALL BE DESIGNED BY A PROFESSIONAL ENGINEER IN ACCORDANCE WITH GOOD ENGINEERING PRACTICES, ONTARIO FIRE CODE, AND ONTARIO BUILDING CODE.
 - SHALL REMAIN OPERATIONAL OR BE ACTIVATED DURING THE DAY BETWEEN CONSTRUCTION SHIFTS WHEN THE CONSTRUCTION AREA IS UNOCCUPIED FOR THE ENTIRE DURATION OF CONSTRUCTION IN THAT AREA.
 - ALL EXISTING SMOKE/HEAT DETECTORS SHALL BE PROTECTED DURING DEMOLITION/CONSTRUCTION.
 - MEANS OF EGRESS:
 - REQUIRED MEANS OF EGRESS SHALL BE MAINTAINED AND LIFE SAFETY DEVICES TO REMAIN IN OPERATION AT ALL TIMES.
 - PROVIDE ACCEPTABLE ALTERNATIVE EXITS WHERE AN EXISTING EXIT IS BLOCKED OFF OR DELETED DUE TO CONSTRUCTION ACTIVITIES.

LEGEND - ASSEMBLIES

- PREFIXES
- 'F' - FURRING ASSEMBLY
 - 'P' - PARTITION ASSEMBLY
 - 'S' - SHAFT WALL ASSEMBLY
 - 'C' - FINISH CEILING ASSEMBLY
 - 'R' - ROOF ASSEMBLY
 - 'FL' - FLOOR ASSEMBLY
 - 'EW' - EXTERIOR WALL ASSEMBLY
 - 'X' - THE ASSEMBLY HAS A FIRE-RESISTANCE RATING
 - 'A' - THE ASSEMBLY HAS ACOUSTIC PROPERTIES

GENERAL NOTES

- THESE NOTES ARE TO BE READ IN CONJUNCTION WITH THE DRAWINGS AND SPECIFICATIONS.
- DO NOT SCALE DRAWINGS. WRITTEN DIMENSIONS GOVERN. NOTIFY CONSULTANT OF DISCREPANCIES OR CONFLICTS IN THE DOCUMENTS PRIOR TO EXECUTION OF WORK.
- VERIFY DIMENSIONS NOTED AS "CLEAR", "HOLD", "MIN", "CRITICAL", OR "V.I.F." DURING LAYOUT OF WORK.
- STRUCTURAL, MECHANICAL & ELECTRICAL ITEMS SHOWN ON THE ARCHITECTURAL DRAWINGS ARE FOR COORDINATION PURPOSES. REFER TO RESPECTIVE DISCIPLINES DRAWINGS AND SPECIFICATIONS FOR COMPLETE LAYOUTS.
- PROTECT AREA OF WORK AND ADJACENT AREAS FROM DAMAGE.
- DO NOT LOAD ANY PART OF THE WORK WITH WEIGHT THAT WILL DAMAGE OR ENDANGER THE SAFETY OF THE STRUCTURE OR ANY PART THEREOF.
- CONFIRM THE LOCATION OF ALL SERVICES INTERIOR AND EXTERIOR PRIOR TO COMMENCING CONSTRUCTION.
- NOTIFY CONSULTANT AND OWNER IF HAZARDOUS MATERIALS ARE DISCOVERED ON SITE DURING CONSTRUCTION.
- REVIEW THE LOCATION OF ACCESS HATCHES OR PANELS WITH CONSULTANT PRIOR TO INSTALLATION AND ADJUST POSITION AS REQUIRED BASED ON REVIEW.
- SCAN STRUCTURAL SLAB AT ALL LOCATIONS OF CORE DRILLING AND PROVIDE SUBMITTALS FOR REVIEW IN ACCORDANCE WITH THE SPECIFICATIONS AND WITH THE OWNER'S REQUIREMENTS. COORDINATE LAYOUT OF ALL CORE LOCATIONS AND REVIEW WITH CONSULTANT PRIOR TO EXECUTION OF WORK.
- AT PARTITIONS IN WET AREAS (WASHROOMS AND KITCHENETTE) PROVIDE MOISTURE & MOULD RESISTANT GYPSUM BOARD.
- PROVIDE CONTINUOUS REINFORCING BETWEEN STUDS FOR WALL MOUNTED HANDRAILS, GRAB BARS, MILLWORK, CASEWORK, FURNITURE AND THE LIKE.
- COORDINATE BLOCKING REQUIREMENTS WITH THE DRAWINGS OF ALL DISCIPLINES.

AT FIRE-RATED PARTITIONS:

- CONSTRUCT ASSEMBLY IN ACCORDANCE WITH ULC LISTED DESIGN NO. FROM MATERIALS BEARING ASSOCIATED ULC CLASSIFICATION MARKINGS.
- EXTEND PARTITIONS FULL HEIGHT TO UNDERSIDE OF FLOOR OR ROOF SLAB ABOVE, UNLESS OTHERWISE NOTED.
- PROVIDE FIRESTOPPING AND SMOKE SEALS AT PERIMETER JOINTS AND ALL PENETRATIONS IN FIRE RATED PARTITIONS AND NON-RATED FIRE SEPARATIONS.
- AT FIRE-RATED PARTITIONS AND NON-RATED FIRE SEPARATIONS, FILL AND TAPE ALL JOINTS, FASTENER HEADS, EDGES AND CORNERS IN GYPSUM BOARD AT BOTH EXPOSED AND CONCEALED LOCATIONS.
- COORDINATE THE WORK OF OTHER DISCIPLINES TO MAINTAIN THE SPECIFIED FIRE-RATING.

AT SOUND-RATED PARTITIONS:

- EXTEND GYPSUM BOARD PARTITIONS FULL HEIGHT TO UNDERSIDE OF FLOOR OR ROOF SLAB ABOVE, UNLESS OTHERWISE NOTED.
- PROVIDE ACOUSTIC SEALANT AT PERIMETER JOINTS AND ALL PENETRATIONS THROUGH GYPSUM BOARD.
- STAGGER OPPOSING RECESSED ELECTRICAL AND OTHER DEVICE BOXES MINIMUM 500MM.
- COORDINATE THE WORK OF OTHER DISCIPLINES TO MAINTAIN THE SPECIFIED SOUND-RATING.

APPLICABLE STANDARDS AND CODES:

ALL ASSEMBLIES AND FINISHES TO BE INSTALLED IN CONFORMANCE WITH IPAC CONSTRUCTION DESIGN GUIDELINES AND APPLICABLE CSA 'Z' STANDARDS.

CLIENT:



CONSULTANT:



SEAL:



This drawing, as an instrument of service, is the property of Cumulus Architects Inc. The copyright in the same being reserved to them. No reproduction is allowed without the permission of Cumulus Architects Inc. and when made must bear its name.

This drawing is not to be scaled. The contractor is to verify dimensions and data noted herein for conformity with the conditions on site and is responsible for reporting in writing any discrepancy to Cumulus Architects Inc. for adjustment.

Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.

3	Issued for Permit/Tender	2025-12-17
2	Issued for 100% Design Development	2025-10-14
1	Issued for Schematic Design	2025-05-26
NO	DESCRIPTION	DATE


SHEET REVISION

PROJECT:
GBGH Minor Works - Pharmacy
1112 St Andrews Dr, Midland, ON L4R 4P4

TITLE:
ASSEMBLIES SCHEDULE

PROJECT NO:
24013B
CHECKED:
TP

DRAWING NO:
A003



EXIT ACCESS TRAVEL DISTANCE		
EXIT ROUTE	EGRESS TRAVEL DISTANCE	MAX DISTANCE
PATH A	6.7 m	45 m
PATH B	9.8 m	45 m
PATH C	12.1 m	45 m
PATH D	13.7 m	45 m
PATH E	16 m	45 m
PATH F	20.1 m	45 m
PATH G	33.7 m	45 m

LEGEND - CODE COMPLIANCE

- NOT IN CONTRACT / NOT IN SCOPE AREA
- EXISTING CONSTRUCTION
- NEW CONSTRUCTION
- LINE OF 0 HOUR FIRE SEPARATION
- LINE OF 1 HOUR FIRE SEPARATION
- LINE OF 2 HOUR FIRE SEPARATION

FIRE PROTECTION NOTES:

REQUIRED MEANS OF EGRESS SHALL BE MAINTAINED AND LIFE SAFETY DEVICES TO REMAIN IN OPERATION AT ALL TIMES PER BUILDING CODES.

SPRINKLER AND FIRE ALARM SYSTEMS SHALL BE PUT IN SERVICE AT THE END OF EACH WORKING DAY.

MAKE REPAIRS WITH NEW MATERIALS TO MAINTAIN FIRE RESISTANCE RATING OF EXISTING FIRE-RATED ASSEMBLIES WITHIN THE CONTRACT AREA WHICH ARE FOUND TO BE DEFICIENT.

MAKE REPAIRS WITH NEW MATERIALS TO ALL EXISTING FIRESTOPPING, SMOKE SEALS AND SEALANTS WITHIN THE CONTRACT AREA WHICH ARE FOUND TO BE DEFICIENT.

MAKE REPAIRS WITH NEW MATERIALS TO ALL EXISTING FIRE-RATED ASSEMBLIES, FIRESTOPPING, SMOKE SEALS AND SEALANTS THAT ARE AFFECTED OR DAMAGED AS A RESULT OF THIS WORK.

PROVIDE FIRE DAMPERS, FIRESTOPPING AND/OR SMOKE SEALS AT SERVICE PENETRATIONS THROUGH ALL FIRE-RATED WALL AND FLOOR ASSEMBLIES. FIRE RESISTANCE RATING OF CLOSURE MATERIALS TO MATCH FIRE RESISTANCE RATING (FRR) OF THE FIRE SEPARATION TYP.

ALL PLYWOOD AND/OR WOOD WALL BLOCKING TO BE FIRE RETARDANT TREATED TYP.

CLIENT:



CONSULTANT:




SEAL:



This drawing, as an instrument of service, is the property of Cumulus Architects Inc. the copyright in the same being reserved to them. No reproduction is allowed without the permission of Cumulus Architects Inc. and when made must bear its name.

This drawing is not to be scaled. The contractor is to verify dimensions and data noted herein for conformity with the conditions on site and is responsible for reporting in writing any discrepancy to Cumulus Architects Inc. for adjustment.

Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.



3	Issued for Permit/Tender	2025-12-17
2	Issued for 100% Design Development	2025-10-14
1	Issued for Schematic Design	2025-05-26
NO	DESCRIPTION	DATE


PROJECT:
GBGH Minor Works - Pharmacy
1112 St Andrews Dr, Midland, ON L4R 4P4

TITLE:
LIFE SAFETY PLANS

PROJECT NO:
24013B
CHECKED:
TP

DRAWING NO:

A011





1112 St Andrews Dr,
Midland, ON
L4R 4P4

CONSULTANT:



160 Pears Ave. - Suite 300
Toronto, ON M5R 3P8
416-539-0763
www.cumulusarch.com

SEAL:



SHELLAN MORAO CATARINO
LICENCE
0177

This drawing, as an instrument of service, is the property of Cumulus Architects Inc. The copyright in the same being reserved to them. No reproduction is allowed without the permission of Cumulus Architects Inc. and when made must bear its name.

This drawing is not to be scaled. The contractor is to verify dimensions and data noted herein for conformity with the conditions on site and is responsible for reporting in writing any discrepancy to Cumulus Architects Inc. for adjustment.

Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.

NO	DESCRIPTION	DATE
3	Issued for Permit/Tender	2025-12-17
2	Issued for 100% Design Development	2025-10-14
1	Issued for Schematic Design	2025-05-26

PROJECT:

GBGH Minor Works - Pharmacy
1112 St Andrews Dr, Midland, ON L4R 4P4

TITLE:

SITE SURVEY

PROJECT NO:

24013B

CHECKED:

TP

DRAWING NO:

A015

NOTE: PHASE 1 AND PHASE 3 REQUIRE SEPARATE OCCUPANCIES TO MAINTAIN CONTINUOUS PHARMACY OPERATION.

CLIENT:



1112 St Andrews Dr,
Midland, ON
L4R 4P4

CONSULTANT:



160 Pears Ave. - Suite 30
Toronto, ON M5R 3P8
416-539-0763
www.cumulusarch.com


SEAL:



This drawing, as an instrument of service, is the property of Cumulus Architects Inc., the copyright in the same being reserved to them. No reproduction is allowed without the permission of Cumulus Architects Inc. and when made must bear its name.

This drawing is not to be scaled. The contractor is to verify dimensions and data noted herein for conformity with the conditions on site and is responsible for reporting in writing any discrepancy to Cumulus Architects Inc. for adjustment.

Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.



1 EXISTING LEVEL 1
1:275




TITLE:
LEVEL 1 - OVERALL KEY
PLAN

PROJECT NO:	24013B
CHECKED:	TP

DRAWING NO:

WING NO:

A021



PROJECT NO: 24013B	DRAWING NO: A100
CHECKED: Checker	

A100

NOTE: PHASE 1 AND PHASE 3 REQUIRE SEPARATE OCCUPANCIES TO MAINTAIN CONTINUOUS PHARMACY OPERATION.

LEGEND - DEMOLITION PLAN

- NOT IN CONTRACT / NOT IN SCOPE AREA
- EXISTING CONSTRUCTION TO REMAIN
- EXISTING CONSTRUCTION TO BE REMOVED
- LINE OF 1 HOUR FIRE SEPARATION
- LINE OF PROPOSED CONSTRUCTION HOARDING
- CONTRACTOR TO TAKE RESPONSIBILITY FOR TEMPORARY CONSTRUCTION AND EGRESS/ACCESS ROUTES DURING CONSTRUCTION

GENERAL NOTES:

- PRIOR TO DEMOLITION NOTIFY CONSULTANTS OF ANY DISCREPANCIES WITH THE DRAWINGS.
- PRIOR TO DEMOLITION COORDINATE WITH OWNER HOURS OF OPERATION, MATERIAL AND WASTE HANDLING REQUIREMENTS AND MATERIAL TO BE REUSED.
- PROTECT AREA OF WORK, EXISTING CONSTRUCTION TO REMAIN AND ADJACENT AREAS FROM DAMAGE.
- COORDINATE WITH OWNER AND OBTAIN APPROVAL FOR SPECIAL DEMOLITION ACTIVITIES CAUSING DISTURBANCE TO OTHER OCCUPANTS AND SPACES OUTSIDE DEMOLITION AREA.
- PROVIDE DUST BARRIER TO ALL AREAS AFFECTED BY THE DEMOLITION AND PROTECT AND MAINTAIN PUBLIC AND ADJACENT TENANT AREAS (CORRIDORS, LOBBIES, ETC) DURING DEMOLITION.
- REFER TO OWNER'S DESIGNATED SUBSTANCES REPORT FOR PRE-EXISTING DESIGNATED SUBSTANCES OBSERVED. NOTIFY CONSULTANT AND OWNER OF ANY DESIGNATED SUBSTANCES DISCOVERED DURING DEMOLITION.
- OWNER TO ARRANGE FOR REMOVAL OF ALL EXISTING FURNITURE, FITTINGS AND EQUIPMENT FROM PHASED WORK AREAS PRIOR TO START OF CONSTRUCTION.

FLOORS

- MAINTAIN INTEGRITY OF EXISTING CORRIDOR AND EXITS. CORRIDOR SHALL BE FREE OF CONSTRUCTION MATERIAL AND/OR DEBRIS. EXISTING FLOORING TO REMAIN IN THIS AREA AS NOTED ON PLAN. PROVIDE LOCKING HARDWARE FOR ALL DOORS ENTERING INTO THE CONSTRUCTION AREA FROM EXISTING CORRIDOR. COORDINATE WITH OWNER TO PROVIDE CONSTRUCTION CORE LOCKSET FOR HOARDING ACCESS. PROVIDE DUST SEAL ON ALL DOORS BORDERING WORK AREA WHEN PERFORMING WORK IN CORRIDOR. ANY WORK PERFORMED OUTSIDE OF THE SCOPE AREA SHALL BE DONE AFTER HOURS AND IN COORDINATION WITH THE HOSPITAL. ALL WORK SHALL BE PERFORMED IN CONFORMANCE WITH INFECTION PREVENTION AND CONTROL GUIDELINES.
- NOT USED
- EXISTING FLOOR FINISH (SHEET VINYL, C/W FLASH COVE AND OTHER APPLIED BASES, ETC) TO BE REMOVED. SCRAPE AND PREPARE SUBSTRATE AS REQUIRED TO OBTAIN SMOOTH AND LEVEL SURFACE READY TO RECEIVE NEW FLOOR FINISHES AS AND WHERE SPECIFIED. CLEAN AND LEVEL EXISTING CONCRETE SUBSTRATE, INCLUDING ANY IRREGULARITIES AND PHYSICAL RESIDUE, AND FILL DEPRESSIONS AND CRACKS WITH FLOOR LEVELING COMPOUND. REMOVE ANY EXISTING MATERIAL, ADHESIVES, OIL OR DUST THAT MAY BE DETRIMENTAL TO THE BONDING OF THE NEW FLOORING. TELEGRAPHING OF SUBSTRATE THROUGH TO NEW FLOORING IS NOT PERMITTED. USE SELF-LEVELING MORTAR IN AREAS THAT NEED TO BE BUILT UP TO MATCH EXISTING FLOOR LEVELS. CONTRACTOR TO ENSURE FLOOR IS TRUE AND LEVEL TO MEET THE REQUIREMENTS OF THE NEW WORK. MAKE GOOD FLOOR SUBSTRATES WHERE EXISTING PARTITIONS HAVE BEEN DEMOLISHED (TYP.).
- EXISTING CARPET AND/OR APPLIED WALL BASES TO BE REMOVED, INCLUDING MASTICS, ADHESIVES OR OTHER SURFACE RESIDUES. MAKE GOOD FLOOR SUBSTRATES WHERE EXISTING PARTITIONS HAVE BEEN DEMOLISHED TYP.
- REDUNDANT FLOOR BOXES, RACEWAYS, SERVICES, DRAINS, SLEEVES/OPENINGS THROUGH EXISTING CONCRETE FLOOR SLAB SHALL BE FILLED WITH NEW CONCRETE TO OBTAIN A STRUCTURALLY SOUND, SMOOTH AND LEVEL SURFACE TO RECEIVE NEW FLOOR FINISH TYPICAL. MAKE REPAIRS AS REQUIRED MAINTAIN REQUIRED FIRE-RESISTANCE RATINGS OF FLOOR SLABS.

WALLS

- REMOVE AND DISPOSE OF EXISTING GYPSUM BOARD AND METAL STUD FRAMED PARTITIONS COMPLETE WITH ASSOCIATED WALL BASE, AND CORNER GUARDS, WHERE INDICATED BY DASHED LINES. REMOVE ALL REDUNDANT MECHANICAL AND ELECTRICAL SERVICES IN CONFORMANCE WITH GOVERNING CODES AND AUTHORITIES. REFER TO AND COORDINATE WITH MECHANICAL, ELECTRICAL AND ABATEMENT SCOPE OF WORK. MAKE GOOD ALL AFFECTED SURFACES AS REQUIRED TO MATCH EXISTING, OR TO LEAVE READY TO RECEIVE NEW FINISHES TYP.
- REMOVE AND DISPOSE OF EXISTING CMU WALL TO EXTENTS NOTED. PROVIDE TEMPORARY STRUCTURAL SUPPORT UNTIL NEW LINTELS CAN BE INSTALLED.
- REMOVE AND DISPOSE OF EXISTING INTERIOR WALL ACCESSORIES (I.E. CORNER GUARDS, WALL BUMPERS ETC.) AND MAKE GOOD (PATCH, PAINT) ALL AFFECTED SURFACES AS REQUIRED TO MATCH EXISTING, OR TO LEAVE READY TO RECEIVE NEW FINISHES TYP.
- N.B.: REMOVE AND RETAIN EXISTING WALL-MOUNTED EQUIPMENT, FITMENTS AND DEVICES, INCLUDING ALL RELATED ATTACHMENTS, MOUNTINGS, ETC. COORDINATE WITH OWNER THE EXTENT OF ITEMS TO BE RETAINED.

WINDOWS

- REMOVE AND DISPOSE OF EXISTING INTERIOR WINDOWS AND FRAMES.

DOORS

- REMOVE AND DISPOSE OF EXISTING DOOR, FRAME AND HARDWARE WHERE INDICATED BY DASHED LINES. ELECTRICAL TRADE TO DISCONNECT POWER FOR DOORS WITH ELECTRIFIED CONTROLS/HARDWARE. REFER TO AND COORDINATE WITH MECHANICAL, ELECTRICAL AND ABATEMENT SCOPE OF WORK. MAKE GOOD ALL AFFECTED SURFACES AS REQUIRED TO MATCH EXISTING, OR TO LEAVE READY TO RECEIVE NEW FINISHES TYP. AT EXTERIOR DOORS THAT ARE TO BE REMOVED.

MILLWORK/CASEWORK

- REMOVE AND DISPOSE OF EXISTING MILLWORK COMPLETE WITH PLUMBING AND ELECTRICAL FIXTURES AND ALL RELATED FITMENTS WHERE INDICATED BY DASHED LINES. CAP OFF ALL SERVICES IN ACCORDANCE WITH MECHANICAL, ELECTRICAL AND ABATEMENT SCOPE OF WORK. PLUMBING SERVICES TO BE CAPPED AS FAR BACK TO THE MAIN AS POSSIBLE TO ELIMINATE DEAD LEGS. MAKE GOOD ALL AFFECTED SURFACES AS REQUIRED TO LEAVE READY FOR INSTALLATION OF NEW WORK. REFER TO AND COORDINATE WITH MECHANICAL, ELECTRICAL AND ABATEMENT SCOPE OF WORK.

CEILINGS

- CEILING WORK IN CORRIDORS/AREAS OUTSIDE THE CONSTRUCTION HOARDED AREAS TO TAKE PLACE AFTER HOURS IN COORDINATION WITH OWNER.
- REMOVE AND DISPOSE OF EXISTING CEILING TILES AND T-BAR SUSPENSION GRIDS WHERE INDICATED BY DIAGONAL HATCH PATTERN. COORDINATE WITH MECHANICAL AND ELECTRICAL FOR FULL SCOPE OF REMOVALS. REMOVE ALL REDUNDANT HANGERS AND FRAMING TO MAKE FOR A CLEAN AND UNOBSTRUCTED WORK AREA READY FOR NEW WORK UNDER THIS CONTRACT.

MECHANICAL & ELECTRICAL

- COORDINATE WITH MECHANICAL DIVISION AND REMOVE PLUMBING FIXTURES, FAUCETS AND CONTROLS, FLOOR DRAINS, VENTS AND CONTROLS, MEDICAL GASES, AND CONNECTORS WHERE INDICATED. COORDINATE WITH MECHANICAL DIVISION FOR SHUT-OFF, TERMINATION, REMOVAL AND CAPPING OFF OF EXISTING DUCTWORK, PLUMBING, FIXTURES AND ACCESSORIES AS REQUIRED TO ACCOMMODATE THE DEMOLITION AND NEW WORK. TERMINATE AND CAP OFF SERVICES IN CONFORMANCE WITH MECHANICAL SCOPE OF WORK AND IN CONFORMANCE WITH ALL GOVERNING CODES AND AUTHORITIES. COORDINATE WITH MECHANICAL DIVISION FOR FULL EXTENT OF MECHANICAL DEMOLITION WORK REQUIRED. FILL AND FIRESTOP REDUNDANT CORE/SLEEVE OPENINGS IN FIRE-RATED ASSEMBLIES TYP.
- COORDINATE WITH ELECTRICAL DIVISION FOR THE SHUT-OFF, TERMINATION, REMOVAL AND CAPPING OFF OF EXISTING ELECTRICAL CONTROLS, SWITCHES AND SERVICES AS REQUIRED TO ACCOMMODATE THE DEMOLITION AND NEW WORK. TERMINATE AND CAP OFF SERVICES IN CONFORMANCE WITH ELECTRICAL SCOPE OF WORK AND IN CONFORMANCE WITH ALL GOVERNING CODES AND AUTHORITIES. COORDINATE WITH ELECTRICAL DIVISION FOR FULL EXTENT OF ELECTRICAL DEMOLITION WORK REQUIRED. FILL AND FIRESTOP REDUNDANT CORE/SLEEVE OPENINGS IN FIRE-RATED ASSEMBLIES TYP.

CLIENT:

Georgian Bay General Hospital
1112 St Andrews Dr.
Midland, ON
L4R 4P4

CONSULTANT:

CUMULUS ARCHITECTS INC.
160 Pears Ave. - Suite 300
Toronto, ON M5R 3P8
416-539-0763
www.cumulusarch.com


SEAL:



This drawing, as an instrument of service, is the property of Cumulus Architects Inc. The copyright in the same being reserved to them. No reproduction is allowed without the permission of Cumulus Architects Inc. and when made must bear its name.

This drawing is not to be scaled. The contractor is to verify dimensions and data noted herein for conformity with the conditions on site and is responsible for reporting in writing any discrepancy to Cumulus Architects Inc. for adjustment.

Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.



1 LEVEL 1 - DEMOLITION PLAN (PHASE 1)
1 : 50

3	Issued for Permit/Tender	2025-12-17
2	Issued for 100% Design Development	2025-10-14
1	Issued for Schematic Design	2025-05-26
NO	DESCRIPTION	DATE

SHEET REVISION

PROJECT:
GBGH Minor Works - Pharmacy
1112 St Andrews Dr, Midland, ON L4R 4P4

TITLE:
LEVEL 1 - DEMOLITION PLAN
(PHASE 1)

PROJECT NO:
24013B
CHECKED:
Checker

DRAWING NO:
A102

NOTE: PHASE 1 AND PHASE 3 REQUIRE
SEPARATE OCCUPANCIES TO MAINTAIN
CONTINUOUS PHARMACY OPERATION.

LEGEND - DEMOLITION PLAN

- NOT IN CONTRACT / NOT IN SCOPE AREA
- EXISTING CONSTRUCTION TO REMAIN
- EXISTING CONSTRUCTION TO BE REMOVED
- LINE OF 1 HOUR FIRE SEPARATION
- LINE OF PROPOSED CONSTRUCTION HOARDING
CONTRACTOR TO TAKE RESPONSIBILITY FOR TEMPORARY CONSTRUCTION AND
EGRESS/ACCESS ROUTES DURING CONSTRUCTION

GENERAL NOTES:

- PRIOR TO DEMOLITION NOTIFY CONSULTANTS OF ANY DISCREPANCIES WITH THE DRAWINGS.
- PRIOR TO DEMOLITION COORDINATE WITH OWNER HOURS OF OPERATION, MATERIAL AND WASTE HANDLING REQUIREMENTS AND MATERIAL TO BE REUSED.
- PROTECT AREA OF WORK, EXISTING CONSTRUCTION TO REMAIN AND ADJACENT AREAS FROM DAMAGE.
- COORDINATE WITH OWNER AND OBTAIN APPROVAL FOR SPECIAL DEMOLITION ACTIVITIES CAUSING DISTURBANCE TO OTHER OCCUPANTS AND SPACES OUTSIDE DEMOLITION AREA.
- PROVIDE DUST BARRIER TO ALL AREAS AFFECTED BY THE DEMOLITION AND PROTECT AND MAINTAIN PUBLIC AND ADJACENT TENANT AREAS (CORRIDORS, LOBBIES, ETC) DURING DEMOLITION.

REFER TO OWNER'S DESIGNATED SUBSTANCES REPORT FOR PRE-EXISTING DESIGNATED SUBSTANCES OBSERVED. NOTIFY CONSULTANT AND OWNER OF ANY DESIGNATED SUBSTANCES DISCOVERED DURING DEMOLITION. OWNER TO ARRANGE FOR REMOVAL OF ALL EXISTING FURNITURE, FITTINGS AND EQUIPMENT FROM PHASED WORK AREAS PRIOR TO START OF CONSTRUCTION.

FLOORS

- 1A MAINTAIN INTEGRITY OF EXISTING CORRIDOR AND EXITS. CORRIDOR SHALL BE FREE OF CONSTRUCTION MATERIAL AND/OR DEBRIS. EXISTING FLOORING TO REMAIN IN THIS AREA AS NOTED ON PLAN. PROVIDE LOCKING HARDWARE FOR ALL DOORS ENTERING INTO THE CONSTRUCTION AREA FROM EXISTING CORRIDOR. COORDINATE WITH OWNER TO PROVIDE CONSTRUCTION CORE LOCKSET FOR HOARDING ACCESS. PROVIDE DUST SEAL ON ALL DOORS BORDERING WORK AREA WHEN PERFORMING WORK IN CORRIDOR. ANY WORK PERFORMED OUTSIDE OF THE SCOPE AREA SHALL BE DONE AFTER HOURS AND IN COORDINATION WITH THE HOSPITAL. ALL WORK SHALL BE PERFORMED IN CONFORMANCE WITH INFECTION PREVENTION AND CONTROL GUIDELINES.

- 1B NOT USED

- 1C EXISTING FLOOR FINISH (SHEET VINYL, C/W FLASH COVE AND OTHER APPLIED BASES, ETC) TO BE REMOVED. SCRAPE AND PREPARE SUBSTRATE AS REQUIRED TO OBTAIN SMOOTH AND LEVEL SURFACE READY TO RECEIVE NEW FLOOR FINISHES AS AND WHERE SPECIFIED. CLEAN AND LEVEL EXISTING CONCRETE SUBSTRATE, INCLUDING ANY IRREGULARITIES AND PHYSICAL RESIDUE, AND FILL DEPRESSIONS AND CRACKS WITH FLOOR LEVELING COMPOUND. REMOVE ANY EXISTING MATERIAL, ADHESIVES, OIL OR DUST THAT MAY BE DETRIMENTAL TO THE BONDING OF THE NEW FLOORING. TELEGRAPHING OF SUBSTRATE THROUGH TO NEW FLOORING IS NOT PERMITTED. USE SELF-LEVELING MORTAR IN AREAS THAT NEED TO BE BUILT UP TO MATCH EXISTING FLOOR LEVELS. CONTRACTOR TO ENSURE FLOOR IS TRUE AND LEVEL TO MEET THE REQUIREMENTS OF THE NEW WORK. MAKE GOOD FLOOR SUBSTRATES WHERE EXISTING PARTITIONS HAVE BEEN DEMOLISHED (TYP.).

- 1D EXISTING CARPET AND/OR APPLIED WALL BASES TO BE REMOVED, INCLUDING MASTICS, ADHESIVES OR OTHER SURFACE RESIDUES. MAKE GOOD FLOOR SUBSTRATES WHERE EXISTING PARTITIONS HAVE BEEN DEMOLISHED TYP.

- 1E REDUNDANT FLOOR BOXES, RACEWAYS, SERVICES, DRAINS, SLEEVES/OPENINGS THROUGH EXISTING CONCRETE FLOOR SLAB SHALL BE FILLED WITH NEW CONCRETE TO OBTAIN A STRUCTURALLY SOUND, SMOOTH AND LEVEL SURFACE TO RECEIVE NEW FLOOR FINISH TYPICAL. MAKE REPAIRS AS REQUIRED MAINTAIN REQUIRED FIRE-RESISTANCE RATINGS OF FLOOR SLABS.

WALLS

- 2A REMOVE AND DISPOSE OF EXISTING GYPSUM BOARD AND METAL STUD FRAMED PARTITIONS COMPLETE WITH ASSOCIATED WALL BASE, AND CORNER GUARDS, WHERE INDICATED BY DASHED LINES. REMOVE ALL REDUNDANT MECHANICAL AND ELECTRICAL SERVICES IN CONFORMANCE WITH GOVERNING CODES AND AUTHORITIES. REFER TO AND COORDINATE WITH MECHANICAL, ELECTRICAL AND ABATEMENT SCOPE OF WORK. MAKE GOOD ALL AFFECTED SURFACES AS REQUIRED TO MATCH EXISTING, OR TO LEAVE READY TO RECEIVE NEW FINISHES TYP.

- 2B REMOVE AND DISPOSE OF EXISTING CMU WALL TO EXTENTS NOTED. PROVIDE TEMPORARY STRUCTURAL SUPPORT UNTIL NEW LINTELS CAN BE INSTALLED.

- 2C REMOVE AND DISPOSE OF EXISTING INTERIOR WALL ACCESSORIES (I.E. CORNER GUARDS, WALL BUMPERS ETC.) AND MAKE GOOD (PATCH, PAINT) ALL AFFECTED SURFACES AS REQUIRED TO MATCH EXISTING, OR TO LEAVE READY TO RECEIVE NEW FINISHES TYP.

N.B. - REMOVE AND RETAIN EXISTING WALL-MOUNTED EQUIPMENT, FITMENTS AND DEVICES, INCLUDING ALL RELATED ATTACHMENTS, MOUNTINGS, ETC. COORDINATE WITH OWNER THE EXTENT OF ITEMS TO BE RETAINED.

WINDOWS

- 3A REMOVE AND DISPOSE OF EXISTING INTERIOR WINDOWS AND FRAMES.

DOORS

- 4A REMOVE AND DISPOSE OF EXISTING DOOR, FRAME AND HARDWARE WHERE INDICATED BY DASHED LINES. ELECTRICAL TRADE TO DISCONNECT POWER FOR DOORS WITH ELECTRIFIED CONTROLS/HARDWARE. REFER TO AND COORDINATE WITH MECHANICAL, ELECTRICAL AND ABATEMENT SCOPE OF WORK. MAKE GOOD ALL AFFECTED SURFACES AS REQUIRED TO MATCH EXISTING, OR TO LEAVE READY TO RECEIVE NEW FINISHES TYP. AT EXTERIOR DOORS THAT ARE TO BE REMOVED.

MILLWORK/CASEWORK

- 5A REMOVE AND DISPOSE OF EXISTING MILLWORK COMPLETE WITH PLUMBING AND ELECTRICAL FIXTURES AND ALL RELATED FITMENTS WHERE INDICATED BY DASHED LINES. CAP OFF ALL SERVICES IN ACCORDANCE WITH MECHANICAL, ELECTRICAL AND ABATEMENT SCOPE OF WORK. PLUMBING SERVICES TO BE CAPPED AS FAR BACK TO THE MAIN AS POSSIBLE TO ELIMINATE DEAD LEGS. MAKE GOOD ALL AFFECTED SURFACES AS REQUIRED TO LEAVE READY FOR INSTALLATION OF NEW WORK. REFER TO AND COORDINATE WITH MECHANICAL, ELECTRICAL AND ABATEMENT SCOPE OF WORK.

CEILING

- 6A REMOVE AND DISPOSE OF EXISTING CEILING TILES AND T-BAR SUSPENSION GRIDS TO TAKE PLACE AFTER HOURS IN COORDINATION WITH OWNER.

- 6B REMOVE AND DISPOSE OF EXISTING CEILING TILES AND T-BAR SUSPENSION GRIDS WHERE INDICATED BY DIAGONAL HATCH PATTERN. COORDINATE WITH MECHANICAL AND ELECTRICAL FOR FULL SCOPE OF REMOVALS. REMOVE ALL REDUNDANT HANGERS AND FRAMING TO MAKE FOR A CLEAN AND UNOBSTRUCTED WORK AREA READY FOR NEW WORK UNDER THIS CONTRACT.

MECHANICAL & ELECTRICAL

- 7A COORDINATE WITH MECHANICAL DIVISION AND REMOVE PLUMBING FIXTURES, FAUCETS AND CONTROLS, FLOOR DRAINS, VENTS AND CONTROLS, MEDICAL GASES, AND CONNECTORS WHERE INDICATED. COORDINATE WITH MECHANICAL DIVISION FOR SHUT-OFF, TERMINATION, REMOVAL AND CAPPING OFF OF EXISTING DUCTWORK, PLUMBING, FIXTURES AND ACCESSORIES AS REQUIRED TO ACCOMMODATE THE DEMOLITION AND NEW WORK. TERMINATE AND CAP OFF SERVICES IN CONFORMANCE WITH MECHANICAL SCOPE OF WORK AND IN CONFORMANCE WITH ALL GOVERNING CODES AND AUTHORITIES. COORDINATE WITH MECHANICAL DIVISION FOR FULL EXTENT OF MECHANICAL DEMOLITION WORK REQUIRED. FILL AND FIRESTOP REDUNDANT CORE/SLEEVE OPENINGS IN FIRE-RATED ASSEMBLIES TYP.

- 7B COORDINATE WITH ELECTRICAL DIVISION FOR THE SHUT-OFF, TERMINATION, REMOVAL AND CAPPING OFF OF EXISTING ELECTRICAL CONTROLS, SWITCHES AND SERVICES AS REQUIRED TO ACCOMMODATE THE DEMOLITION AND NEW WORK. TERMINATE AND CAP OFF SERVICES IN CONFORMANCE WITH ELECTRICAL SCOPE OF WORK AND IN CONFORMANCE WITH ALL GOVERNING CODES AND AUTHORITIES. COORDINATE WITH ELECTRICAL DIVISION FOR FULL EXTENT OF ELECTRICAL DEMOLITION WORK REQUIRED. FILL AND FIRESTOP REDUNDANT CORE/SLEEVE OPENINGS IN FIRE-RATED ASSEMBLIES TYP.



1 LEVEL 1 - DEMOLITION PLAN (PHASE 3)
1 : 50

CLIENT:

Georgian Bay General Hospital
1112 St Andrews Dr.
Midland, ON
L4R 4P4

CONSULTANT:

Cumulus Architects Inc.
160 Pears Ave. - Suite 300
Toronto, ON M5R 3P8
416-539-0763
www.cumulusarch.com

SEAL:



This drawing, as an instrument of service, is the property of Cumulus Architects Inc. The copyright in the same being reserved to them. No reproduction is allowed without the permission of Cumulus Architects Inc. and when made must bear its name.

This drawing is not to be scaled. The contractor is to verify dimensions and data noted herein for conformity with the conditions on site and is responsible for reporting in writing any discrepancy to Cumulus Architects Inc. for adjustment.

Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.

NO	DESCRIPTION	DATE
3	Issued for Permit/Tender	2025-12-17
2	Issued for 100% Design Development	2025-10-14
1	Issued for Schematic Design	2025-05-26

SHEET REVISION


PROJECT:
GBGH Minor Works - Pharmacy
1112 St Andrews Dr, Midland, ON L4R 4P4

TITLE:
LEVEL 1 - DEMOLITION PLAN
(PHASE 3)

PROJECT NO:
24013B
CHECKED:
Checker

DRAWING NO:


A103



Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.

PROJECT NO: 24013B	DRAWING NO:
CHECKED: Checker	

A110



DRAWING NO: **A111**

NOTE: PHASE 1 AND PHASE 3 REQUIRE SEPARATE OCCUPANCIES TO MAINTAIN CONTINUOUS PHARMACY OPERATION.

LEGEND - DEMOLITION PLAN

- NOT IN CONTRACT / NOT IN SCOPE AREA
- EXISTING CONSTRUCTION TO REMAIN
- EXISTING CONSTRUCTION TO BE REMOVED
- LINE OF 1 HOUR FIRE SEPARATION
- LINE OF PROPOSED CONSTRUCTION HOARDING
- CONTRACTOR TO TAKE RESPONSIBILITY FOR TEMPORARY CONSTRUCTION AND EGRESS/ACCESS ROUTES DURING CONSTRUCTION

GENERAL NOTES:

PRIOR TO DEMOLITION NOTIFY CONSULTANTS OF ANY DISCREPANCIES WITH THE DRAWINGS.

PRIOR TO DEMOLITION COORDINATE WITH OWNER HOURS OF OPERATION, MATERIAL AND WASTE HANDLING REQUIREMENTS AND MATERIAL TO BE REUSED.

PROTECT AREA OF WORK, EXISTING CONSTRUCTION TO REMAIN AND ADJACENT AREAS FROM DAMAGE.

COORDINATE WITH OWNER AND OBTAIN APPROVAL FOR SPECIAL DEMOLITION ACTIVITIES CAUSING DISTURBANCE TO OTHER OCCUPANTS AND SPACES OUTSIDE DEMOLITION AREA.

PROVIDE DUST BARRIER TO ALL AREAS AFFECTED BY THE DEMOLITION AND PROTECT AND MAINTAIN PUBLIC AND ADJACENT TENANT AREAS (CORRIDORS, LOBBIES, ETC) DURING DEMOLITION.

REFER TO OWNER'S DESIGNATED SUBSTANCES REPORT FOR PRE-EXISTING DESIGNATED SUBSTANCES OBSERVED. NOTIFY CONSULTANT AND OWNER OF ANY DESIGNATED SUBSTANCES DISCOVERED DURING DEMOLITION.

OWNER TO ARRANGE FOR REMOVAL OF ALL EXISTING FURNITURE, FITTINGS AND EQUIPMENT FROM PHASED WORK AREAS PRIOR TO START OF CONSTRUCTION.

FLOORS

1A MAINTAIN INTEGRITY OF EXISTING CORRIDOR AND EXITS. CORRIDOR SHALL BE FREE OF CONSTRUCTION MATERIAL AND/OR DEBRIS. EXISTING FLOORING TO REMAIN IN THIS AREA AS NOTED ON PLAN. PROVIDE LOCKING HARDWARE FOR ALL DOORS ENTERING INTO THE CONSTRUCTION AREA FROM EXISTING CORRIDOR. COORDINATE WITH OWNER TO PROVIDE CONSTRUCTION CORE LOCKSET FOR HOARDING ACCESS. PROVIDE DUST SEAL ON ALL DOORS BORDERING WORK AREA WHEN PERFORMING WORK IN CORRIDOR. ANY WORK PERFORMED OUTSIDE OF THE SCOPE AREA SHALL BE DONE AFTER HOURS AND IN COORDINATION WITH THE HOSPITAL. ALL WORK SHALL BE PERFORMED IN CONFORMANCE WITH INFECTION PREVENTION AND CONTROL GUIDELINES.

1B NOT USED

1C EXISTING FLOOR FINISH (SHEET VINYL, C/W FLASH COVE AND OTHER APPLIED BASES, ETC) TO BE REMOVED. SCRAPE AND PREPARE SUBSTRATE AS REQUIRED TO OBTAIN SMOOTH AND LEVEL SURFACE READY TO RECEIVE NEW FLOOR FINISHES AS AND WHERE SPECIFIED. CLEAN AND LEVEL EXISTING CONCRETE SUBSTRATE, INCLUDING ANY IRREGULARITIES AND PHYSICAL RESIDUE, AND FILL DEPRESSIONS AND CRACKS WITH FLOOR LEVELING COMPOUND. REMOVE ANY EXISTING MATERIAL, ADHESIVES, OIL OR DUST THAT MAY BE DETRIMENTAL TO THE BONDING OF THE NEW FLOORING. TELEGRAPHING OF SUBSTRATE THROUGH TO NEW FLOORING IS NOT PERMITTED. USE SELF-LEVELING MORTAR IN AREAS THAT NEED TO BE BUILT UP TO MATCH EXISTING FLOOR LEVELS. CONTRACTOR TO ENSURE FLOOR IS TRUE AND LEVEL TO MEET THE REQUIREMENTS OF THE NEW WORK. MAKE GOOD FLOOR SUBSTRATES WHERE EXISTING PARTITIONS HAVE BEEN DEMOLISHED (TYP.).

1D EXISTING CARPET AND/OR APPLIED WALL BASES TO BE REMOVED, INCLUDING MASTICS, ADHESIVES OR OTHER SURFACE RESIDUES. MAKE GOOD FLOOR SUBSTRATES WHERE EXISTING PARTITIONS HAVE BEEN DEMOLISHED TYP.

1E REDUNDANT FLOOR BOXES, RACEWAYS, SERVICES, DRAINS, SLEEVES/OPENINGS THROUGH EXISTING CONCRETE FLOOR SLAB SHALL BE FILLED WITH NEW CONCRETE TO OBTAIN A STRUCTURALLY SOUND, SMOOTH AND LEVEL SURFACE TO RECEIVE NEW FLOOR FINISH TYPICAL. MAKE REPAIRS AS REQUIRED MAINTAIN REQUIRED FIRE-RESISTANCE RATINGS OF FLOOR SLABS.

WALLS

2A REMOVE AND DISPOSE OF EXISTING GYPSUM BOARD AND METAL STUD FRAMED PARTITIONS COMPLETE WITH ASSOCIATED WALL BASE, AND CORNER GUARDS, WHERE INDICATED BY DASHED LINES. REMOVE ALL REDUNDANT MECHANICAL AND ELECTRICAL SERVICES IN CONFORMANCE WITH GOVERNING CODES AND AUTHORITIES. REFER TO AND COORDINATE WITH MECHANICAL, ELECTRICAL AND ABATEMENT SCOPE OF WORK. MAKE GOOD ALL AFFECTED SURFACES AS REQUIRED TO MATCH EXISTING, OR TO LEAVE READY TO RECEIVE NEW FINISHES TYP.

2B REMOVE AND DISPOSE OF EXISTING CMU WALL TO EXTENTS NOTED. PROVIDE TEMPORARY STRUCTURAL SUPPORT UNTIL NEW LINTELS CAN BE INSTALLED.

2C REMOVE AND DISPOSE OF EXISTING INTERIOR WALL ACCESSORIES (I.E. CORNER GUARDS, WALL BUMPERS ETC.) AND MAKE GOOD (PATCH, PAINT) ALL AFFECTED SURFACES AS REQUIRED TO MATCH EXISTING, OR TO LEAVE READY TO RECEIVE NEW FINISHES TYP.

N.B.: REMOVE AND RETAIN EXISTING WALL-MOUNTED EQUIPMENT, FITMENTS AND DEVICES, INCLUDING ALL RELATED ATTACHMENTS, MOUNTINGS, ETC. COORDINATE WITH OWNER THE EXTENT OF ITEMS TO BE RETAINED.

WINDOWS

3A REMOVE AND DISPOSE OF EXISTING INTERIOR WINDOWS AND FRAMES.

DOORS

4A REMOVE AND DISPOSE OF EXISTING DOOR, FRAME AND HARDWARE WHERE INDICATED BY DASHED LINES. ELECTRICAL TRADE TO DISCONNECT POWER FOR DOORS WITH ELECTRIFIED CONTROLS/HARDWARE. REFER TO AND COORDINATE WITH MECHANICAL, ELECTRICAL AND ABATEMENT SCOPE OF WORK. MAKE GOOD ALL AFFECTED SURFACES AS REQUIRED TO MATCH EXISTING, OR TO LEAVE READY TO RECEIVE NEW FINISHES TYP. AT EXTERIOR DOORS THAT ARE TO BE REMOVED.

MILLWORK/CASEWORK

5A REMOVE AND DISPOSE OF EXISTING MILLWORK COMPLETE WITH PLUMBING AND ELECTRICAL FIXTURES AND ALL RELATED FITMENTS WHERE INDICATED BY DASHED LINES. CAP OFF ALL SERVICES IN ACCORDANCE WITH MECHANICAL, ELECTRICAL AND ABATEMENT SCOPE OF WORK. PLUMBING SERVICES TO BE CAPPED AS FAR BACK TO THE MAIN AS POSSIBLE TO ELIMINATE DEAD LEGS. MAKE GOOD ALL AFFECTED SURFACES AS REQUIRED TO LEAVE READY FOR INSTALLATION OF NEW WORK. REFER TO AND COORDINATE WITH MECHANICAL, ELECTRICAL AND ABATEMENT SCOPE OF WORK.

CEILING

6A CEILING WORK IN CORRIDORS/AREAS OUTSIDE THE CONSTRUCTION HOARDED AREAS TO TAKE PLACE AFTER HOURS IN COORDINATION WITH OWNER.

6B REMOVE AND DISPOSE OF EXISTING CEILING TILES AND T-BAR SUSPENSION GRIDS WHERE INDICATED BY DIAGONAL HATCH PATTERN. COORDINATE WITH MECHANICAL AND ELECTRICAL FOR FULL SCOPE OF REMOVALS. REMOVE ALL REDUNDANT HANGERS AND FRAMING TO MAKE FOR A CLEAN AND UNOBSTRUCTED WORK AREA READY FOR NEW WORK UNDER THIS CONTRACT.

MECHANICAL & ELECTRICAL

COORDINATE WITH MECHANICAL DIVISION AND REMOVE PLUMBING FIXTURES, FAUCETS AND CONTROLS, FLOOR DRAINS, VENTS AND CONTROLS, MEDICAL GASES, AND CONNECTORS WHERE INDICATED. COORDINATE WITH MECHANICAL DIVISION FOR SHUT-OFF, TERMINATION, REMOVAL AND CAPPING OFF OF EXISTING DUCTWORK, PLUMBING, FIXTURES AND ACCESSORIES AS REQUIRED TO ACCOMMODATE THE DEMOLITION AND NEW WORK. TERMINATE AND CAP OFF SERVICES IN CONFORMANCE WITH MECHANICAL SCOPE OF WORK AND IN CONFORMANCE WITH ALL GOVERNING CODES AND AUTHORITIES. COORDINATE WITH MECHANICAL DIVISION FOR FULL EXTENT OF MECHANICAL DEMOLITION WORK REQUIRED. FILL AND FIRESTOP REDUNDANT CORE/SLEEVE OPENINGS IN FIRE-RATED ASSEMBLIES TYP.

COORDINATE WITH ELECTRICAL DIVISION FOR THE SHUT-OFF, TERMINATION, REMOVAL AND CAPPING OFF OF EXISTING ELECTRICAL CONTROLS, SWITCHES AND SERVICES AS REQUIRED TO ACCOMMODATE THE DEMOLITION AND NEW WORK. TERMINATE AND CAP OFF SERVICES IN CONFORMANCE WITH ELECTRICAL SCOPE OF WORK AND IN CONFORMANCE WITH ALL GOVERNING CODES AND AUTHORITIES. COORDINATE WITH ELECTRICAL DIVISION FOR FULL EXTENT OF ELECTRICAL DEMOLITION WORK REQUIRED. FILL AND FIRESTOP REDUNDANT CORE/SLEEVE OPENINGS IN FIRE-RATED ASSEMBLIES TYP.

CLIENT:

Georgian Bay General Hospital
1112 St Andrews Dr.
Midland, ON
L4R 4P4

CONSULTANT:

CUMULUS ARCHITECTS INC.
160 Pears Ave. - Suite 300
Toronto, ON M5R 3P8
416-539-0763
www.cumulusarch.com


SEAL:



This drawing, as an instrument of service, is the property of Cumulus Architects Inc. the copyright in the same being reserved to them. No reproduction is allowed without the permission of Cumulus Architects Inc. and when made must bear its name.

This drawing is not to be scaled. The contractor is to verify dimensions and data noted herein for conformity with the conditions on site and is responsible for reporting in writing any discrepancy to Cumulus Architects Inc. for adjustment.

Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.



1 LEVEL 1 - DEMOLITION RCP (PHASE 1)
1 : 50

3	Issued for Permit/Tender	2025-12-17
2	Issued for 100% Design Development	2025-10-14
1	Issued for Schematic Design	2025-05-26
NO	DESCRIPTION	DATE

SHEET REVISION

PROJECT:
GBGH Minor Works - Pharmacy
1112 St Andrews Dr, Midland, ON L4R 4P4

TITLE:
LEVEL 1 - DEMOLITION RCP
(PHASE 1)

PROJECT NO:
24013B
CHECKED:
Checker

DRAWING NO:

A112

NOTE: PHASE 1 AND PHASE 3 REQUIRE SEPARATE OCCUPANCIES TO MAINTAIN CONTINUOUS PHARMACY OPERATION.

LEGEND - DEMOLITION PLAN

- NOT IN CONTRACT / NOT IN SCOPE AREA
- EXISTING CONSTRUCTION TO REMAIN
- EXISTING CONSTRUCTION TO BE REMOVED
- LINE OF 1 HOUR FIRE SEPARATION
- LINE OF PROPOSED CONSTRUCTION HOARDING
- CONTRACTOR TO TAKE RESPONSIBILITY FOR TEMPORARY CONSTRUCTION AND EGRESS/ACCESS ROUTES DURING CONSTRUCTION

GENERAL NOTES:

PRIOR TO DEMOLITION NOTIFY CONSULTANTS OF ANY DISCREPANCIES WITH THE DRAWINGS.

PRIOR TO DEMOLITION COORDINATE WITH OWNER HOURS OF OPERATION, MATERIAL AND WASTE HANDLING REQUIREMENTS AND MATERIAL TO BE REUSED.

PROTECT AREA OF WORK, EXISTING CONSTRUCTION TO REMAIN AND ADJACENT AREAS FROM DAMAGE.

COORDINATE WITH OWNER AND OBTAIN APPROVAL FOR SPECIAL DEMOLITION ACTIVITIES CAUSING DISTURBANCE TO OTHER OCCUPANTS AND SPACES OUTSIDE DEMOLITION AREA.

PROVIDE DUST BARRIER TO ALL AREAS AFFECTED BY THE DEMOLITION AND PROTECT AND MAINTAIN PUBLIC AND ADJACENT TENANT AREAS (CORRIDORS, LOBBIES, ETC) DURING DEMOLITION.

REFER TO OWNER'S DESIGNATED SUBSTANCES REPORT FOR PRE-EXISTING DESIGNATED SUBSTANCES OBSERVED. NOTIFY CONSULTANT AND OWNER OF ANY DESIGNATED SUBSTANCES DISCOVERED DURING DEMOLITION.

OWNER TO ARRANGE FOR REMOVAL OF ALL EXISTING FURNITURE, FITTINGS AND EQUIPMENT FROM PHASED WORK AREAS PRIOR TO START OF CONSTRUCTION.

FLOORS

1A MAINTAIN INTEGRITY OF EXISTING CORRIDOR AND EXITS. CORRIDOR SHALL BE FREE OF CONSTRUCTION MATERIAL AND/OR DEBRIS. EXISTING FLOORING TO REMAIN IN THIS AREA AS NOTED ON PLAN. PROVIDE LOCKING HARDWARE FOR ALL DOORS ENTERING INTO THE CONSTRUCTION AREA FROM EXISTING CORRIDOR. COORDINATE WITH OWNER TO PROVIDE CONSTRUCTION CORE LOCKSET FOR HOARDING ACCESS. PROVIDE DUST SEAL ON ALL DOORS BORDERING WORK AREA WHEN PERFORMING WORK IN CORRIDOR. ANY WORK PERFORMED OUTSIDE OF THE SCOPE AREA SHALL BE DONE AFTER HOURS AND IN COORDINATION WITH THE HOSPITAL. ALL WORK SHALL BE PERFORMED IN CONFORMANCE WITH INFECTION PREVENTION AND CONTROL GUIDELINES.

1B NOT USED

1C EXISTING FLOOR FINISH (SHEET VINYL, C/W FLASH COVE AND OTHER APPLIED BASES, ETC) TO BE REMOVED. SCRAPE AND PREPARE SUBSTRATE AS REQUIRED TO OBTAIN SMOOTH AND LEVEL SURFACE READY TO RECEIVE NEW FLOOR FINISHES AS AND WHERE SPECIFIED. CLEAN AND LEVEL EXISTING CONCRETE SUBSTRATE, INCLUDING ANY IRREGULARITIES AND PHYSICAL RESIDUE, AND FILL DEPRESSIONS AND CRACKS WITH FLOOR LEVELING COMPOUND. REMOVE ANY EXISTING MATERIAL, ADHESIVES, OIL OR DUST THAT MAY BE DETRIMENTAL TO THE BONDING OF THE NEW FLOORING. TELEGRAPHING OF SUBSTRATE THROUGH TO NEW FLOORING IS NOT PERMITTED. USE SELF-LEVELING MORTAR IN AREAS THAT NEED TO BE BUILT UP TO MATCH EXISTING FLOOR LEVELS. CONTRACTOR TO ENSURE FLOOR IS TRUE AND LEVEL TO MEET THE REQUIREMENTS OF THE NEW WORK. MAKE GOOD FLOOR SUBSTRATES WHERE EXISTING PARTITIONS HAVE BEEN DEMOLISHED (TYP.).

1D EXISTING CARPET AND/OR APPLIED WALL BASES TO BE REMOVED, INCLUDING MASTICS, ADHESIVES OR OTHER SURFACE RESIDUES. MAKE GOOD FLOOR SUBSTRATES WHERE EXISTING PARTITIONS HAVE BEEN DEMOLISHED TYP.

1E REDUNDANT FLOOR BOXES, RACEWAYS, SERVICES, DRAINS, SLEEVES/OPENINGS THROUGH EXISTING CONCRETE FLOOR SLAB SHALL BE FILL FILL WITH NEW CONCRETE TO OBTAIN A STRUCTURALLY SOUND, SMOOTH AND LEVEL SURFACE TO RECEIVE NEW FLOOR FINISH TYPICAL. MAKE REPAIRS AS REQUIRED MAINTAIN REQUIRED FIRE-RESISTANCE RATINGS OF FLOOR SLABS.

WALLS

2A REMOVE AND DISPOSE OF EXISTING GYPSUM BOARD AND METAL STUD FRAMED PARTITIONS COMPLETE WITH ASSOCIATED WALL BASE, AND CORNER GUARDS, WHERE INDICATED BY DASHED LINES. REMOVE ALL REDUNDANT MECHANICAL AND ELECTRICAL SERVICES IN CONFORMANCE WITH GOVERNING CODES AND AUTHORITIES. REFER TO AND COORDINATE WITH MECHANICAL, ELECTRICAL AND ABATEMENT SCOPE OF WORK. MAKE GOOD ALL AFFECTED SURFACES AS REQUIRED TO MATCH EXISTING, OR TO LEAVE READY TO RECEIVE NEW FINISHES TYP.

2B REMOVE AND DISPOSE OF EXISTING CMU WALL TO EXTENTS NOTED. PROVIDE TEMPORARY STRUCTURAL SUPPORT UNTIL NEW LINTELS CAN BE INSTALLED.

2C REMOVE AND DISPOSE OF EXISTING INTERIOR WALL ACCESSORIES (I.E. CORNER GUARDS, WALL BUMPERS ETC.) AND MAKE GOOD (PATCH, PAINT) ALL AFFECTED SURFACES AS REQUIRED TO MATCH EXISTING, OR TO LEAVE READY TO RECEIVE NEW FINISHES TYP.

N.B.: REMOVE AND RETAIN EXISTING WALL-MOUNTED EQUIPMENT, FITMENTS AND DEVICES, INCLUDING ALL RELATED ATTACHMENTS, MOUNTINGS, ETC. COORDINATE WITH OWNER THE EXTENT OF ITEMS TO BE RETAINED.

WINDOWS

3A REMOVE AND DISPOSE OF EXISTING INTERIOR WINDOWS AND FRAMES.

DOORS

4A REMOVE AND DISPOSE OF EXISTING DOOR, FRAME AND HARDWARE WHERE INDICATED BY DASHED LINES. ELECTRICAL TRADE TO DISCONNECT POWER FOR DOORS WITH ELECTRIFIED CONTROLS/HARDWARE. REFER TO AND COORDINATE WITH MECHANICAL, ELECTRICAL AND ABATEMENT SCOPE OF WORK. MAKE GOOD ALL AFFECTED SURFACES AS REQUIRED TO MATCH EXISTING, OR TO LEAVE READY TO RECEIVE NEW FINISHES TYP. AT EXTERIOR DOORS THAT ARE TO BE REMOVED.

MILLWORK/CASEWORK

5A REMOVE AND DISPOSE OF EXISTING MILLWORK COMPLETE WITH PLUMBING AND ELECTRICAL FIXTURES AND ALL RELATED FITMENTS WHERE INDICATED BY DASHED LINES. CAP OFF ALL SERVICES IN ACCORDANCE WITH MECHANICAL, ELECTRICAL AND ABATEMENT SCOPE OF WORK. PLUMBING SERVICES TO BE CAPPED AS FAR BACK TO THE MAIN AS POSSIBLE TO ELIMINATE DEAD LEGS. MAKE GOOD ALL AFFECTED SURFACES AS REQUIRED TO LEAVE READY FOR INSTALLATION OF NEW WORK. REFER TO AND COORDINATE WITH MECHANICAL, ELECTRICAL AND ABATEMENT SCOPE OF WORK.

CEILINGS

6A CEILING WORK IN CORRIDORS/AREAS OUTSIDE THE CONSTRUCTION HOARDED AREAS TO TAKE PLACE AFTER HOURS IN COORDINATION WITH OWNER.

6B REMOVE AND DISPOSE OF EXISTING CEILING TILES AND T-BAR SUSPENSION GRIDS WHERE INDICATED BY DIAGONAL HATCH PATTERN. COORDINATE WITH MECHANICAL AND ELECTRICAL FOR FULL SCOPE OF REMOVALS. REMOVE ALL REDUNDANT HANGERS AND FRAMING TO MAKE FOR A CLEAN AND UNOBSTRUCTED WORK AREA READY FOR NEW WORK UNDER THIS CONTRACT.

MECHANICAL & ELECTRICAL

COORDINATE WITH MECHANICAL DIVISION AND REMOVE PLUMBING FIXTURES, FAUCETS AND CONTROLS, FLOOR DRAINS, VENTS AND CONTROLS, MEDICAL GASES, AND CONNECTORS WHERE INDICATED. COORDINATE WITH MECHANICAL DIVISION FOR SHUT-OFF, TERMINATION, REMOVAL AND CAPPING OFF OF EXISTING DUCTWORK, PLUMBING, FIXTURES AND ACCESSORIES AS REQUIRED TO ACCOMMODATE THE DEMOLITION AND NEW WORK. TERMINATE AND CAP OFF SERVICES IN CONFORMANCE WITH MECHANICAL SCOPE OF WORK AND IN CONFORMANCE WITH ALL GOVERNING CODES AND AUTHORITIES. COORDINATE WITH MECHANICAL DIVISION FOR FULL EXTENT OF MECHANICAL DEMOLITION WORK REQUIRED. FILL AND FIRESTOP REDUNDANT CORE/SLEEVE OPENINGS IN FIRE-RATED ASSEMBLIES TYP.

7B COORDINATE WITH ELECTRICAL DIVISION FOR THE SHUT-OFF, TERMINATION, REMOVAL AND CAPPING OFF OF EXISTING ELECTRICAL CONTROLS, SWITCHES AND SERVICES AS REQUIRED TO ACCOMMODATE THE DEMOLITION AND NEW WORK. TERMINATE AND CAP OFF SERVICES IN CONFORMANCE WITH ELECTRICAL SCOPE OF WORK AND IN CONFORMANCE WITH ALL GOVERNING CODES AND AUTHORITIES. COORDINATE WITH ELECTRICAL DIVISION FOR FULL EXTENT OF ELECTRICAL DEMOLITION WORK REQUIRED. FILL AND FIRESTOP REDUNDANT CORE/SLEEVE OPENINGS IN FIRE-RATED ASSEMBLIES TYP.

CLIENT:

GEORGIAN BAY
General Hospital
1112 St Andrews Dr,
Midland, ON
L4R 4P4

CONSULTANT:

CUMULUS ARCHITECTS INC.
160 Pears Ave. - Suite 300
Toronto, ON M5R 3P8
416-539-0763
www.cumulusarch.com


SEAL:



This drawing, as an instrument of service, is the property of Cumulus Architects Inc. the copyright in the same being reserved to them. No reproduction is allowed without the permission of Cumulus Architects Inc. and when made must bear its name.

This drawing is not to be scaled. The contractor is to verify dimensions and data noted herein for conformity with the conditions on site and is responsible for reporting in writing any discrepancy to Cumulus Architects Inc. for adjustment.

Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.



3	Issued for Permit/Tender	2025-12-17
2	Issued for 100% Design Development	2025-10-14
1	Issued for Schematic Design	2025-05-26
NO	DESCRIPTION	DATE




SHEET REVISION

PROJECT:
GBGH Minor Works - Pharmacy
1112 St Andrews Dr, Midland, ON L4R 4P4






TITLE:
**LEVEL 1 - DEMOLITION RCP
(PHASE 3)**

PROJECT NO:
24013B
CHECKED:
Checker

DRAWING NO:
A113



LEGEND - DEMOLITION PLAN

- 
 NOT IN CONTRACT / NOT IN SCOPE AREA

 EXISTING CONSTRUCTION TO REMAIN

 EXISTING CONSTRUCTION TO BE REMOVED

 LINE OF 1 HOUR FIRE SEPARATION

 LINE OF PROPOSED CONSTRUCTION HOARDING
 CONTRACTOR TO TAKE RESPONSIBILITY FOR TEMPORARY CONSTRUCTION AND EGRESS/ACCESS ROUTES DURING CONSTRUCTION

GENERAL NOTES:

PRIOR TO DEMOLITION NOTIFY CONSULTANTS OF ANY DISCREPANCIES WITH THE DRAWINGS.

PRIOR TO DEMOLITION COORDINATE WITH OWNER HOURS OF OPERATION, MATERIAL AND WASTE HANDLING REQUIREMENTS AND MATERIAL TO BE REUSED.

PROTECT AREA OF WORK, EXISTING CONSTRUCTION TO REMAIN AND ADJACENT AREAS FROM DAMAGE.

COORDINATE WITH OWNER AND OBTAIN APPROVAL FOR SPECIAL DEMOLITION
ACTIVITIES CAUSING DISTURBANCE TO OTHER OCCUPANTS AND SPACES OUTSIDE
DEMOLITION AREA.

PROVIDE DUST BARRIER TO ALL AREAS AFFECTED BY THE DEMOLITION AND PROTECT AND MAINTAIN PUBLIC AND ADJACENT TENANT AREAS (CORRIDORS, LOBBIES, ETC) DURING DEMOLITION.

FF&E REFER TO OWNER'S DESIGNATED SUBSTANCES REPORT FOR PRE-EXISTING DESIGNATED SUBSTANCES OBSERVED. NOTIFY CONSULTANT AND OWNER OF ANY DESIGNATED SUBSTANCES DISCOVERED DURING DEMOLITION. OWNER TO ARRANGE FOR REMOVAL OF ALL EXISTING FURNITURE, FITTINGS AND EQUIPMENT FROM PHASED WORK AREAS PRIOR TO START OF CONSTRUCTION.

FLOORS

1A MAINTAIN INTEGRITY OF EXISTING CORRIDOR AND EXITS. CORRIDOR SHALL BE FREE OF CONSTRUCTION MATERIAL AND/OR DEBRIS. EXISTING FLOORING TO REMAIN IN THIS AREA AS NOTED ON PLAN. PROVIDE LOCKING HARDWARE FOR ALL DOORS ENTERING INTO THE CONSTRUCTION AREA FROM EXISTING CORRIDOR. COORDINATE WITH OWNER TO PROVIDE CONSTRUCTION CORE LOCKSET FOR HOARDING ACCESS. PROVIDE DUST SEAL ON ALL DOORS BORDERING WORK AREA WHEN PERFORMING WORK IN CORRIDOR. ANY WORK PERFORMED OUTSIDE OF THE SCOPE AREA SHALL BE DONE AFTER HOURS AND IN COORDINATION WITH THE HOSPITAL. ALL WORK SHALL BE PERFORMED IN CONFORMANCE WITH INFECTION PREVENTION AND CONTROL GUIDELINES.

1B NOT USED

1C EXISTING FLOOR FINISH (SHEET VINYL, C/W FLAME COVE AND OTHER APPLIED BASES, ETC.) TO BE REMOVED. SCRAPE AND PREPARE SUBSTRATE AS REQUIRED TO OBTAIN SMOOTH AND LEVEL SURFACE READY TO RECEIVE NEW FLOOR FINISHES AS AND WHERE SPECIFIED. CLEAN AND LEVEL EXISTING CONCRETE SUBSTRATE, INCLUDING ANY IRREGULARITIES AND PHYSICAL RESIDUE, AND FILL DEPRESSIONS AND CRACKS WITH FLOOR LEVELING COMPOUND. REMOVE ANY EXISTING MATERIAL, ADHESIVES, OIL OR DUST THAT MAY BE DETRIMENTAL TO THE BONDING OF THE NEW FLOORING. TELEGRAPHING OF SUBSTRATE THROUGH TO NEW FLOORING IS NOT PERMITTED. USE SELF-LEVELING MORTAR IN AREAS THAT NEED TO BE BUILT UP TO MATCH EXISTING FLOOR LEVELS. CONTRACTOR TO ENSURE FLOOR IS TRUE AND LEVEL TO MEET THE REQUIREMENTS OF THE NEW WORK. MAKE GOOD FLOOR SUBSTRATES WHERE EXISTING PARTITIONS HAVE BEEN DEMOLISHED (TYP.).

1D EXISTING CARPET AND/OR APPLIED WALL BASES TO BE REMOVED, INCLUDING MASTICS ADHESIVES OR OTHER SURFACE RESIDUES. MAKE GOOD FLOOR SUBSTRATES WHERE EXISTING PARTITIONS HAVE BEEN DEMOLISHED TYP.

1E REDUNDANT FLOOR BOXES, RACEWAYS, SERVICES, DRAINS, SLEEVES/OPENINGS
THOUGH EXISTING CONCRETE FLOOR SLAB SHALL BE FILLED WITH NEW CONCRETE TO
OBTAIN A STRUCTURALLY SOUND, SMOOTH AND LEVEL SURFACE TO RECEIVE NEW
FLOOR FINISH TYPICAL. MAKE REPAIRS AS REQUIRED MAINTAIN REQUIRED FIRE-
RESISTANCE RATINGS OF FLOOR SLABS.

WALLS

2A REMOVE AND DISPOSE OF EXISTING GYPSUM BOARD AND METAL STUD FRAMED PARTITIONS COMPLETELY WITH ASSOCIATED WALL BASE, AND CORNER GUARDS, WHERE INDICATED BY DASHED LINES. REMOVE ALL REDUNDANT MECHANICAL AND ELECTRICAL SERVICES IN CONFORMANCE WITH GOVERNING CODES AND AUTHORITIES. REFER TO AND COORDINATE WITH MECHANICAL, ELECTRICAL AND ABATEMENT SCOPE OF WORK. MAKE GOOD ALL AFFECTED SURFACES AS REQUIRED TO MATCH EXISTING, OR TO LEAVE READY TO RECEIVE NEW FINISHES TYP.

2B REMOVE AND DISPOSE OF EXISTING CMU WALL TO EXTENTS NOTED. PROVIDE TEMPORARY STRUCTURAL SUPPORT UNTIL NEW LINTELS CAN BE INSTALLED.

2C REMOVE AND DISPOSE OF EXISTING INTERIOR WALL ACCESSORIES (I.E. CORNER GUARDS, WALL BUMPERS ETC.) AND MAKE GOOD (PATCH, PAINT) ALL AFFECTED SURFACES AS REQUIRED TO MATCH EXISTING, OR TO LEAVE READY TO RECEIVE NEW FINISHES TYP.

N.B.: REMOVE AND RETAIN EXISTING WALL-MOUNTED EQUIPMENT, FITMENTS AND DEVICES, INCLUDING ALL RELATED ATTACHMENTS, MOUNTINGS, ETC. COORDINATE WITH OWNER THE EXTENT OF ITEMS TO BE RETAINED.

WINDOWS

3A REMOVE AND DISPOSE OF EXISTING INTERIOR WINDOWS AND FRAMES.

DOORS

4A REMOVE AND DISPOSE OF EXISTING DOOR, FRAME AND HARDWARE WHERE INDICATED BY DASHED LINES. ELECTRICAL TRADE TO DISCONNECT POWER FOR DOORS WITH ELECTRIFIED CONTROLS/HARDWARE. REFER TO AND COORDINATE WITH MECHANICAL, ELECTRICAL AND ABATEMENT SCOPE OF WORK. MAKE GOOD ALL AFFECTED SURFACES AS REQUIRED TO MATCH EXISTING, OR TO LEAVE READY TO RECEIVE NEW FINISHES TYP. AT EXTERIOR DOORS THAT ARE TO BE REMOVED.

MILLWORK/CASEWORK

5A REMOVE AND DISPOSE OF EXISTING MILLWORK COMPLETE WITH PLUMBING AND ELECTRICAL FIXTURES AND ALL RELATED FITMENTS WHERE INDICATED BY DASHED LINES. CAP OFF ALL SERVICES IN ACCORDANCE WITH MECHANICAL, ELECTRICAL AND ABATEMENT SCOPE OF WORK. PLUMBING SERVICES TO BE CAPPED AS FAR BACK TO THE MAIN AS POSSIBLE TO ELIMINATE DEAD LEGS. MAKE GOOD ALL AFFECTED SURFACES AS REQUIRED TO LEAVE READY FOR INSTALLATION OF NEW WORK. REFER TO AND COORDINATE WITH MECHANICAL, ELECTRICAL AND ABATEMENT SCOPE OF WORK.

CEILINGS

6A CEILING WORK IN CORRIDORS/AREAS OUTSIDE THE CONSTRUCTION HOARDED AREAS TO TAKE PLACE AFTER HOURS IN COORDINATION WITH OWNER.

68 REMOVE AND DISPOSE OF EXISTING CEILING TILES AND T-BAR SUSPENSION GRIDS WHERE INDICATED BY DIAGONAL HATCH PATTERN. COORDINATE WITH MECHANICAL AND ELECTRICAL FOR FULL SCOPE OF REMOVALS. REMOVE ALL REDUNDANT HANGERS AND FRAMING TO MAKE FOR A CLEAN AND UNOBSTRUCTED WORK AREA READY FOR NEW WORK UNDER THIS CONTRACT.

MECHANICAL & ELECTRICAL

7A COORDINATE WITH MECHANICAL DIVISION AND REMOVE PLUMBING FIXTURES, FAUCETS AND CONTROLS, FLOOR DRAINS, VENTS AND CONTROLS, MEDICAL GASES, AND CONVECTORS WHERE INDICATED. COORDINATE WITH MECHANICAL DIVISION FOR SHUT-OFF, TERMINATION, REMOVAL AND CAPPING OFF OF EXISTING DUCTWORK, PLUMBING, FIXTURES AND ACCESSORIES AS REQUIRED TO ACCOMMODATE THE DEMOLITION AND NEW WORK. TERMINATE AND CAP OFF SERVICES IN CONFORMANCE WITH MECHANICAL SCOPE OF WORK AND IN CONFORMANCE WITH ALL GOVERNING CODES AND AUTHORITIES. COORDINATE WITH MECHANICAL DIVISION FOR FULL EXTENT OF MECHANICAL DEMOLITION WORK REQUIRED. FILL AND PRESTRESS REDUNDANT CORE/SLEEVE OPENINGS IN FIRE-RATED ASSEMBLIES TYP.

7B COORDINATE WITH ELECTRICAL DIVISION FOR THE SHUT-OFF, TERMINATION, REMOVAL AND CAPPING OFF OF EXISTING ELECTRICAL CONTROLS, SWITCHES AND SERVICES AS REQUIRED TO ACCOMMODATE THE DEMOLITION AND NEW WORK. TERMINATE AND CAP OFF SERVICES IN CONFORMANCE WITH ELECTRICAL SCOPE OF WORK AND IN CONFORMANCE WITH ALL GOVERNING CODES AND AUTHORITIES. COORDINATE WITH ELECTRICAL DIVISION FOR FULL EXTENT OF ELECTRICAL DEMOLITION WORK REQUIRED. FILL AND FIRESTOP REDUNDANT CORE/SLEEVE OPENINGS IN FIRE-RATED ASSEMBLIES TYP.

CLIENT:	
---------	--



CONSULTANT:



SEAL:



This drawing, as an instrument of service, is the property of Cumulus Architects Inc., the copyright in the same being reserved to them. No reproduction is allowed without the permission of Cumulus Architects Inc. and when made must bear its name.

This drawing is not to be scaled. The contractor is to verify dimensions and data noted herein for conformity with the conditions on site and is responsible for reporting in writing any discrepancy to Cumulus Architects Inc. for adjustment.

Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.


[illegible]

3	Issued for Permit/Tender	2025-12-17
NO	DESCRIPTION	DATE
SHEET REVISION		


PROJECT:
GBGH Minor Works - Pharmacy
1112 St Andrews Dr. Midland, ON L4R 4P4

TITLE:
DEMOLITION DETAILS

PROJECT NO: 24013B	DRAWING NO: A114
CHECKED: Checker	



2 LEVEL 1 CLEAN CARTS - ENLARGED FLOOR PLAN (PHASE 0)
1:50



1 LEVEL 1 DECANT SPACE - ENLARGED FLOOR PLAN (PHASE 0)
1:50

LEGEND - ROOF PLAN

- NOT IN CONTRACT / NOT IN SCOPE AREA
- EXISTING CONSTRUCTION
- NEW CONSTRUCTION

ROOM TAG:

- ROOM NAME
DESIGNED AREA
(PROGRAMMED AREA)
- FUNCTIONAL PROGRAM
REFERENCE NUMBER

GENERAL NOTES:

ARCHITECTURAL CONSTRUCTION PLANS INDICATE PARTITION LAYOUT, TYPES AND BUILT-IN FEATURES. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO ENSURE PROPER COORDINATION WITH DOORS, DEVICES, MILLWORK, FIXTURES, FINISHES, EQUIPMENT AND FURNITURE.

ALIGNMENTS ARE DIMENSIONED FROM FINISH FACE TO FINISH FACE, UNLESS OTHERWISE NOTED. ALLOW FOR THICKNESS OF FINISHES.

VERIFY DIMENSIONS NOTED AS "CLEAR", "HOLD", "MIN", "CRITICAL", OR "V.L.F." DURING LAYOUT OF WORK. NOTIFY ARCHITECT OF DISCREPANCIES OR CONFLICTS PRIOR TO EXECUTION OF WORK.

LAYOUT ALL PARTITION LOCATIONS ON THE STRUCTURAL SLAB FOR CONSULTANT REVIEW PRIOR TO CONSTRUCTION. ADVISE CONSULTANTS OF DISCREPANCIES WITH THE DIMENSIONED PLANS OR CONFLICTS WITH OTHER PARTS OF THE WORK. ADJUST LOCATIONS AS REQUIRED BASED ON REVIEW.

PARTITIONS ARE TO BE SECURED TO THE U/S OF STRUCTURE UNLESS OTHERWISE NOTED. REFER TO STRUCTURAL DRAWINGS FOR REINFORCING AND ANCHORING DETAILS FOR ALL MASONRY WALLS.

PATCH AND REPAIR EXISTING WALLS, FLOORS, COLUMNS AND SURFACES TO REMAIN AS REQUIRED TO LEAVE THEM SMOOTH, EVEN AND/OR LEVEL TO RECEIVE NEW FINISHES. STARTING OF WORK INDICATES INSTALLERS ACCEPTANCE OF SUBSTRATE.

PROVIDE SOLID FRT BLOCKING AS REQUIRED IN PARTITION WALLS TO SUPPORT SHELVING, HANGING RODS, MILLWORK, GRAB BARS, ACCESSORIES AND OTHER ITEMS THAT ARE PART OF THIS CONTRACT. REFER TO CONSULTANT PLANS AND SPECIFICATIONS TO COORDINATE LOCATION OF BLOCKING TO SUPPORT ALL WALL MOUNTED FURNISHINGS PROVIDED BY OTHERS.

EXPOSED EDGES OF GWB TO BE TRIMMED WITH D200 BEAD, AS REQUIRED OR AS OTHERWISE DETAILED TO MAKE A TRUE AND STRAIGHT EDGE.

PARTITIONS ARE TO BE FINISHED AS PER ROOM FINISH SCHEDULE AND SPECIFICATIONS.

1 MINOR WORKS TO BE COMPLETED AS PER ELEC. EXISTING STAFF AREA TO BE USED AS DECANT SPACE.

DURING PHASE 1, AREA TO BE USED TO SUPPORT PHARMACY WORKSTATIONS.

DURING PHASE 2, AREA TO BE USED AS TEMPORARY RECEIVING AND STORAGE AREA.

2 MINOR WORKS TO BE COMPLETED AS PER MECH. AND ELEC. EXISTING FINISHES AND ARCHITECTURAL ELEMENTS TO REMAIN.

3 SCOPE OF WORK WITHIN CLEAN CARTS IN PHASE 1 IS MECHANICAL ONLY. REFER TO MECHANICAL FOR FULL EXTENT.

4 ALLOW FOR ENGINEERED STEEL LINTEL AND PATCH AND MAKE GOOD OF EXISTING CMU AT THIS LOCATION TO SUPPORT EXISTING MASONRY BLOCK WALL. SEE WALL SECTIONS.

5 LAMINATE 16mm GYPSUM BOARD ONTO WEST FACE OF COLUMN

6 PROVIDE CLEANROOM AIRTIGHTNESS. SEAL ALL PENETRATIONS. ALL ACCESS PANELS TO BE GASKETED.

7 ALL CORNERS WALL-WALL AND CEILING-WALL TO BE RADIUS WITH PVC MUD-IN TRIM. REFER TO SPECIFICATIONS FOR TRIM. SEE ALSO DETAIL 6/A610.

8 CONTRACTOR TO PROVIDE NETWORK CONNECTION BETWEEN TABLETOP FRIDGE (OS/CJ) AND C SAFE (OS/CJ). REFER TO ELECTRICAL.

9 LOW LEVEL EXHAUST. REFER TO MECH.

CLIENT:

GEORGIAN BAY
General Hospital
1112 St Andrews Dr,
Midland, ON
L4R 4P4

CONSULTANT:

CUMULUS ARCHITECTS INC.
160 Pears Ave. - Suite 300
Toronto, ON M5R 3P8
416-539-0763
www.cumulusarch.com

SEAL:



This drawing, as an instrument of service, is the property of Cumulus Architects Inc. the copyright in the same being reserved to them. No reproduction is allowed without the permission of Cumulus Architects Inc. and when made must bear its name.

This drawing is not to be scaled. The contractor is to verify dimensions and data noted herein for conformity with the conditions on site and is responsible for reporting in writing any discrepancy to Cumulus Architects Inc. for adjustment.

Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.

3	Issued for Permit/Tender	2025-12-17
2	Issued for 100% Design Development	2025-10-14
1	Issued for Schematic Design	2025-05-26
NO	DESCRIPTION	DATE

SHEET REVISION

PROJECT:
GBGH Minor Works - Pharmacy
1112 St Andrews Dr, Midland, ON L4R 4P4

TITLE:
LEVEL 1 - OVERALL FLOOR
PLAN (PHASE 0)

PROJECT NO:
24013B
CHECKED:
Checker

DRAWING NO:

A201



LEGEND - ROOF PLAN

- NOT IN CONTRACT / NOT IN SCOPE AREA
- EXISTING CONSTRUCTION
- NEW CONSTRUCTION

ROOM TAG:

- ROOM NAME
- DESIGNED AREA
- PROGRAMMED AREA
- FUNCTIONAL PROGRAM
- REFERENCE NUMBER

GENERAL NOTES:

ARCHITECTURAL CONSTRUCTION PLANS INDICATE PARTITION LAYOUT, TYPES AND BUILT-IN FEATURES. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO ENSURE PROPER COORDINATION WITH DOORS, DEVICES, MILLWORK, FIXTURES, FINISHES, EQUIPMENT AND FURNITURE.

ALIGNMENTS ARE DIMENSIONED FROM FINISH FACE TO FINISH FACE, UNLESS OTHERWISE NOTED. ALLOW FOR THICKNESS OF FINISHES.

VERIFY DIMENSIONS NOTED AS "CLEAR", "HOLD", "MIN", "CRITICAL", OR "V.I.F." DURING LAYOUT OF WORK. NOTIFY ARCHITECT OF DISCREPANCIES OR CONFLICTS PRIOR TO EXECUTION OF WORK.

LAYOUT ALL PARTITION LOCATIONS ON THE STRUCTURAL SLAB FOR CONSULTANT REVIEW PRIOR TO CONSTRUCTION. ADVISE CONSULTANTS OF DISCREPANCIES WITH THE DIMENSIONED PLANS OR CONFLICTS WITH OTHER PARTS OF THE WORK. ADJUST LOCATIONS AS REQUIRED BASED ON REVIEW.

PARTITIONS ARE TO BE SECURED TO THE U/S OF STRUCTURE UNLESS OTHERWISE NOTED. REFER TO STRUCTURAL DRAWINGS FOR REINFORCING AND ANCHORING DETAILS FOR ALL MASONRY WALLS.

PATCH AND REPAIR EXISTING WALLS, FLOORS, COLUMNS AND SURFACES TO REMAIN AS REQUIRED TO LEAVE THEM SMOOTH, EVEN AND/OR LEVEL TO RECEIVE NEW FINISHES. STARTING OF WORK INDICATES INSTALLERS ACCEPTANCE OF SUBSTRATE.

PROVIDE SOLID FRT BLOCKING AS REQUIRED IN PARTITION WALLS TO SUPPORT SHELVING, HANGING RODS, MILLWORK, GRAB BARS, ACCESSORIES AND OTHER ITEMS THAT ARE PART OF THIS CONTRACT. REFER TO CONSULTANT PLANS AND SPECIFICATIONS TO COORDINATE LOCATION OF BLOCKING TO SUPPORT ALL WALL MOUNTED FURNISHINGS PROVIDED BY OTHERS.

EXPOSED EDGES OF GWB TO BE TRIMMED WITH D200 BEAD, AS REQUIRED OR AS OTHERWISE DETAILED TO MAKE A TRUE AND STRAIGHT EDGE.

PARTITIONS ARE TO BE FINISHED AS PER ROOM FINISH SCHEDULE AND SPECIFICATIONS.

- MINOR WORKS TO BE COMPLETED AS PER ELEC. EXISTING STAFF AREA TO BE USED AS DECANT SPACE.

DURING PHASE 1, AREA 1, AREA TO BE USED TO SUPPORT PHARMACY WORKSTATIONS.

DURING PHASE 2, AREA 2, AREA TO BE USED AS TEMPORARY RECEIVING AND STORAGE AREA.

- MINOR WORKS TO BE COMPLETED AS PER MECH. AND ELEC. EXISTING FINISHES AND ARCHITECTURAL ELEMENTS TO REMAIN.

- SCOPE OF WORK WITHIN CLEAN CARTS IN PHASE IS MECHANICAL ONLY. REFER TO MECHANICAL FOR FULL EXTENT.

- ALLOW FOR ENGINEERED STEEL LINTEL AND PATCH AND MAKE GOOD OF EXISTING CMU AT THIS LOCATION TO SUPPORT EXISTING MASONRY BLOCK WALL. SEE WALL SECTIONS.

- LAMINATE 16mm GYPSUM BOARD ONTO WEST FACE OF COLUMN

- PROVIDE CLEANROOM AIRTIGHTNESS. SEAL ALL PENETRATIONS. ALL ACCESS PANELS TO BE GASKETED.

- ALL CORNERS WALL-WALL AND CEILING-WALL TO BE RADIUSED WITH PVC MUD-IN TRIM. REFER TO SPECIFICATIONS FOR TRIM. SEE ALSO DETAIL 6/A610.

- CONTRACTOR TO PROVIDE NETWORK CONNECTION BETWEEN TABLETOP FRIDGE (OS/CJ) AND C SAFE (OS/CJ). REFER TO ELECTRICAL.

- LOW LEVEL EXHAUST. REFER TO MECH.

CLIENT:

Georgian Bay General Hospital
1112 St Andrews Dr.
Midland, ON
L4R 4P4

CONSULTANT:

CUMULUS ARCHITECTS INC.
160 Pears Ave. - Suite 300
Toronto, ON M5R 3P8
416-539-0763
www.cumulusarch.com

SEAL:



This drawing, as an instrument of service, is the property of Cumulus Architects Inc. the copyright in the same being reserved to them. No reproduction is allowed without the permission of Cumulus Architects Inc. and when made must bear its name.

This drawing is not to be scaled. The contractor is to verify dimensions and data noted herein for conformity with the conditions on site and is responsible for reporting in writing any discrepancy to Cumulus Architects Inc. for adjustment.

Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.

3	Issued for Permit/Tender	2025-12-17
2	Issued for 100% Design Development	2025-10-14
1	Issued for Schematic Design	2025-05-26
NO	DESCRIPTION	DATE

SHEET REVISION

PROJECT:
GBGH Minor Works - Pharmacy
1112 St Andrews Dr, Midland, ON L4R 4P4

TITLE:
LEVEL 1 - OVERALL FLOOR
PLAN (PHASE 1)

PROJECT NO:
24013B
CHECKED:
Checker

DRAWING NO:


A202

1 LEVEL 1 - OVERALL FLOOR PLAN (PHASE 1)

1 : 50



A203



LEGEND - ROOF PLAN

- NOT IN CONTRACT / NOT IN SCOPE AREA
- EXISTING CONSTRUCTION
- NEW CONSTRUCTION

ROOM TAG:

- ROOM NAME
DESIGNED AREA
(PROGRAMMED AREA)
- FUNCTIONAL PROGRAM
REFERENCE NUMBER

GENERAL NOTES:

ARCHITECTURAL CONSTRUCTION PLANS INDICATE PARTITION LAYOUT, TYPES AND BUILT-IN FEATURES. IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO ENSURE PROPER COORDINATION WITH DOORS, DEVICES, MILLWORK, FIXTURES, FINISHES, EQUIPMENT AND FURNITURE.

ALIGNMENTS ARE DIMENSIONED FROM FINISH FACE TO FINISH FACE, UNLESS OTHERWISE NOTED. ALLOW FOR THICKNESS OF FINISHES.

VERIFY DIMENSIONS NOTED AS "CLEAR", "HOLD", "MIN", "CRITICAL", OR "V.L.F." DURING LAYOUT OF WORK. NOTIFY ARCHITECT OF DISCREPANCIES OR CONFLICTS PRIOR TO EXECUTION OF WORK.

LAYOUT ALL PARTITION LOCATIONS ON THE STRUCTURAL SLAB FOR CONSULTANT REVIEW PRIOR TO CONSTRUCTION. ADVISE CONSULTANTS OF DISCREPANCIES WITH THE DIMENSIONED PLANS OR CONFLICTS WITH OTHER PARTS OF THE WORK. ADJUST LOCATIONS AS REQUIRED BASED ON REVIEW.

PARTITIONS ARE TO BE SECURED TO THE US OF STRUCTURE UNLESS OTHERWISE NOTED. REFER TO STRUCTURAL DRAWINGS FOR REINFORCING AND ANCHORING DETAILS FOR ALL MASONRY WALLS.

PATCH AND REPAIR EXISTING WALLS, FLOORS, COLUMNS AND SURFACES TO REMAIN AS REQUIRED TO LEAVE THEM SMOOTH, EVEN AND/OR LEVEL TO RECEIVE NEW FINISHES. STARTING OF WORK INDICATES INSTALLERS ACCEPTANCE OF SUBSTRATE.

PROVIDE SOLID FRT BLOCKING AS REQUIRED IN PARTITION WALLS TO SUPPORT SHELVING, HANGING RODS, MILLWORK, GRAB BARS, ACCESSORIES AND OTHER ITEMS THAT ARE PART OF THIS CONTRACT. REFER TO CONSULTANT PLANS AND SPECIFICATIONS TO COORDINATE LOCATION OF BLOCKING TO SUPPORT ALL WALL MOUNTED FURNISHINGS PROVIDED BY OTHERS.

EXPOSED EDGES OF GWB TO BE TRIMMED WITH D200 BEAD, AS REQUIRED OR AS OTHERWISE DETAILED TO MAKE A TRUE AND STRAIGHT EDGE.

PARTITIONS ARE TO BE FINISHED AS PER ROOM FINISH SCHEDULE AND SPECIFICATIONS.

- MINOR WORKS TO BE COMPLETED AS PER ELEC. EXISTING STAFF AREA TO BE USED AS DECANT SPACE.

DURING PHASE 1, AREA TO BE USED TO SUPPORT PHARMACY WORKSTATIONS.

DURING PHASE 2, AREA TO BE USED AS TEMPORARY RECEIVING AND STORAGE AREA.
- MINOR WORKS TO BE COMPLETED AS PER MECH. AND ELEC. EXISTING FINISHES AND ARCHITECTURAL ELEMENTS TO REMAIN.
- SCOPE OF WORK WITHIN CLEAN CARTS IN PHASE 1 IS MECHANICAL ONLY. REFER TO MECHANICAL FOR FULL EXTENT.
- ALLOW FOR ENGINEERED STEEL LINTEL AND PATCH AND MAKE GOOD OF EXISTING CMU AT THIS LOCATION TO SUPPORT EXISTING MASONRY BLOCK WALL. SEE WALL SECTIONS.
- LAMINATE 16mm GYPSUM BOARD ONTO WEST FACE OF COLUMN
- PROVIDE CLEANROOM AIRTIGHTNESS. SEAL ALL PENETRATIONS. ALL ACCESS PANELS TO BE GASKETED.
- ALL CORNERS WALL-WALL AND CEILING-WALL TO BE RADIUS WITH PVC MUD-IN TRIM. REFER TO SPECIFICATIONS FOR TRIM. SEE ALSO DETAIL 6/A610.
- CONTRACTOR TO PROVIDE NETWORK CONNECTION BETWEEN TABLETOP FRIDGE (OS/CJ) AND C SAFE (OS/CJ). REFER TO ELECTRICAL.
- LOW LEVEL EXHAUST. REFER TO MECH.

CLIENT:



CONSULTANT:



SEAL:



This drawing, as an instrument of service, is the property of Cumulus Architects Inc. the copyright in the same being reserved to them. No reproduction is allowed without the permission of Cumulus Architects Inc. and when made must bear its name.

This drawing is not to be scaled. The contractor is to verify dimensions and data noted herein for conformity with the conditions on site and is responsible for reporting in writing any discrepancy to Cumulus Architects Inc. for adjustment.

Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.



PROJECT:
GBGH Minor Works - Pharmacy
1112 St Andrews Dr, Midland, ON L4R 4P4

TITLE:
LEVEL 1 - OVERALL FLOOR
PLAN (PHASE 3)

PROJECT NO:
24013B
CHECKED:
Checker

DRAWING NO:

A204



LEGEND - FINISHES PLAN

- NOT IN CONTRACT / NOT IN SCOPE AREA
- EXISTING CONSTRUCTION
- NEW CONSTRUCTION
- RSF2 FLOORING (ACCENT)

FINISHES TAG:

ROOM NAME
ROOM NUMBER
FLOOR
BASE
WALL
CEILING

WALL PROTECTION:

- WP1 - HEIGHT TO 915AFF
- WP2 - HEIGHT TO U/S OF CEILING AFF
- WP1 - HEIGHT TO UNDERSIDE OF CABINETS FROM ABOVE COUNTER
- WP1 - HEIGHT TO U/S OF CEILING AFF
- WP1 - HEIGHT TO 1000MM AFF (WASHROOMS)
- WG1 WALL GRAPHIC (SEE MATERIALS FINISH SCHEDULE)

NOTE: REFER TO INTERIOR FINISHES SCHEDULE FOR FINISH CODES

ALL WALL PAINT PT1 UNLESS OTHERWISE NOTED ON FINISHES PLAN

CLIENT:



CONSULTANT:




SEAL:



This drawing, as an instrument of service, is the property of Cumulus Architects Inc. the copyright in the same being reserved to them. No reproduction is allowed without the permission of Cumulus Architects Inc. and when made must bear its name.

This drawing is not to be scaled. The contractor is to verify dimensions and data noted herein for conformity with the conditions on site and is responsible for reporting in writing any discrepancy to Cumulus Architects Inc. for adjustment.

Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.



3	Issued for Permit/Tender	2025-12-17
2	Issued for 100% Design Development	2025-10-14
1	Issued for Schematic Design	2025-05-26
NO	DESCRIPTION	DATE

PROJECT:
GBGH Minor Works - Pharmacy
1112 St Andrews Dr, Midland, ON L4R 4P4


TITLE:
LEVEL 1 - OVERALL FINISH
PLAN

PROJECT NO:
24013B
CHECKED:
Checker


DRAWING NO:

A210


PHASE THREE:



8 CORRIDOR B WALL GRAPHIC - SOUTH
1 : 25




7 LOCKER AREA WALL GRAPHIC - EAST
1 : 25




6 STAFF BREAK ROOM WALL GRAPHIC - WEST
1 : 25


PHASE ONE:




5 MGR. OFFICE WALL GRAPHIC - SOUTH
1 : 25



4 PHARM. WORKSTATIONS WALL GRAPHIC - WEST
1 : 25




3 CART STAGING WALL GRAPHIC - WEST
1 : 25




1 PNEUMATIC TUBE WALL GRAPHIC - WEST
1 : 25

CLIENT:




1112 St Andrews Dr,
Midland, ON
L4R 4P4

CONSULTANT:



160 Pears Ave. - Suite 300
Toronto, ON M5R 3P8
416-539-0763
www.cumulusarch.com

SEAL:




This drawing, as an instrument of service, is the property of Cumulus Architects Inc. the copyright in the same being reserved to them. No reproduction is allowed without the permission of Cumulus Architects Inc. and when made must bear its name.

This drawing is not to be scaled. The contractor is to verify dimensions and data noted herein for conformity with the conditions on site and is responsible for reporting in writing any discrepancy to Cumulus Architects Inc. for adjustment.

Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.

3	Issued for Permit/Tender	2025-12-17
2	Issued for 100% Design Development	2025-10-14
1	Issued for Schematic Design	2025-05-26
NO	DESCRIPTION	DATE
SHEET REVISION		
PROJECT: GBGH Minor Works - Pharmacy 1112 St Andrews Dr, Midland, ON L4R 4P4		
TITLE: WALL GRAPHIC ELEVATIONS		
PROJECT NO: 24013B	DRAWING NO: A220	
CHECKED: Checker		



LEGEND - RCP

- EXISTING CONSTRUCTION
- NEW CONSTRUCTION
- FUTURE WORK, NOT IN SCOPE/CONTRACT
- CEILING TYPE AND ELEVATION A.F.F.
- LAY-IN ACT1 ACOUSTIC TILES IN T-BAR GRID SYSTEM. REFER TO FINISH SCHEDULE.
- GYPSON BOARD ON METAL FRAMING AS REQUIRED AND SUSPENDED FROM STRUCTURE.
- CEILING FIXTURES/DEVICES LEGEND
- NOTE: REFER TO MIE DRAWINGS AND SPECIFICATIONS FOR DEVICES.
- CEILING MOUNTED LIGHT FIXTURE.
- CEILING MOUNTED LIGHT FIXTURE - SQUARE RECESSED SPOT LIGHT.
- OCCUPANCY SENSOR
- FIRE ALARM SIGNAL SPEAKER.
- ACCESS PANEL.
- CEILING MOUNTED EXIT LIGHT WITH DIRECTIONAL ARROW AS INDICATED.
- SUPPLY AIR DIFFUSER.
- RETURN AIR GRILLE.
- SPRINKLER HEAD
- WALL-MOUNTED VANITY LIGHT
- SECURITY CAMERA
- SMOKE DETECTOR

GENERAL NOTES:

THE REFLECTED CEILING PLAN AND ASSOCIATED ENLARGED CEILING PLANS SHOW LOCATION FOR CRITICAL CEILING COMPONENTS AND DEVICES. NOT ALL CEILING ELEMENTS OF ALL TRADES ARE SHOWN. REFER TO ELECTRICAL, MECHANICAL, COMMUNICATION, A/V AND SECURITY DRAWINGS AS THEY APPLY FOR FULL SCOPE OF WORK AND QUANTITIES.

CONTRACTOR TO LAYOUT PIPING, DUCTWORK AND OTHER MAJOR ELEMENTS IN CEILING PLENUM SPACE AND COORDINATE FOR ADEQUATE CLEARANCES FOR RECESSED CEILING DEVICES TO MAINTAIN LAYOUT AS INDICATED IN THE REFLECTED CEILING PLANS. ADVISE CONSULTANTS OF DISCREPANCIES WITH THE DIMENSIONED PLANS OR CONFLICTS WITH OTHER PARTS OF THE WORK. ADJUST LOCATIONS AS REQUIRED BASED ON REVIEW.

FOR ALL ELECTRICAL ACCESSORIES AND COVERPLATES PROVIDE STANDARD WHITE COLOUR, UNLESS OTHERWISE NOTED. COORDINATE WITH ARCHITECT PRIOR TO PURCHASE AND INSTALLATION OF MATERIALS. NO BLANK PLATES ARE PERMITTED.

LOCATE UNDIMENSIONED SPRINKLER HEADS, SPEAKERS, LIGHT FIXTURES AND OTHER ITEMS IN THE CENTRE OF SUSPENDED ACOUSTIC CEILING TILES UNLESS OTHERWISE NOTED.

FINISH AND COLOUR OF ACCESS PANELS, HVAC DIFFUSERS/REGISTERS, LIGHT FIXTURES, CEILING TRIM, DRAPERY POCKETS, SPEAKER GRILLES AND OTHER CEILING MOUNTED DEVICES TO MATCH SCHEDULED CEILING COLOUR UNLESS OTHERWISE NOTED.

CUT EXISTING GWB CEILINGS AS REQUIRED TO FACILITATE INSTALLATION OF ELECTRICAL OR MECHANICAL SERVICES AND REPAIR CEILINGS TO PRE-EXISTING CONDITIONS. ALLOW FOR SUCH CEILING REPAIRS OF FLOOR LEVEL BELOW, IF REQUIRED. SCOPE OF SUCH WORK FOR REPAIRS SHALL BE ESTABLISHED AT TIME OF BID AND INCLUDED IN BASE AMOUNT.

VERIFY WITH CONSULTANT THE INSTALLATION HEIGHT OF ALL SUSPENDED OR WALL-MOUNTED LIGHTING FIXTURES PRIOR TO INSTALLATION. WHERE POSSIBLE PROVIDE 'SLACK' SUSPENSION SYSTEM TO ALLOW FOR HEIGHT ADJUSTMENT UPON CONSULTANT REVIEW IN THE FIELD.

- PROVIDE CLEANROOM AIRTIGHTNESS. SEAL ALL PENETRATIONS. ALL ACCESS PANELS TO BE GASKETED.

CLIENT:



CONSULTANT:



SEAL:



This drawing, as an instrument of service, is the property of Cumulus Architects Inc. the copyright in the same being reserved to them. No reproduction is allowed without the permission of Cumulus Architects Inc. and when made must bear its name.

This drawing is not to be scaled. The contractor is to verify dimensions and data noted herein for conformity with the conditions on site and is responsible for reporting in writing any discrepancy to Cumulus Architects Inc. for adjustment.

Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.

1 LEVEL 1 - REFLECTED CEILING PLAN

1 : 50



PROJECT:
GBGH Minor Works - Pharmacy
1112 St Andrews Dr, Midland, ON L4R 4P4

TITLE:
**LEVEL 1 - REFLECTED
CEILING PLAN**

PROJECT NO:
24013B
CHECKED:
TP

DRAWING NO:

A300



LEGEND - RCP

- EXISTING CONSTRUCTION
- NEW CONSTRUCTION
- FUTURE WORK, NOT IN SCOPE/CONTRACT
- CEILING FINISH
[XXXX AFF]
- LAY-IN ACT1 ACOUSTIC TILES IN T-BAR GRID SYSTEM. REFER TO FINISH SCHEDULE.
- GYPSUM BOARD ON METAL FRAMING AS REQUIRED AND SUSPENDED FROM STRUCTURE.

CEILING FIXTURES/DEVICES LEGEND

NOTE: REFER TO M/E DRAWINGS AND SPECIFICATIONS FOR DEVICES.

- CEILING MOUNTED LIGHT FIXTURE.
- CEILING MOUNTED LIGHT FIXTURE - SQUARE RECESSED SPOT LIGHT.
- OCCUPANCY SENSOR
- FIRE ALARM SIGNAL SPEAKER.
- ACCESS PANEL.
- CEILING MOUNTED EXIT LIGHT WITH DIRECTIONAL ARROW AS INDICATED.
- SUPPLY AIR DIFFUSER.
- RETURN AIR GRILLE.
- SPRINKLER HEAD
- WALL-MOUNTED VANITY LIGHT
- SECURITY CAMERA
- SMOKE DETECTOR

GENERAL NOTES:

THE REFLECTED CEILING PLAN AND ASSOCIATED ENLARGED CEILING PLANS SHOW LOCATION FOR CRITICAL CEILING COMPONENTS AND DEVICES. NOT ALL CEILING ELEMENTS OF ALL TRADES ARE SHOWN. REFER TO ELECTRICAL, MECHANICAL, COMMUNICATION, A/V AND SECURITY DRAWINGS AS THEY APPLY FOR FULL SCOPE OF WORK AND QUANTITIES.

CONTRACTOR TO LAYOUT PIPING, DUCTWORK AND OTHER MAJOR ELEMENTS IN CEILING PLENUM SPACE AND COORDINATE FOR ADEQUATE CLEARANCES FOR RECESSED CEILING DEVICES TO MAINTAIN LAYOUT AS INDICATED IN THE REFLECTED CEILING PLANS. ADVISE CONSULTANTS OF DISCREPANCIES WITH THE DIMENSIONED PLANS OR CONFLICTS WITH OTHER PARTS OF THE WORK. ADJUST LOCATIONS AS REQUIRED BASED ON REVIEW.

FOR ALL ELECTRICAL ACCESSORIES AND COVERPLATES PROVIDE STANDARD WHITE COLOUR, UNLESS OTHERWISE NOTED. COORDINATE WITH ARCHITECT PRIOR TO PURCHASE AND INSTALLATION OF MATERIALS. NO BLANK PLATES ARE PERMITTED.

LOCATE UNDIMENSIONED SPRINKLER HEADS, SPEAKERS, LIGHT FIXTURES AND OTHER ITEMS IN THE CENTRE OF SUSPENDED ACOUSTIC CEILING TILES UNLESS OTHERWISE NOTED.

FINISH AND COLOUR OF ACCESS PANELS, HVAC DIFFUSERS/REGISTERS, LIGHT FIXTURES, CEILING TRIM, DRAPERY POCKETS, SPEAKER GRILLES AND OTHER CEILING MOUNTED DEVICES TO MATCH SCHEDULED CEILING COLOUR UNLESS OTHERWISE NOTED.

CUT EXISTING GWB CEILINGS AS REQUIRED TO FACILITATE INSTALLATION OF ELECTRICAL OR MECHANICAL SERVICES AND REPAIR CEILINGS TO PRE-EXISTING CONDITIONS. ALLOW FOR SUCH CEILING REPAIRS OF FLOOR LEVEL BELOW, IF REQUIRED. SCOPE OF SUCH WORK FOR REPAIRS SHALL BE ESTABLISHED AT TIME OF BID AND INCLUDED IN BASE AMOUNT.

VERIFY WITH CONSULTANT THE INSTALLATION HEIGHT OF ALL SUSPENDED OR WALL-MOUNTED LIGHTING FIXTURES PRIOR TO INSTALLATION. WHERE POSSIBLE PROVIDE 'SLACK' SUSPENSION SYSTEM TO ALLOW FOR HEIGHT ADJUSTMENT UPON CONSULTANT REVIEW IN THE FIELD.

- 1 PROVIDE CLEANROOM AIRTIGHTNESS. SEAL ALL PENETRATIONS. ALL ACCESS PANELS TO BE GASKETED.

CLIENT:



CONSULTANT:



SEAL:



This drawing, as an instrument of service, is the property of Cumulus Architects Inc. the copyright in the same being reserved to them. No reproduction is allowed without the permission of Cumulus Architects Inc. and when made must bear its name.

This drawing is not to be scaled. The contractor is to verify dimensions and data noted herein for conformity with the conditions on site and is responsible for reporting in writing any discrepancy to Cumulus Architects Inc. for adjustment.

Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.

NO	DESCRIPTION	DATE
3	Issued for Permit/Tender	2025-12-17
2	Issued for 100% Design Development	2025-10-14
1	Issued for Schematic Design	2025-05-26

SHEET REVISION

PROJECT:
GBGH Minor Works - Pharmacy
1112 St Andrews Dr, Midland, ON L4R 4P4

TITLE:
**LEVEL 1 - REFLECTED
CEILING PLAN (PHASE 1)**

PROJECT NO:
24013B
CHECKED:
TP

DRAWING NO:

A301

1 LEVEL 1 - REFLECTED CEILING PLAN (PHASE 1)

1 : 50





1 LEVEL 1 - REFLECTED CEILING PLAN (PHASE 3)
1 : 50

LEGEND - RCP

- EXISTING CONSTRUCTION
- NEW CONSTRUCTION
- FUTURE WORK, NOT IN SCOPE/CONTRACT
- CEILING FINISH
XXXX AFF
- LAY-IN ACT1 ACOUSTIC TILES IN T-BAR GRID SYSTEM. REFER TO FINISH SCHEDULE.
- GYPSUM BOARD ON METAL FRAMING AS REQUIRED AND SUSPENDED FROM STRUCTURE.
- CEILING FIXTURES/DEVICES LEGEND
NOTE: REFER TO MIE DRAWINGS AND SPECIFICATIONS FOR DEVICES.
- CEILING MOUNTED LIGHT FIXTURE.
- CEILING MOUNTED LIGHT FIXTURE - SQUARE RECESSED SPOT LIGHT.
- OCCUPANCY SENSOR
- FIRE ALARM SIGNAL SPEAKER.
- ACCESS PANEL.
- CEILING MOUNTED EXIT LIGHT WITH DIRECTIONAL ARROW AS INDICATED.
- SUPPLY AIR DIFFUSER.
- RETURN AIR GRILLE.
- SPRINKLER HEAD
- WALL-MOUNTED VANITY LIGHT
- SECURITY CAMERA
- SMOKE DETECTOR

GENERAL NOTES:

THE REFLECTED CEILING PLAN AND ASSOCIATED ENLARGED CEILING PLANS SHOW LOCATION FOR CRITICAL CEILING COMPONENTS AND DEVICES. NOT ALL CEILING ELEMENTS OF ALL TRADES ARE SHOWN. REFER TO ELECTRICAL, MECHANICAL, COMMUNICATION, A/V AND SECURITY DRAWINGS AS THEY APPLY FOR FULL SCOPE OF WORK AND QUANTITIES.

CONTRACTOR TO LAYOUT PIPING, DUCTWORK AND OTHER MAJOR ELEMENTS IN CEILING PLENUM SPACE AND COORDINATE FOR ADEQUATE CLEARANCES FOR RECESSED CEILING DEVICES TO MAINTAIN LAYOUT AS INDICATED IN THE REFLECTED CEILING PLANS. ADVISE CONSULTANTS OF DISCREPANCIES WITH THE DIMENSIONED PLANS OR CONFLICTS WITH OTHER PARTS OF THE WORK. ADJUST LOCATIONS AS REQUIRED BASED ON REVIEW.

FOR ALL ELECTRICAL ACCESSORIES AND COVERPLATES PROVIDE STANDARD WHITE COLOUR, UNLESS OTHERWISE NOTED. COORDINATE WITH ARCHITECT PRIOR TO PURCHASE AND INSTALLATION OF MATERIALS. NO BLANK PLATES ARE PERMITTED.

LOCATE UNDIMENSIONED SPRINKLER HEADS, SPEAKERS, LIGHT FIXTURES AND OTHER ITEMS IN THE CENTRE OF SUSPENDED ACOUSTIC CEILING TILES UNLESS OTHERWISE NOTED.

FINISH AND COLOUR OF ACCESS PANELS, HVAC DIFFUSERS/REGISTERS, LIGHT FIXTURES, CEILING TRIM, DRAPERY POCKETS, SPEAKER GRILLES AND OTHER CEILING MOUNTED DEVICES TO MATCH SCHEDULED CEILING COLOUR UNLESS OTHERWISE NOTED.

CUT EXISTING GWB CEILINGS AS REQUIRED TO FACILITATE INSTALLATION OF ELECTRICAL OR MECHANICAL SERVICES AND REPAIR CEILINGS TO PRE-EXISTING CONDITIONS. ALLOW FOR SUCH CEILING REPAIRS OF FLOOR LEVEL BELOW, IF REQUIRED. SCOPE OF SUCH WORK FOR REPAIRS SHALL BE ESTABLISHED AT TIME OF BID AND INCLUDED IN BASE AMOUNT.

VERIFY WITH CONSULTANT THE INSTALLATION HEIGHT OF ALL SUSPENDED OR WALL-MOUNTED LIGHTING FIXTURES PRIOR TO INSTALLATION. WHERE POSSIBLE PROVIDE "SLACK" SUSPENSION SYSTEM TO ALLOW FOR HEIGHT ADJUSTMENT UPON CONSULTANT REVIEW IN THE FIELD.

1 PROVIDE CLEANROOM AIRTIGHTNESS. SEAL ALL PENETRATIONS. ALL ACCESS PANELS TO BE GASKETED.

CLIENT:



CONSULTANT:



SEAL:



This drawing, as an instrument of service, is the property of Cumulus Architects Inc. the copyright in the same being reserved to them. No reproduction is allowed without the permission of Cumulus Architects Inc. and when made must bear its name.

This drawing is not to be scaled. The contractor is to verify dimensions and data noted herein for conformity with the conditions on site and is responsible for reporting in writing any discrepancy to Cumulus Architects Inc. for adjustment.

Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.

3	Issued for Permit/Tender	2025-12-17
2	Issued for 100% Design Development	2025-10-14
1	Issued for Schematic Design	2025-05-26
NO	DESCRIPTION	DATE

SHEET REVISION


PROJECT:
GBGH Minor Works - Pharmacy
1112 St Andrews Dr, Midland, ON L4R 4P4

TITLE:
LEVEL 1 - REFLECTED
CEILING PLAN (PHASE 3)


PROJECT NO:
24013B
CHECKED:
TP

DRAWING NO:


A302



3 BUILDING SECTION - EAST WEST
1 : 50



2 BUILDING SECTION - NORTH SOUTH B
1 : 50



1 BUILDING SECTION - NORTH SOUTH A
1 : 50

CLIENT:



CONSULTANT:



SEAL:



This drawing, as an instrument of service, is the property of Cumulus Architects Inc. the copyright in the same being reserved to them. No reproduction is allowed without the permission of Cumulus Architects Inc. and when made must bear its name.

This drawing is not to be scaled. The contractor is to verify dimensions and data noted herein for conformity with the conditions on site and is responsible for reporting in writing any discrepancy to Cumulus Architects Inc. for adjustment.

Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.

NO	DESCRIPTION	DATE
3	Issued for Permit/Tender	2025-12-17
1	Issued for Schematic Design	2025-05-26





PROJECT:
GBGH Minor Works - Pharmacy
1112 St Andrews Dr, Midland, ON L4R 4P4

TITLE:
BUILDING SECTIONS

PROJECT NO:
24013B
CHECKED:
Checker

DRAWING NO:

A500



CLIENT:

GEORGIAN BAY
General Hospital

1112 St Andrews Dr,
Midland, ON
L4R 4P4

CONSULTANT:

CUMULUS ARCHITECTS INC.

160 Pears Ave. - Suite 300
Toronto, ON M5R 3P8
416-539-0763
www.cumulusarch.com

SEAL:

ONTARIO ASSOCIATION
OF
ARCHITECTS
SHELLY MORAO CATARINO
LICENCE
0177

This drawing, as an instrument of service, is the property of Cumulus Architects Inc. the copyright in the same being reserved to them. No reproduction is allowed without the permission of Cumulus Architects Inc. and when made must bear its name.

This drawing is not to be scaled. The contractor is to verify dimensions and data noted herein for conformity with the conditions on site and is responsible for reporting in writing any discrepancy to Cumulus Architects Inc. for adjustment.

Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.

NO	DESCRIPTION	DATE
3	Issued for Permit/Tender	2025-12-17

SHEET REVISION






PROJECT:
GBGH Minor Works - Pharmacy
1112 St Andrews Dr, Midland, ON L4R 4P4

TITLE:
WALL SECTIONS

PROJECT NO:
24013B

CHECKED:
Checker

DRAWING NO:
A550



CLIENT:

GEORGIAN BAY General Hospital
1112 St Andrews Dr.
Midland, ON
L4R 4P4

CONSULTANT:

CUMULUS ARCHITECTS INC.
160 Pears Ave. - Suite 300
Toronto, ON M5R 3P8
416-539-0763
www.cumulusarch.com

SEAL:

ONTARIO ASSOCIATION
OF
ARCHITECTS
SHELLY MORAO CATARINO
LICENCE
0177

This drawing, as an instrument of service, is the property of Cumulus Architects Inc. the copyright in the same being reserved to them. No reproduction is allowed without the permission of Cumulus Architects Inc. and when made must bear its name.

This drawing is not to be scaled. The contractor is to verify dimensions and data noted herein for conformity with the conditions on site and is responsible for reporting in writing any discrepancy to Cumulus Architects Inc. for adjustment.

Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.

NO	DESCRIPTION	DATE
3	Issued for Permit/Tender	2025-12-17
1	Issued for Schematic Design	2025-05-26

SHEET REVISION

PROJECT:
GBGH Minor Works - Pharmacy
1112 St Andrews Dr, Midland, ON L4R 4P4

TITLE:
TYPICAL DETAILS

PROJECT NO:
24013B

CHECKED:
Checker


DRAWING NO:
A610




Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.

DRAWING NO:


A800




18 MGR. OFFICE - SOUTH
1 : 50




17 MGR. OFFICE - EAST
1 : 50




16 MGR. OFFICE - NORTH
1 : 50




15 MGR. OFFICE - WEST
1 : 50




14 CORRIDOR A SOUTH - EAST
1 : 50




13 CORRIDOR A SOUTH - WEST
1 : 50




12 ANTEROOM - SOUTH
1 : 50




11 ANTEROOM - EAST
1 : 50




10 ANTEROOM - NORTH
1 : 50




9 ANTEROOM - WEST
1 : 50




8 STERILE PREP. - SOUTH
1 : 50




7 STERILE PREP. - EAST
1 : 50




6 STERILE PREP. - NORTH
1 : 50




5 STERILE PREP. - WEST
1 : 50




4 PHARM. WORKSTATIONS - SOUTH
1 : 50



3 PHARM. WORKSTATIONS - EAST
1 : 50



2 PHARM. WORKSTATIONS - NORTH
1 : 50



1 PHARM. WORKSTATIONS - WEST
1 : 50

CLIENT:



CONSULTANT:





SEAL:




This drawing, as an instrument of service, is the property of Cumulus Architects Inc. the copyright in the same being reserved to them. No reproduction is allowed without the permission of Cumulus Architects Inc. and when made must bear its name.

This drawing is not to be scaled. The contractor is to verify dimensions and data noted herein for conformity with the conditions on site and is responsible for reporting in writing any discrepancy to Cumulus Architects Inc. for adjustment.


Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.




NO	DESCRIPTION	DATE
3	Issued for Permit/Tender	2025-12-17
2	Issued for 100% Design Development	2025-10-14
1	Issued for Schematic Design	2025-05-26




18 CLEAN ROOM - SOUTH
1 : 50




17 CLEAN ROOM - EAST
1 : 50




16 CLEAN ROOM - NORTH
1 : 50




15 CLEAN ROOM - WEST
1 : 50




14 STAFF BREAK RM - SOUTH
1 : 50




13 STAFF BREAK ROOM - EAST
1 : 50




12 STAFF BREAK RM - NORTH
1 : 50




11 STAFF BREAK RM - WEST
1 : 50




10 CORRIDOR B NORTH - EAST
1 : 50




9 CORRIDOR B NORTH - NORTH
1 : 50




8 CORRIDOR B NORTH - WEST
1 : 50




7 RECEIVING ENTRANCE - SOUTH
1 : 50




6 RECEIVING ENTRANCE - NORTH
1 : 50




5 RECEIVING ENTRANCE - WEST
1 : 50




4 RECEIVING - SOUTH
1 : 50



3 RECEIVING - EAST
1 : 50



2 RECEIVING ROOM - NORTH
1 : 50



1 RECEIVING - WEST
1 : 50

CLIENT:



CONSULTANT:



SEAL:



This drawing, as an instrument of service, is the property of Cumulus Architects Inc. the copyright in the same being reserved to them. No reproduction is allowed without the permission of Cumulus Architects Inc. and when made must bear its name.

This drawing is not to be scaled. The contractor is to verify dimensions and data noted herein for conformity with the conditions on site and is responsible for reporting in writing any discrepancy to Cumulus Architects Inc. for adjustment.

Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.

CLIENT: _____



1112 St Andrews Dr,
Midland, ON
L4R 4P4

CONSULTANT:



160 Pears Ave. - Suite 300
Toronto, ON M5R 3P8
416-539-0763
www.cumulusarch.com


EAL: 1000



This drawing, as an instrument of service, is the property of Cumulus Architects Inc., the copyright in the same being reserved to them. No reproduction is allowed without the permission of Cumulus Architects Inc. and when made must bear its name.

This drawing is not to be scaled. The contractor is to verify dimensions and data noted herein for conformity with the conditions on site and is responsible for reporting in writing any discrepancy to Cumulus Architects Inc. for adjustment.

Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.



1 NORTH EXTERIOR CORRIDOR - SOUTH
1 : 50

3	Issued for Permit/Tender	2025-12-17
2	Issued for 100% Design Development	2025-10-14
1	Issued for Schematic Design	2025-05-26
NO	DESCRIPTION	DATE

HEET REVISION

PROJECT:
GBGH Minor Works - Pharmacy
1112 St Andrews Dr, Midland, ON L4R 4P4

TITLE:

INTERIOR ELEVATIONS

PROJECT NO:	DRAWING NO:
-------------	-------------

24013B **A0001**

CHECKED: _____

A804

Checked: _____
Checker: _____









DRAWING NO:

A0004

A804

A004

A804



CLIENT:

GEORGIAN BAY
General Hospital

1112 St Andrews Dr,
Midland, ON
L4R 4P4

CONSULTANT:

CUMULUS ARCHITECTS INC.

160 Pears Ave. - Suite 300
Toronto, ON M5R 3P8
416-539-0763
www.cumulusarch.com

SEAL:

ONTARIO ASSOCIATION OF ARCHITECTS

SHELLY MORAO CATARINO
LICENCE 0177

This drawing, as an instrument of service, is the property of Cumulus Architects Inc. the copyright in the same being reserved to them. No reproduction is allowed without the permission of Cumulus Architects Inc. and when made must bear its name.

This drawing is not to be scaled. The contractor is to verify dimensions and data noted herein for conformity with the conditions on site and is responsible for reporting in writing any discrepancy to Cumulus Architects Inc. for adjustment.

Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.

NO	DESCRIPTION	DATE
2	Issued for 100% Design Development	2025-10-14
1	Issued for Schematic Design	2025-05-26

SHEET REVISION


PROJECT:
GBGH Minor Works - Pharmacy
1112 St Andrews Dr, Midland, ON L4R 4P4

TITLE:
MILLWORK DETAILS


PROJECT NO:
24013B

CHECKED:
Checker


DRAWING NO:
A830




8 SLIP JOINT DRAW BOLT DETAIL
1:2




9 SQUARE EDGE SHELF
1:2



10 STAINLESS STEEL COUNTER TOP + CABINET EDGE
1:2




11 STAINLESS STEEL BACKSPLASH
1:2




TYP. STAINLESS STEEL COUNTERTOP UNITS


12 STAINLESS STEEL COUNTER, TYP.
1:20



6 SPW CASEWORK - EAST
1:20




5 STERILE PREP. WORKROOM - CASEWORK
1:25



3 NS COMP. CASEWORK - NORTH
1:20

2 NS COMP. CASEWORK - EAST
1:20




1 NS COMPOUNDING ROOM CASEWORK

[illegible]


PROJECT:
GBGH Minor Works - Pharmacy
112 St Andrews Dr, Midland, ON L4R 4P4

METAL CASEWORK DETAILS

PROJECT NO: 24013B	DRAWING NO: A831
CHECKED: Checker	




TYPICAL ROOM ACCESSORIES & ELECTRICAL DEVICES LAYOUTS AT DOORS (CORRIDOR SIDE)




TYPICAL ROOM ACCESSORIES & ELECTRICAL DEVICES LAYOUTS AT DOORS (ROOM SIDE)

TYPICAL ADO AT DOOR / SWING DIRECTION




LIFE SAFETY




POWER RECEPTACLES
NOTE: REFER TO ELECTRICAL DRAWINGS

ELECTRICAL DEVICES
NOTE: REFER TO ELECTRICAL DRAWINGS



HAND HYGIENE SINK STATION TYPES



ROOM ACCESSORIES

CLIENT:

Georgian Bay General Hospital
1112 St Andrews Dr,
Midland, ON
L4R 4P4

CONSULTANT:

Cumulus Architects Inc.
160 Pears Ave. - Suite 300
Toronto, ON M5R 3P8
416-539-0763
www.cumulusarch.com

SEAL:



This drawing, as an instrument of service, is the property of Cumulus Architects Inc. The copyright in the same being reserved to them. No reproduction is allowed without the permission of Cumulus Architects Inc. and when made must bear its name.

This drawing is not to be scaled. The contractor is to verify dimensions and data noted herein for conformity with the conditions on site and is responsible for reporting in writing any discrepancy to Cumulus Architects Inc. for adjustment.

Cumulus will not be liable for any claims or damages arising from the unauthorized use of this drawing or any portion thereof.

NO	DESCRIPTION	DATE
2	Issued for 100% Design Development	2025-10-14

PROJECT:
GBGH Minor Works - Pharmacy
1112 St Andrews Dr, Midland, ON L4R 4P4

TITLE:
MOUNTING HEIGHTS

PROJECT NO:
24013B
CHECKED:
Checker

DRAWING NO:
A1000