



Finance
Town of East Gwillimbury
19000 Leslie Street, Sharon ON
L0G 1V0
905-806-1728 Mobile
Email: mgerrior@eastgwillimbury.ca

Addenda #4

Renovations for Holland Landing Fire Station in the Town of East Gwillimbury - T-26-05

Thursday, April 16, 2026, 1:00 PM

Bidders are requested to incorporate the changes/clarifications noted below to the above noted Tender documents in your possession and be governed accordingly.

Where applicable bidders must acknowledge receipt of all addenda issued in the Town's Bids & Tenders Website: <https://eastgwillimbury.bidsandtenders.ca>

Where there is no evidence of receipt of all addenda, save and except any addenda which the Town deems, in its sole discretion, to be administrative in nature, the bid shall be rejected.

This addendum shall remain attached to and form part of the contract documents.

Question 1:

Kindly provide specs for the SLD doors for #36, #40, #41,#45 & #46.

Answer 1:

This is answered under previous addendum.#3

Question 2:

Are the Generator and ATS 400A to be new or are they existing and nothing is to be done to them at this time?

Answer 2:

Generator and ATS are existing and are to remain

Question 3:

Panels A, B and C, are to be removed and replace with new, or just the circuiting is to be revised as per the Proposed Panel Schedules?

Answer 3:

Panels A B and C are to be removed and replaced with new.

Question 4:

Are the Generator and ATS 400A to be new or are they existing and nothing is to be done to them at this time?

Answer 4:

Generator and ATS are existing and are to remain.

Question 5:

Panels A, B and C, are to be removed and replace with new, or just the circuiting is to be revised as per the Proposed Panel Schedules?

Answer 5:

Panels A B and C are to be removed and replaced with new.

Yours truly,

M R Gerrior

Mike Gerrior CSCMP, NIGP-CPP, CPPB, C.P.M., C. Mgr.

Manager of Procurement

Finance