

August 5, 2026

Posted via Ariba
(2 pages + 2 attachments)

ADDENDUM No. 1
REQUEST FOR TENDER No. Doc5793587590
SUBMISSION DEADLINE: 12:00 NOON (LOCAL TIME), AUGUST 21, 2026
FOR: Multiple SOGR Scopes at Various City's Facility Locations for
Toronto Police Services

Please refer to the above Request for Tender document in your possession and be advised of the following:

I. REVISIONS

R1. The Closing Date of this solicitation has been extended to **August 21, 2026**.

R2. Part 2 – Construction Agreement has been REVISED to INCLUDE Buy Ontario Act requirements. Note: The revised Part 2 is attached to this Addendum and replaces the version previously issued with the Request for Tender document.

II. ADDITIONS

ADD1. The following documents are added in Ariba:

a. Part 4, Form E - Domestic Supply Chain Plan

III. QUESTIONS AND ANSWERS

Q1. Re: TPS 52 Division - 255 Dundas Street W. Line Item No. 5.2.1.8.6.1 (Remove Existing Waterproofing and Install New Waterproofing - Including all associated works and drains):

Please clarify, if waterproofing need to be included in a Base Bid.

A1. Complete replacement of the existing waterproofing system shall be included in the Base Bid Price, including all associated works. The scope shall include waterproofing at all surface drainage locations and around all drains, extending to the underside slab drain pipe connections, complete and watertight.

Q2. May we get an extension for 1-2 weeks, please.

A2. A one week extension has been granted.

Should you have any questions regarding this addendum send via the event message board or contact Max Parker by email at Max.Parker@toronto.ca.

Suppliers must acknowledge receipt of all addenda in the space provided on Part 4 – Submission Form as per Part 1 Tender Process, Section 1 RFT Specific Process and

Submission Instructions, Item 1.7 – Addenda, of the Tender document. All other aspects of the Tender remain the same.

Yours truly,

Theodoros Maicantis, Supervisor
Purchasing & Materials Management Division